

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	25647.8 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	16.9V x 17.5H
	At 50% of Imax	8.7V x 9.0H
	At 90% of Imax	3.4V x 3.5H

Beam Flux	Total	1000.9 lumens per klm.
	To 10% of Imax	678.2 lumens per klm.
	To 50% of Imax	353.7 lumens per klm.
	To 90% of Imax	78.9 lumens per klm.

Upward LOR	2.1 %
Downward LOR	98.0 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-09-23

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME:Aurora Max-618mm-RGBW BLUE-8D-Rev1	TYPE:RGBW-BLUE	WEIGHT:
SPEC.:8 DEG	DIM.:618mm	SERIAL No.:IES001764
MFR.:	SUR.:	Shielding Angle:



DATA OF LAMP		Eff:7.77lm/W	
MODEL		Imax(cd)	11919
NOMINAL POWER(W)	59.8	AVAILABILITY(%)	67.7
RATED VOLTAGE(V)	220	Avai. FLUX(lm)	314.8
NOMINAL FLUX(lm)	464.7	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	464.7
TEST VOLTAGE(V)	220	q @50%(H,V)	9,9DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm			F t	F a
	9	8	7	6	5	4	3	2	1	0	1	2	3	4	5	6	7	8	9		
	0.09	0.11	0.14	0.17	0.21	0.25	0.29	0.31	0.33	0.33	0.31	0.29	0.25	0.21	0.17	0.14	0.12	0.10	3.82	0.00	
	0.11	0.13	0.17	0.23	0.29	0.36	0.41	0.45	0.47	0.47	0.45	0.41	0.36	0.30	0.25	0.19	0.15	0.12	5.33	2.67	
	0.12	0.16	0.23	0.31	0.40	0.52	0.62	0.70	0.74	0.74	0.71	0.62	0.52	0.42	0.34	0.27	0.20	0.15	7.75	5.98	
	0.14	0.20	0.29	0.39	0.54	0.77	0.95	1.05	1.09	1.10	1.06	0.96	0.79	0.60	0.46	0.35	0.27	0.18	11.2	9.74	
	0.17	0.25	0.35	0.49	0.73	1.01	1.29	1.46	1.57	1.57	1.48	1.31	1.10	0.85	0.62	0.44	0.34	0.25	15.3	13.9	
	0.20	0.29	0.40	0.59	0.88	1.22	1.64	1.96	2.10	2.11	1.98	1.74	1.42	1.11	0.80	0.59	0.47	0.35	19.8	19.0	
	0.22	0.31	0.45	0.68	0.99	1.42	1.93	2.45	2.67	2.69	2.50	2.18	1.78	1.38	1.13	0.86	0.64	0.47	24.8	24.2	
	0.23	0.33	0.49	0.76	1.12	1.56	2.08	2.71	3.17	3.18	2.96	2.56	2.28	1.93	1.54	1.16	0.83	0.58	29.5	28.9	
	0.22	0.33	0.50	0.78	1.15	1.59	2.14	2.74	3.34	3.49	3.38	3.22	2.90	2.44	1.93	1.43	1.01	0.69	33.3	32.7	
	0.24	0.36	0.56	0.87	1.28	1.77	2.40	3.07	3.57	3.57	3.57	3.42	3.07	2.59	2.03	1.50	1.06	0.71	35.7	35.1	
	0.27	0.41	0.66	1.00	1.48	2.07	2.77	3.16	3.40	3.42	3.32	3.16	2.80	2.34	1.84	1.37	0.97	0.65	35.1	34.8	
	0.28	0.42	0.69	1.05	1.51	1.99	2.43	2.79	3.01	3.02	2.85	2.69	2.40	2.01	1.57	1.18	0.83	0.57	31.3	31.0	
	0.27	0.41	0.64	0.97	1.28	1.64	2.00	2.29	2.48	2.49	2.34	2.14	1.90	1.60	1.27	0.97	0.68	0.47	25.8	25.6	
	0.25	0.37	0.52	0.75	1.01	1.27	1.53	1.76	1.89	1.91	1.80	1.59	1.42	1.19	0.97	0.73	0.53	0.38	19.9	19.6	
	0.21	0.30	0.40	0.55	0.73	0.92	1.12	1.28	1.37	1.38	1.31	1.16	0.98	0.85	0.69	0.53	0.40	0.29	14.5	13.7	
	0.17	0.23	0.31	0.40	0.52	0.64	0.78	0.91	0.98	0.99	0.92	0.80	0.67	0.58	0.47	0.39	0.30	0.22	10.3	9.05	
	0.14	0.17	0.24	0.31	0.37	0.44	0.52	0.58	0.62	0.62	0.59	0.53	0.46	0.39	0.35	0.28	0.21	0.17	6.98	5.12	
	0.11	0.13	0.17	0.22	0.27	0.32	0.35	0.38	0.40	0.40	0.39	0.36	0.33	0.29	0.24	0.19	0.16	0.13	4.83	1.57	
HORIZONTAL (DEG)																					
-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9			
F t	3.42	4.93	7.21	10.5	14.8	19.8	25.2	30.1	33.2	33.5	31.9	29.1	25.4	21.1	16.7	12.6	9.15	6.49	335	---	
F a	0.00	1.61	5.31	9.28	14.0	18.8	24.6	29.8	32.9	33.1	31.6	28.5	24.5	20.3	15.3	11.2	7.41	4.52	---	313	

one-half-peak spread: U:4.2,D:4.6 , L:4.5,R:4.6


NEMA Beam Type: Type 1

H_(b) Range: -90 - 90DEG
 H_(b) Interval: 0.5DEG
 Test Speed: LOW
 Temperature: 25.3DEG
 Operators: Fan
 Test Date: 2023-09-23

V(B) Range: -180 - 180DEG
 V(B) Interval: 0.5DEG
 Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
 Humidity: 65.0%
 Test Distance: 8.630m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

NAME:Aurora Max-618mm-RGBW BLUE-8D-Rev1	TYPE:RGBW-BLUE	WEIGHT:
SPEC.:8 DEG	DIM.:618mm	SERIAL No.:IES001764
MFR.:	SUR.:	Shielding Angle:




H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-09-23

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME:Aurora Max-618mm-RGBW BLUE-8D-Rev1	TYPE:RGBW-BLUE	WEIGHT:
SPEC.:8 DEG	DIM.:618mm	SERIAL No.:IES001764
MFR.:	SUR.:	Shielding Angle:



H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-09-23

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H_b Range: -90 - 90DEG
H_b Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-09-23

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME:Aurora Max-618mm-RGBW BLUE-8D-Rev1	TYPE:RGBW-BLUE	WEIGHT:
SPEC.:8 DEG	DIM.:618mm	SERIAL No.:IES001764
MFR.:	SUR.:	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

$H(b)$ Range:-90 - 90DEG
 $H(b)$ Interval: 0.5DEG
 Test Speed: LOW
 Temperature:25.3DEG
 Operators:Fan
 Test Date:2023-09-23

$V(B)$ Range:-180 - 180DEG
 $V(B)$ Interval: 0.5DEG
 Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
 Humidity:65.0%
 Test Distance:8.630m [K=1.0000]
 Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:Aurora Max-618mm-RGBW BLUE-8D-Rev1	TYPE:RGBW-BLUE	WEIGHT:
SPEC.:8 DEG	DIM.:618mm	SERIAL No.:IES001764
MFR.:	SUR.:	Shielding Angle:

Table--1

UNIT: ×10cd

H(°) \ V(°)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	0.22	0.12	0.10	0.11	0.11	0.11	0.12	0.17	0.27	0.36	0.38	0.38	0.34	0.28	0.24	0.21	0.18	0.16	0.19
-170	0.22	0.12	0.10	0.10	0.10	0.10	0.10	0.13	0.19	0.25	0.28	0.28	0.28	0.28	0.30	0.33	0.34	0.37	0.37
-160	0.22	0.12	0.10	0.10	0.10	0.09	0.08	0.09	0.11	0.14	0.15	0.16	0.17	0.21	0.25	0.29	0.32	0.34	0.34
-150	0.22	0.13	0.10	0.10	0.09	0.09	0.07	0.06	0.05	0.05	0.04	0.07	0.10	0.13	0.16	0.18	0.20	0.22	0.22
-140	0.22	0.13	0.10	0.09	0.09	0.09	0.07	0.05	0.03	0.02	0.02	0.03	0.04	0.05	0.07	0.08	0.10	0.10	0.11
-130	0.22	0.14	0.10	0.09	0.09	0.08	0.08	0.06	0.05	0.04	0.03	0.02	0.02	0.02	0.02	0.02	0.03	0.03	0.03
-120	0.22	0.15	0.11	0.09	0.09	0.08	0.08	0.07	0.07	0.07	0.06	0.05	0.05	0.04	0.04	0.03	0.03	0.03	0.03
-110	0.22	0.16	0.12	0.10	0.09	0.08	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07
-100	0.22	0.18	0.14	0.12	0.10	0.08	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07
-90	0.22	0.19	0.16	0.14	0.11	0.09	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
-80	0.22	0.20	0.18	0.16	0.13	0.09	0.06	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.04	0.04	0.04	0.04	0.04
-70	0.22	0.21	0.20	0.17	0.14	0.10	0.06	0.05	0.06	0.07	0.08	0.09	0.10	0.11	0.11	0.12	0.13	0.13	0.13
-60	0.22	0.22	0.21	0.19	0.15	0.12	0.10	0.09	0.12	0.14	0.16	0.19	0.21	0.23	0.25	0.26	0.27	0.28	0.29
-50	0.22	0.23	0.22	0.20	0.17	0.16	0.16	0.17	0.19	0.23	0.27	0.31	0.36	0.40	0.43	0.46	0.48	0.50	0.50
-40	0.22	0.24	0.24	0.22	0.20	0.21	0.24	0.27	0.29	0.33	0.40	0.47	0.54	0.63	0.71	0.80	0.87	0.93	0.94
-30	0.22	0.25	0.25	0.24	0.24	0.28	0.33	0.39	0.45	0.49	0.54	0.66	0.84	1.07	1.37	1.73	2.09	2.37	2.49
-20	0.22	0.26	0.27	0.26	0.28	0.34	0.43	0.54	0.64	0.75	0.88	1.05	1.35	2.02	2.99	4.10	5.35	6.69	7.38
-10	0.22	0.27	0.28	0.28	0.32	0.41	0.53	0.68	0.84	1.05	1.33	1.81	2.76	4.21	5.64	9.61	20.5	46.6	71.7
0	0.22	0.28	0.30	0.30	0.35	0.46	0.61	0.80	1.02	1.31	1.74	2.54	4.35	6.93	8.27	13.3	42.8	316	1101
10	0.22	0.27	0.29	0.30	0.35	0.45	0.60	0.78	0.99	1.27	1.66	2.34	3.81	6.20	7.78	9.74	18.1	40.5	58.2
20	0.22	0.27	0.29	0.29	0.33	0.42	0.55	0.71	0.90	1.13	1.43	1.84	2.56	3.92	5.78	7.18	7.78	8.33	8.68
30	0.22	0.27	0.29	0.29	0.31	0.37	0.47	0.61	0.76	0.93	1.14	1.39	1.68	2.08	2.69	3.48	4.22	4.78	4.99
40	0.22	0.26	0.28	0.28	0.29	0.33	0.39	0.48	0.60	0.73	0.86	1.01	1.17	1.34	1.51	1.64	1.76	1.84	1.87
50	0.22	0.26	0.28	0.28	0.28	0.29	0.33	0.37	0.44	0.52	0.61	0.70	0.79	0.87	0.94	1.00	1.05	1.08	1.09
60	0.22	0.25	0.27	0.27	0.27	0.27	0.28	0.30	0.32	0.35	0.39	0.43	0.48	0.54	0.58	0.61	0.64	0.65	0.66
70	0.22	0.24	0.26	0.27	0.27	0.26	0.26	0.25	0.26	0.27	0.28	0.29	0.30	0.31	0.31	0.32	0.33	0.33	0.34
80	0.22	0.23	0.25	0.26	0.26	0.27	0.26	0.26	0.26	0.25	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24	0.24
90	0.22	0.22	0.23	0.23	0.24	0.24	0.25	0.25	0.25	0.26	0.26	0.26	0.27	0.27	0.27	0.27	0.27	0.27	0.27
100	0.22	0.20	0.19	0.18	0.16	0.15	0.14	0.13	0.12	0.11	0.11	0.11	0.10	0.10	0.10	0.11	0.11	0.11	0.11
110	0.22	0.19	0.15	0.13	0.11	0.11	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.11
120	0.22	0.17	0.13	0.11	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10
130	0.22	0.15	0.11	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.11	0.12	0.13	0.14	0.16	0.18	0.20	0.21	0.21
140	0.22	0.14	0.10	0.10	0.10	0.10	0.10	0.10	0.11	0.13	0.16	0.21	0.27	0.32	0.35	0.37	0.38	0.38	0.38
150	0.22	0.13	0.10	0.10	0.10	0.11	0.11	0.11	0.14	0.21	0.29	0.34	0.37	0.39	0.40	0.41	0.41	0.41	0.41
160	0.22	0.13	0.10	0.11	0.11	0.11	0.11	0.14	0.20	0.29	0.36	0.38	0.39	0.40	0.41	0.42	0.44	0.45	0.46
170	0.22	0.12	0.10	0.11	0.11	0.11	0.12	0.16	0.25	0.34	0.38	0.39	0.38	0.37	0.37	0.38	0.39	0.40	0.43
180	0.22	0.12	0.10	0.11	0.11	0.11	0.12	0.17	0.27	0.36	0.38	0.38	0.34	0.28	0.24	0.21	0.18	0.16	0.19

H_(b) Range: -90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature: 25.3DEG

Operators: Fan

Test Date: 2023-09-23

V(B) Range: -180 - 180DEG

V(B) Interval: 0.5DEG

Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity: 65.0%

Test Distance: 8.630m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:Aurora Max-618mm-RGBW BLUE-8D-Rev1	TYPE:RGBW-BLUE	WEIGHT:
SPEC.:8 DEG	DIM.:618mm	SERIAL No.:IES001764
MFR.:	SUR.:	Shielding Angle:

Table--2

UNIT: ×10cd

H(°) \ V(°)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90
-180	0.19	0.22	0.24	0.23	0.22	0.18	0.13	0.08	0.04	0.03	0.03	0.05	0.07	0.08	0.07	0.07	0.06	0.04
-170	0.35	0.33	0.31	0.28	0.23	0.17	0.12	0.07	0.04	0.03	0.03	0.05	0.07	0.08	0.07	0.07	0.06	0.04
-160	0.33	0.31	0.27	0.23	0.18	0.14	0.09	0.05	0.03	0.03	0.03	0.05	0.07	0.08	0.07	0.07	0.06	0.04
-150	0.21	0.20	0.17	0.14	0.11	0.08	0.05	0.03	0.03	0.03	0.04	0.06	0.07	0.08	0.07	0.07	0.06	0.04
-140	0.10	0.09	0.08	0.06	0.04	0.03	0.03	0.03	0.03	0.04	0.06	0.07	0.08	0.08	0.07	0.07	0.06	0.04
-130	0.03	0.03	0.02	0.02	0.02	0.03	0.03	0.04	0.05	0.06	0.07	0.08	0.08	0.07	0.07	0.07	0.06	0.04
-120	0.03	0.03	0.04	0.04	0.05	0.06	0.06	0.07	0.07	0.08	0.08	0.08	0.08	0.07	0.07	0.06	0.05	0.04
-110	0.07	0.07	0.07	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.07	0.07	0.06	0.05	0.04
-100	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.06	0.06	0.06	0.05	0.05	0.04
-90	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.04	0.04	0.04
-80	0.04	0.04	0.04	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.04	0.04	0.04
-70	0.13	0.12	0.11	0.10	0.09	0.08	0.07	0.06	0.05	0.04	0.04	0.03	0.03	0.03	0.03	0.03	0.04	0.04
-60	0.28	0.27	0.25	0.24	0.21	0.19	0.17	0.15	0.13	0.10	0.08	0.06	0.04	0.03	0.03	0.03	0.03	0.04
-50	0.49	0.48	0.45	0.42	0.38	0.34	0.30	0.26	0.22	0.18	0.14	0.10	0.07	0.05	0.03	0.03	0.03	0.04
-40	0.93	0.87	0.80	0.71	0.63	0.55	0.47	0.39	0.32	0.26	0.20	0.15	0.11	0.07	0.04	0.03	0.03	0.04
-30	2.39	2.11	1.76	1.41	1.11	0.87	0.69	0.56	0.44	0.35	0.27	0.20	0.14	0.09	0.05	0.03	0.03	0.04
-20	6.75	5.44	4.27	3.19	2.20	1.48	1.02	0.74	0.56	0.43	0.32	0.24	0.17	0.11	0.06	0.03	0.03	0.04
-10	48.1	23.8	11.0	5.95	3.75	2.31	1.41	0.92	0.65	0.48	0.36	0.27	0.19	0.12	0.07	0.03	0.03	0.04
0	785	130	23.5	8.71	4.61	2.79	1.62	1.01	0.69	0.50	0.38	0.28	0.20	0.13	0.07	0.04	0.03	0.04
10	40.2	19.3	10.2	7.42	5.71	3.45	1.97	1.25	0.88	0.63	0.46	0.34	0.23	0.15	0.09	0.05	0.03	0.04
20	8.26	7.65	7.17	6.03	4.25	2.79	1.81	1.28	0.94	0.69	0.50	0.36	0.25	0.16	0.10	0.06	0.04	0.04
30	4.80	4.26	3.52	2.76	2.14	1.71	1.41	1.17	0.89	0.67	0.50	0.36	0.25	0.16	0.10	0.07	0.05	0.04
40	1.84	1.75	1.63	1.49	1.34	1.18	1.02	0.86	0.73	0.59	0.44	0.32	0.22	0.15	0.11	0.08	0.06	0.04
50	1.08	1.05	1.00	0.93	0.86	0.78	0.70	0.61	0.53	0.45	0.36	0.27	0.20	0.15	0.11	0.09	0.06	0.04
60	0.65	0.63	0.61	0.58	0.54	0.49	0.44	0.39	0.34	0.31	0.27	0.23	0.19	0.15	0.13	0.10	0.07	0.04
70	0.33	0.32	0.31	0.30	0.29	0.28	0.27	0.26	0.25	0.24	0.24	0.23	0.20	0.18	0.15	0.11	0.08	0.04
80	0.24	0.24	0.24	0.24	0.24	0.24	0.25	0.25	0.26	0.27	0.28	0.28	0.25	0.20	0.16	0.12	0.08	0.04
90	0.27	0.27	0.27	0.27	0.27	0.26	0.27	0.27	0.27	0.27	0.28	0.28	0.24	0.20	0.16	0.12	0.08	0.04
100	0.11	0.11	0.11	0.11	0.10	0.11	0.11	0.12	0.13	0.14	0.16	0.18	0.17	0.16	0.14	0.11	0.08	0.04
110	0.11	0.11	0.11	0.11	0.10	0.10	0.10	0.10	0.10	0.10	0.11	0.11	0.11	0.12	0.12	0.10	0.08	0.04
120	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.09	0.09	0.10	0.10	0.08	0.04
130	0.20	0.19	0.17	0.15	0.13	0.12	0.11	0.10	0.10	0.10	0.10	0.10	0.09	0.09	0.09	0.09	0.08	0.04
140	0.38	0.37	0.36	0.34	0.29	0.23	0.17	0.13	0.11	0.10	0.09	0.09	0.09	0.09	0.08	0.08	0.07	0.04
150	0.41	0.41	0.41	0.40	0.39	0.36	0.31	0.23	0.14	0.10	0.08	0.08	0.09	0.08	0.08	0.08	0.07	0.04
160	0.45	0.44	0.43	0.42	0.40	0.39	0.33	0.25	0.15	0.09	0.07	0.07	0.08	0.08	0.08	0.08	0.07	0.04
170	0.42	0.41	0.42	0.39	0.35	0.30	0.24	0.18	0.12	0.07	0.05	0.06	0.07	0.08	0.08	0.07	0.06	0.04
180	0.19	0.22	0.24	0.23	0.22	0.18	0.13	0.08	0.04	0.03	0.03	0.05	0.07	0.08	0.07	0.07	0.06	0.04

H_(b) Range: -90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature: 25.3DEG

Operators: Fan

Test Date: 2023-09-23

V(B) Range: -180 - 180DEG

V(B) Interval: 0.5DEG

Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity: 65.0%

Test Distance: 8.630m [K=1.0000]

Remarks: