

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	2919.2 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	60.3V x 59.2H
	At 50% of Imax	27.9V x 25.2H
	At 90% of Imax	8.6V x 7.3H

Beam Flux	Total	1000.1 lumens per klm.
	To 10% of Imax	771.2 lumens per klm.
	To 50% of Imax	321.2 lumens per klm.
	To 90% of Imax	39.6 lumens per klm.

Upward LOR	2.3 %
Downward LOR	97.7 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-09-05

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME:BlazeLine Slim-600mm-RGBW DS-GREEN-25D-Rev1	TYPE:RGBW DS-GREEN	WEIGHT:
SPEC.:25 DEG	DIM.:600MM	SERIAL No.:IES001639
MFR.:	SUR.:	Shielding Angle:



DATA OF LAMP		Eff:94.61lm/W	
MODEL		Imax(cd)	1717
NOMINAL POWER(W)	6.216	AVAILABILITY(%)	77.1
RATED VOLTAGE(V)	24	Avai. FLUX(lm)	453.2
NOMINAL FLUX(lm)	588.1	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	588.1
TEST VOLTAGE(V)	24	q @50%(H,V)	25,28DEG

		AREA FLUX DIAGRAM																UNIT:lm				F t	F a
VERTICAL (DEG)	45	0.11	0.15	0.20	0.25	0.31	0.35	0.39	0.41	0.42	0.41	0.38	0.34	0.29	0.24	0.19	0.14	0.11	0.08	4.74	0.00		
	40	0.14	0.19	0.26	0.34	0.43	0.52	0.59	0.64	0.66	0.64	0.59	0.51	0.42	0.33	0.25	0.19	0.14	0.10	6.94	0.00		
	35	0.17	0.25	0.34	0.46	0.61	0.77	0.91	1.03	1.08	1.05	0.96	0.81	0.64	0.48	0.34	0.24	0.17	0.12	10.4	0.21		
	30	0.21	0.31	0.44	0.62	0.85	1.13	1.42	1.66	1.78	1.74	1.56	1.28	0.98	0.69	0.47	0.31	0.21	0.14	15.8	8.65		
	25	0.24	0.37	0.55	0.81	1.18	1.65	2.22	2.68	2.92	2.85	2.51	2.00	1.46	1.00	0.64	0.40	0.25	0.15	23.9	18.8		
	20	0.28	0.43	0.67	1.03	1.58	2.35	3.34	4.26	4.70	4.53	3.86	2.96	2.09	1.37	0.85	0.50	0.29	0.17	35.3	31.1		
	15	0.31	0.49	0.77	1.25	2.01	3.17	4.76	6.45	7.23	6.76	5.53	4.07	2.76	1.78	1.08	0.60	0.33	0.18	49.5	45.8		
	-15	0.33	0.53	0.85	1.41	2.37	3.94	6.25	8.94	10.2	8.87	6.93	5.06	3.42	2.17	1.28	0.70	0.37	0.19	63.8	60.4		
		0.34	0.54	0.88	1.49	2.57	4.38	7.19	10.7	12.4	9.87	7.61	5.79	3.91	2.42	1.40	0.75	0.38	0.19	72.9	69.6		
		0.33	0.53	0.87	1.47	2.57	4.40	7.24	10.7	11.9	10.1	7.73	5.84	3.93	2.42	1.39	0.74	0.37	0.19	72.6	69.4		
		0.31	0.50	0.81	1.37	2.36	3.98	6.31	8.58	9.46	8.52	6.87	5.13	3.46	2.16	1.25	0.67	0.34	0.18	62.3	58.9		
		0.28	0.44	0.71	1.17	1.96	3.12	4.56	5.90	6.62	6.30	5.23	3.95	2.73	1.73	1.02	0.55	0.29	0.16	46.7	43.1		
		0.24	0.38	0.59	0.93	1.45	2.18	3.02	3.80	4.24	4.12	3.52	2.74	1.95	1.27	0.76	0.43	0.24	0.14	32.0	27.7		
		0.20	0.31	0.46	0.69	1.01	1.43	1.90	2.33	2.57	2.52	2.21	1.75	1.28	0.86	0.53	0.32	0.19	0.11	20.7	15.4		
		0.16	0.24	0.35	0.49	0.68	0.91	1.16	1.37	1.48	1.45	1.30	1.05	0.78	0.55	0.36	0.23	0.14	0.09	12.8	4.23		
	-30	0.12	0.18	0.26	0.35	0.45	0.57	0.69	0.79	0.83	0.81	0.73	0.61	0.47	0.34	0.24	0.16	0.11	0.07	7.79	0.00		
-35	0.09	0.13	0.18	0.24	0.30	0.36	0.42	0.46	0.47	0.46	0.42	0.35	0.28	0.22	0.16	0.12	0.08	0.06	4.83	0.00			
-40	0.07	0.10	0.13	0.17	0.20	0.24	0.26	0.28	0.28	0.27	0.25	0.22	0.18	0.14	0.11	0.09	0.06	0.04	3.09	0.00			
-45	-45	-40	-35	-30	-25	-20	-15	-10	HORIZONTAL (DEG)				10	15	20	25	30	35	40	45			
F t	3.92	6.06	9.34	14.5	22.9	35.5	52.6	71.0	79.3	71.3	58.2	44.4	31.0	20.2	12.3	7.14	4.07	2.37	546	---			
F a	0.00	0.00	0.00	7.33	17.4	30.6	48.3	66.9	75.4	67.2	54.1	40.1	26.3	14.8	4.86	0.00	0.00	0.00	---	453			

one-half-peak spread: U:13.6,D:14.6 , L:11.0,R:14.5


NEMA Beam Type: Type 4

H_(b) Range: -90 - 90DEG
 H_(b) Interval: 0.5DEG
 Test Speed: LOW
 Temperature: 25.3DEG
 Operators: Fan
 Test Date: 2023-09-05

V(B) Range: -180 - 180DEG
 V(B) Interval: 0.5DEG
 Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
 Humidity: 65.0%
 Test Distance: 8.630m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

NAME:BlazeLine Slim-600mm-RGBW DS-GREEN-25D-Rev1	TYPE:RGBW DS-GREEN	WEIGHT:
SPEC.:25 DEG	DIM.:600MM	SERIAL No.:IES001639
MFR.:	SUR.:	Shielding Angle:




H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-09-05

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME:BlazeLine Slim-600mm-RGBW DS-GREEN-25D-Rev1	TYPE:RGBW DS-GREEN	WEIGHT:
SPEC.:25 DEG	DIM.:600MM	SERIAL No.:IES001639
MFR.:	SUR.:	Shielding Angle:



H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-09-05

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H_b Range: -90 - 90DEG
H_b Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-09-05

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME:BlazeLine Slim-600mm-RGBW DS-GREEN-25D-Rev1	TYPE:RGBW DS-GREEN	WEIGHT:
SPEC.:25 DEG	DIM.:600MM	SERIAL No.:IES001639
MFR.:	SUR.:	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-09-05

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:BlazeLine Slim-600mm-RGBW DS-GREEN-25D-Rev1	TYPE:RGBW DS-GREEN	WEIGHT:
SPEC.:25 DEG	DIM.:600MM	SERIAL No.:IES001639
MFR.:	SUR.:	Shielding Angle:

Table--1

UNIT: cd

H(DEC) V(DEC)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	2.24	2.03	1.86	1.78	1.80	1.91	2.15	2.51	2.98	3.52	4.03	4.42	4.66	4.74	4.73	4.65	4.56	4.44	4.46
-170	2.24	2.00	1.81	1.71	1.69	1.74	1.89	2.11	2.38	2.70	2.98	3.20	3.31	3.33	3.29	3.35	3.63	3.84	4.05
-160	2.24	1.97	1.77	1.63	1.58	1.57	1.62	1.69	1.78	1.86	1.92	1.93	1.94	2.31	2.66	3.02	3.30	3.50	3.66
-150	2.24	1.95	1.73	1.57	1.49	1.41	1.37	1.35	1.29	1.19	1.10	1.26	1.49	1.75	2.02	2.28	2.50	2.66	2.75
-140	2.24	1.94	1.70	1.53	1.40	1.30	1.19	1.09	0.98	0.92	0.92	0.96	1.06	1.17	1.31	1.45	1.58	1.67	1.72
-130	2.24	1.93	1.69	1.50	1.34	1.21	1.09	0.94	0.88	0.87	0.87	0.85	0.83	0.81	0.85	0.89	0.93	0.96	0.98
-120	2.24	1.94	1.69	1.47	1.31	1.15	1.01	0.91	0.91	0.90	0.89	0.87	0.85	0.83	0.81	0.79	0.78	0.76	0.75
-110	2.24	1.95	1.69	1.47	1.27	1.10	0.95	0.91	0.91	0.91	0.91	0.91	0.91	0.90	0.89	0.89	0.87	0.85	0.83
-100	2.24	1.97	1.71	1.48	1.25	1.05	0.86	0.85	0.86	0.86	0.86	0.87	0.88	0.88	0.88	0.87	0.87	0.87	0.87
-90	2.24	1.99	1.74	1.49	1.24	0.99	0.73	0.73	0.72	0.72	0.71	0.70	0.70	0.70	0.71	0.71	0.72	0.73	0.73
-80	2.24	2.03	1.79	1.54	1.27	0.98	0.67	0.63	0.62	0.61	0.60	0.60	0.60	0.59	0.59	0.59	0.58	0.58	0.57
-70	2.24	2.07	1.87	1.67	1.44	1.18	0.78	0.64	0.78	0.95	1.13	1.31	1.48	1.63	1.77	1.88	1.96	2.00	2.00
-60	2.24	2.13	2.01	1.94	1.91	1.68	1.50	1.48	1.99	2.47	3.01	3.59	4.19	4.83	5.46	6.00	6.35	6.52	6.47
-50	2.24	2.19	2.21	2.47	2.54	2.72	3.00	3.24	4.03	5.50	7.45	9.69	12.0	14.1	16.0	17.4	18.3	18.5	18.1
-40	2.24	2.26	2.51	2.97	3.47	4.18	5.32	7.36	8.61	11.8	16.4	21.4	26.8	32.3	37.5	42.3	45.7	47.2	46.3
-30	2.24	2.34	2.90	3.57	4.53	6.10	10.1	12.5	15.3	21.4	29.5	40.0	53.2	69.2	88.1	109	129	142	144
-20	2.24	2.43	3.23	4.19	5.63	8.77	14.7	16.3	22.6	32.6	46.6	67.2	98.0	143	205	283	360	421	437
-10	2.24	2.51	3.52	4.77	6.64	12.1	17.8	19.7	29.1	42.8	63.4	95.4	148	239	392	611	853	1025	1044
0	2.24	2.57	3.74	5.21	7.41	14.6	20.1	22.2	32.9	48.6	72.4	109	171	281	467	771	1214	1653	1604
10	2.24	2.57	3.67	5.04	7.08	12.8	18.8	21.3	31.5	46.4	68.5	102	157	247	391	608	886	1127	1119
20	2.24	2.54	3.51	4.71	6.45	10.1	16.6	19.1	26.8	38.7	55.4	79.3	113	162	229	318	412	472	486
30	2.24	2.51	3.29	4.29	5.66	7.86	12.6	16.0	20.3	28.5	39.3	52.5	69.0	89.7	114	141	163	178	181
40	2.24	2.47	3.00	3.84	4.84	6.14	8.16	11.2	13.7	18.4	24.5	31.4	39.0	47.2	55.3	61.5	66.0	68.1	67.0
50	2.24	2.42	2.76	3.42	3.99	4.80	5.78	7.05	8.53	10.6	13.5	16.8	20.4	24.0	26.7	28.6	29.8	30.1	29.4
60	2.24	2.38	2.59	2.92	3.36	3.69	4.16	4.72	5.55	6.47	7.45	8.43	9.52	10.6	11.6	12.3	12.8	13.0	12.8
70	2.24	2.34	2.46	2.61	2.80	3.01	3.15	3.30	3.58	3.91	4.28	4.65	5.00	5.31	5.56	5.75	5.87	5.92	5.91
80	2.24	2.30	2.35	2.43	2.50	2.57	2.64	2.68	2.73	2.76	2.80	2.83	2.85	2.88	2.90	2.92	2.94	2.94	2.93
90	2.24	2.25	2.27	2.28	2.29	2.31	2.32	2.30	2.29	2.27	2.25	2.24	2.22	2.21	2.21	2.20	2.19	2.19	2.18
100	2.24	2.22	2.19	2.16	2.14	2.13	2.11	2.06	2.02	1.97	1.92	1.89	1.85	1.84	1.82	1.81	1.81	1.80	1.80
110	2.24	2.18	2.11	2.06	2.01	1.97	1.93	1.88	1.83	1.80	1.77	1.75	1.74	1.74	1.73	1.73	1.72	1.72	1.71
120	2.24	2.14	2.05	1.97	1.91	1.86	1.83	1.79	1.78	1.78	1.80	1.83	1.87	1.92	1.97	2.01	2.03	2.06	2.06
130	2.24	2.11	2.00	1.90	1.83	1.80	1.79	1.79	1.86	1.95	2.08	2.21	2.36	2.51	2.66	2.80	2.91	2.98	3.01
140	2.24	2.08	1.95	1.85	1.80	1.79	1.82	1.93	2.10	2.32	2.57	2.85	3.15	3.43	3.68	3.88	4.04	4.14	4.18
150	2.24	2.06	1.91	1.81	1.78	1.80	1.92	2.12	2.41	2.75	3.15	3.55	3.93	4.25	4.50	4.70	4.82	4.89	4.93
160	2.24	2.04	1.89	1.79	1.79	1.85	2.03	2.31	2.69	3.15	3.64	4.07	4.41	4.64	4.83	4.96	5.01	5.08	5.17
170	2.24	2.03	1.87	1.79	1.79	1.89	2.12	2.46	2.90	3.43	3.93	4.35	4.60	4.75	4.80	4.81	4.79	4.77	4.87
180	2.24	2.03	1.86	1.78	1.80	1.91	2.15	2.51	2.98	3.52	4.03	4.42	4.66	4.74	4.73	4.65	4.56	4.44	4.51

H_(b) Range:-90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-09-05

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:BlazeLine Slim-600mm-RGBW DS-GREEN-25D-Rev1	TYPE:RGBW DS-GREEN	WEIGHT:
SPEC.:25 DEG	DIM.:600MM	SERIAL No.:IES001639
MFR.:	SUR.:	Shielding Angle:

Table--2

UNIT: cd

H(°) \ V(°)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90
-180	4.01	3.74	3.55	3.28	2.93	2.53	2.11	1.70	1.32	1.02	0.83	0.79	0.80	0.85	0.85	0.84	0.78	0.68
-170	3.89	3.77	3.86	3.50	3.18	2.75	2.29	1.78	1.34	1.03	0.84	0.79	0.81	0.84	0.85	0.84	0.78	0.68
-160	3.62	3.53	3.35	3.18	2.93	2.64	2.10	1.62	1.22	0.96	0.82	0.79	0.81	0.84	0.85	0.83	0.78	0.68
-150	2.74	2.64	2.48	2.33	2.12	1.86	1.57	1.28	1.03	0.87	0.80	0.79	0.81	0.84	0.85	0.83	0.78	0.68
-140	1.72	1.67	1.57	1.43	1.31	1.18	1.04	0.93	0.86	0.81	0.79	0.80	0.83	0.85	0.85	0.83	0.77	0.68
-130	0.98	0.96	0.93	0.88	0.83	0.80	0.79	0.79	0.79	0.79	0.79	0.82	0.85	0.85	0.84	0.82	0.75	0.68
-120	0.75	0.75	0.76	0.76	0.77	0.78	0.79	0.80	0.80	0.82	0.84	0.84	0.85	0.84	0.85	0.84	0.83	0.79
-110	0.82	0.82	0.83	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.85	0.85	0.84	0.83	0.81	0.77	0.72	0.68
-100	0.87	0.86	0.85	0.85	0.84	0.83	0.83	0.83	0.83	0.84	0.84	0.83	0.81	0.79	0.76	0.73	0.71	0.68
-90	0.72	0.72	0.71	0.70	0.69	0.68	0.69	0.70	0.71	0.72	0.73	0.73	0.73	0.72	0.71	0.70	0.69	0.68
-80	0.57	0.57	0.57	0.56	0.56	0.56	0.56	0.58	0.59	0.61	0.62	0.65	0.67	0.68	0.68	0.69	0.69	0.68
-70	1.95	1.85	1.73	1.58	1.42	1.26	1.13	0.99	0.85	0.74	0.65	0.66	0.75	0.76	0.70	0.69	0.68	0.68
-60	6.24	5.84	5.32	4.70	4.03	3.50	3.00	2.51	2.07	1.66	1.31	1.12	0.99	0.98	0.90	0.72	0.69	0.68
-50	17.3	15.9	14.2	12.3	10.3	8.64	7.01	5.54	4.23	3.19	2.59	2.16	1.68	1.26	1.13	0.86	0.69	0.68
-40	43.9	39.5	33.8	27.7	22.4	17.7	13.8	10.5	7.79	5.91	5.28	4.11	2.77	1.84	1.31	1.04	0.71	0.68
-30	137	117	93.7	71.0	51.4	36.0	24.9	17.4	12.4	8.94	7.52	7.09	4.44	2.61	1.58	1.21	0.72	0.68
-20	403	334	257	183	119	73.5	44.5	27.5	17.7	12.0	8.71	9.07	6.78	3.45	1.88	1.34	0.73	0.68
-10	904	716	517	348	217	127	69.8	38.9	22.9	14.5	10.1	9.87	9.01	4.26	2.17	1.44	0.75	0.68
0	1180	921	676	442	272	158	84.0	45.1	25.4	15.6	10.8	10.5	10.5	4.80	2.36	1.50	0.75	0.68
10	948	730	514	347	223	134	75.7	43.5	26.1	16.7	11.6	10.8	9.65	4.66	2.41	1.56	0.80	0.68
20	447	373	285	202	135	86.4	55.0	35.2	23.2	15.9	11.3	10.9	7.96	4.21	2.33	1.59	0.83	0.68
30	171	149	122	93.9	69.2	49.9	36.0	26.2	18.9	13.7	10.9	9.42	6.01	3.63	2.21	1.56	0.86	0.68
40	64.1	58.4	51.3	43.2	35.4	28.5	22.7	17.9	13.9	10.7	8.84	6.65	4.56	3.04	2.07	1.46	0.89	0.68
50	28.4	26.7	24.4	21.8	19.1	16.2	13.6	11.1	9.04	7.33	5.98	4.71	3.52	2.54	1.97	1.33	0.90	0.68
60	12.6	12.1	11.3	10.5	9.49	8.48	7.52	6.58	5.72	4.95	4.24	3.48	2.76	2.26	1.74	1.22	0.91	0.68
70	5.83	5.68	5.48	5.22	4.91	4.58	4.24	3.89	3.55	3.25	3.00	2.74	2.35	1.94	1.53	1.20	0.92	0.68
80	2.91	2.88	2.85	2.81	2.76	2.70	2.65	2.60	2.55	2.49	2.44	2.36	2.05	1.74	1.45	1.18	0.92	0.68
90	2.17	2.16	2.14	2.13	2.12	2.10	2.11	2.11	2.11	2.11	2.12	2.12	1.88	1.64	1.40	1.16	0.92	0.68
100	1.79	1.79	1.78	1.78	1.78	1.78	1.80	1.82	1.84	1.87	1.90	1.92	1.74	1.56	1.36	1.15	0.93	0.68
110	1.72	1.73	1.73	1.73	1.73	1.73	1.73	1.74	1.75	1.76	1.78	1.76	1.62	1.48	1.32	1.14	0.92	0.68
120	2.08	2.07	2.05	2.02	1.98	1.93	1.88	1.82	1.78	1.76	1.76	1.67	1.53	1.41	1.27	1.11	0.92	0.68
130	3.03	3.00	2.93	2.82	2.68	2.52	2.36	2.19	2.04	1.92	1.75	1.58	1.45	1.33	1.21	1.08	0.91	0.68
140	4.18	4.13	4.02	3.87	3.67	3.42	3.13	2.81	2.51	2.15	1.77	1.51	1.36	1.25	1.16	1.05	0.89	0.68
150	4.93	4.90	4.81	4.66	4.45	4.19	3.87	3.49	2.81	2.18	1.73	1.43	1.26	1.16	1.08	1.00	0.87	0.68
160	5.16	5.16	5.12	5.00	4.85	4.64	4.01	3.31	2.62	2.02	1.56	1.29	1.13	1.06	1.01	0.95	0.84	0.68
170	4.84	4.87	4.92	4.75	4.28	3.77	3.22	2.64	2.09	1.61	1.25	1.06	0.98	0.96	0.93	0.90	0.81	0.68
180	4.01	3.74	3.55	3.28	2.93	2.53	2.11	1.70	1.32	1.02	0.83	0.79	0.80	0.85	0.85	0.84	0.78	0.68

H_(b) Range:-90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-09-05

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks: