

Floodlight Summary:

Report based on lamp delivering 1000 lumens.


Maximum Intensity (Luminaire orientation as tested.)		1268.3 cd per klm. 0.0 degrees vertical 0.0 degrees horizontal
Beam Spread	At 10% of Imax	88.5V x 86.2H
	At 50% of Imax	49.4V x 48.3H
	At 90% of Imax	19.0V x 18.4H
Beam Flux	Total	1000.0 lumens per klm.
	To 10% of Imax	891.0 lumens per klm.
	To 50% of Imax	516.7 lumens per klm.
	To 90% of Imax	102.2 lumens per klm.
Upward LOR		1.8 %
Downward LOR		98.2 %
Luminaire Efficiency(Light Output Ratio)		100.0 %

H(B) Range:-90 - 90DEG
H(B) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-09-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME:BlazeLine Slim-600mm-RGBW DS-RED-50D-Rev1	TYPE:RGBW DS-RED	WEIGHT:
SPEC.:50 DEG	DIM.:600MM	SERIAL No.:IES001648
MFR.:	SUR.:	Shielding Angle:



DATA OF LAMP		Eff:15.87lm/W	
MODEL		Imax(cd)	124.7
NOMINAL POWER(W)	6.192	AVAILABILITY(%)	89.1
RATED VOLTAGE(V)	24	Avai. FLUX(lm)	87.58
NOMINAL FLUX(lm)	98.29	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	98.29
TEST VOLTAGE(V)	24	q @50%(H,V)	48,49DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm		F t	F a
	0.00	0.01	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.01	0.01	0.01	0.00	0.00	0.23	0.00
72	0.00	0.01	0.01	0.01	0.02	0.03	0.03	0.04	0.05	0.05	0.04	0.03	0.03	0.02	0.01	0.01	0.01	0.00	0.40	0.00
64	0.00	0.01	0.01	0.02	0.03	0.05	0.08	0.10	0.12	0.12	0.10	0.08	0.05	0.03	0.02	0.01	0.01	0.00	0.86	0.00
56	0.01	0.01	0.02	0.03	0.07	0.12	0.19	0.25	0.29	0.28	0.24	0.17	0.11	0.06	0.03	0.02	0.01	0.00	1.91	0.82
48	0.01	0.01	0.02	0.06	0.12	0.24	0.40	0.53	0.59	0.57	0.47	0.34	0.21	0.11	0.05	0.02	0.01	0.00	3.77	3.18
40	0.01	0.01	0.03	0.09	0.21	0.42	0.69	0.94	1.05	1.01	0.83	0.58	0.35	0.18	0.08	0.03	0.01	0.00	6.52	6.08
32	0.01	0.02	0.05	0.13	0.31	0.62	1.04	1.42	1.59	1.52	1.25	0.86	0.51	0.26	0.11	0.04	0.01	0.00	9.75	9.37
24	0.01	0.02	0.06	0.16	0.39	0.81	1.36	1.84	2.08	1.98	1.61	1.12	0.66	0.33	0.14	0.05	0.01	0.00	12.6	12.3
	0.01	0.02	0.06	0.18	0.44	0.92	1.54	2.07	2.36	2.24	1.80	1.26	0.74	0.37	0.15	0.05	0.01	0.00	14.2	13.9
	0.01	0.02	0.06	0.17	0.44	0.91	1.54	2.06	2.33	2.20	1.78	1.24	0.73	0.36	0.15	0.05	0.01	0.00	14.1	13.7
	0.01	0.02	0.05	0.15	0.38	0.80	1.34	1.78	1.99	1.87	1.52	1.07	0.63	0.31	0.13	0.04	0.01	0.00	12.1	11.8
	0.01	0.01	0.04	0.11	0.29	0.59	0.98	1.31	1.47	1.39	1.13	0.79	0.47	0.24	0.10	0.03	0.01	0.00	8.96	8.60
-24	0.01	0.01	0.03	0.07	0.18	0.37	0.60	0.81	0.92	0.88	0.71	0.50	0.30	0.15	0.06	0.02	0.01	0.00	5.64	5.19
-32	0.00	0.01	0.01	0.04	0.10	0.20	0.32	0.43	0.49	0.47	0.38	0.27	0.16	0.08	0.04	0.01	0.01	0.00	3.02	2.39
-40	0.00	0.00	0.01	0.02	0.04	0.09	0.14	0.19	0.22	0.21	0.17	0.12	0.07	0.04	0.02	0.01	0.00	0.00	1.35	0.28
-48	0.00	0.00	0.00	0.01	0.02	0.03	0.05	0.06	0.07	0.07	0.06	0.04	0.03	0.02	0.01	0.00	0.00	0.00	0.48	0.00
-56	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.15	0.00
-64	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00
-72	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.00
	-72	-64	-56	-48	-40	-32	-24	-16	HORIZONTAL (DEG)	16	24	32	40	48	56	64	72			
F t	0.09	0.19	0.47	1.26	3.07	6.22	10.3	13.9	15.6	14.9	12.1	8.51	5.09	2.59	1.11	0.40	0.14	0.06	96	---
F a	0.00	0.00	0.00	0.36	2.46	5.71	9.85	13.4	15.2	14.4	11.6	7.98	4.51	1.90	0.16	0.00	0.00	0.00	---	88

one-half-peak spread: U:25.4,D:24.4 , L:23.6,R:25.1


NEMA Beam Type: Type 5

H_b) Range:-90 - 90DEG
H_b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-09-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

NAME:BlazeLine Slim-600mm-RGBW DS-RED-50D-Rev1	TYPE:RGBW DS-RED	WEIGHT:
SPEC.:50 DEG	DIM.:600MM	SERIAL No.:IES001648
MFR.:	SUR.:	Shielding Angle:




H(B) Range:-90 - 90DEG
H(B) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-09-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME:BlazeLine Slim-600mm-RGBW DS-RED-50D-Rev1	TYPE:RGBW DS-RED	WEIGHT:
SPEC.:50 DEG	DIM.:600MM	SERIAL No.:IES001648
MFR.:	SUR.:	Shielding Angle:



H(θ) Range:-90 - 90DEG
H(θ) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-09-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H(ϕ) Range:-90 - 90DEG
H(ϕ) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-09-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME:BlazeLine Slim-600mm-RGBW DS-RED-50D-Rev1	TYPE:RGBW DS-RED	WEIGHT:
SPEC.:50 DEG	DIM.:600MM	SERIAL No.:IES001648
MFR.:	SUR.:	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-09-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:BlazeLine Slim-600mm-RGBW DS-RED-50D-Rev1	TYPE:RGBW DS-RED	WEIGHT:
SPEC.:50 DEG	DIM.:600MM	SERIAL No.:IES001648
MFR.:	SUR.:	Shielding Angle:

Table--1

UNIT: cd

H(°) \ V(°)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	0.30	0.28	0.28	0.28	0.29	0.32	0.35	0.40	0.46	0.52	0.59	0.64	0.69	0.71	0.71	0.71	0.70	0.68	0.71
-170	0.30	0.27	0.27	0.26	0.26	0.28	0.30	0.33	0.36	0.40	0.43	0.45	0.47	0.48	0.47	0.48	0.51	0.56	0.61
-160	0.30	0.27	0.25	0.24	0.24	0.23	0.24	0.25	0.26	0.27	0.27	0.27	0.26	0.31	0.35	0.38	0.43	0.46	0.50
-150	0.30	0.26	0.24	0.22	0.21	0.20	0.19	0.18	0.17	0.16	0.14	0.17	0.19	0.21	0.25	0.28	0.31	0.35	0.38
-140	0.30	0.25	0.23	0.21	0.18	0.17	0.14	0.13	0.10	0.09	0.10	0.11	0.13	0.14	0.15	0.17	0.21	0.23	0.25
-130	0.30	0.25	0.22	0.19	0.17	0.14	0.11	0.09	0.07	0.08	0.07	0.07	0.07	0.07	0.08	0.10	0.12	0.14	0.15
-120	0.30	0.24	0.21	0.18	0.15	0.12	0.08	0.07	0.06	0.05	0.05	0.05	0.05	0.06	0.06	0.07	0.08	0.08	0.09
-110	0.30	0.24	0.20	0.17	0.13	0.10	0.07	0.05	0.05	0.04	0.04	0.04	0.03	0.04	0.04	0.05	0.05	0.06	0.07
-100	0.30	0.24	0.20	0.16	0.12	0.09	0.05	0.04	0.04	0.04	0.03	0.03	0.03	0.03	0.04	0.04	0.04	0.05	0.05
-90	0.30	0.25	0.21	0.16	0.12	0.07	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.04	0.04	0.04	0.04
-80	0.30	0.26	0.22	0.17	0.13	0.08	0.03	0.02	0.02	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03
-70	0.30	0.27	0.23	0.20	0.16	0.12	0.05	0.02	0.03	0.05	0.07	0.10	0.12	0.15	0.16	0.18	0.19	0.20	0.20
-60	0.30	0.27	0.26	0.24	0.25	0.20	0.13	0.09	0.14	0.21	0.29	0.37	0.47	0.58	0.69	0.80	0.89	0.96	0.98
-50	0.30	0.29	0.29	0.34	0.35	0.32	0.30	0.28	0.36	0.56	0.87	1.31	1.90	2.60	3.38	4.05	4.56	4.86	4.89
-40	0.30	0.30	0.34	0.44	0.47	0.50	0.57	0.67	0.92	1.58	2.76	4.43	6.74	9.24	11.9	14.1	15.8	16.8	17.0
-30	0.30	0.32	0.40	0.54	0.60	0.73	0.91	1.28	2.18	3.82	6.79	10.9	16.1	22.1	28.2	33.9	38.2	40.4	40.4
-20	0.30	0.33	0.47	0.63	0.75	0.97	1.31	2.13	3.89	7.10	12.1	19.7	29.7	41.5	53.5	63.9	71.8	75.8	75.6
-10	0.30	0.34	0.53	0.72	0.90	1.20	1.72	2.96	5.45	9.74	17.0	27.4	41.9	59.4	77.4	92.7	103	109	108
0	0.30	0.36	0.57	0.79	1.02	1.38	2.00	3.46	6.22	10.8	18.9	30.1	45.8	65.7	86.0	102	115	123	123
10	0.30	0.36	0.56	0.77	0.99	1.34	1.92	3.23	5.82	10.2	17.6	27.9	42.1	60.1	78.5	94.0	106	113	113
20	0.30	0.35	0.53	0.74	0.93	1.23	1.69	2.64	4.57	7.80	13.2	20.9	30.9	43.3	56.9	69.1	78.2	82.2	82.1
30	0.30	0.35	0.48	0.68	0.84	1.08	1.41	1.97	3.05	4.97	7.95	12.7	18.6	25.5	33.1	40.1	44.7	47.2	47.3
40	0.30	0.34	0.43	0.61	0.75	0.91	1.13	1.44	1.91	2.73	4.10	6.08	8.71	11.9	15.3	18.0	20.1	21.3	21.4
50	0.30	0.33	0.39	0.53	0.65	0.75	0.89	1.05	1.26	1.55	1.96	2.56	3.35	4.32	5.28	6.21	6.95	7.42	7.57
60	0.30	0.32	0.37	0.43	0.53	0.60	0.67	0.76	0.86	0.98	1.10	1.24	1.40	1.58	1.77	1.95	2.11	2.22	2.28
70	0.30	0.32	0.35	0.38	0.42	0.47	0.51	0.54	0.58	0.62	0.66	0.71	0.75	0.81	0.87	0.91	0.95	0.98	1.00
80	0.30	0.31	0.33	0.35	0.37	0.39	0.40	0.41	0.42	0.42	0.43	0.43	0.43	0.44	0.46	0.48	0.49	0.50	0.51
90	0.30	0.31	0.32	0.32	0.33	0.34	0.35	0.34	0.33	0.33	0.32	0.31	0.30	0.31	0.31	0.32	0.33	0.33	0.34
100	0.30	0.29	0.30	0.30	0.31	0.31	0.31	0.30	0.29	0.28	0.28	0.27	0.27	0.27	0.27	0.28	0.28	0.28	0.28
110	0.30	0.29	0.29	0.29	0.29	0.28	0.28	0.28	0.28	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.27
120	0.30	0.29	0.29	0.29	0.28	0.28	0.28	0.27	0.27	0.27	0.28	0.28	0.30	0.31	0.32	0.32	0.31	0.31	0.31
130	0.30	0.28	0.29	0.28	0.28	0.28	0.28	0.28	0.28	0.29	0.31	0.34	0.37	0.40	0.42	0.43	0.44	0.44	0.43
140	0.30	0.28	0.28	0.28	0.28	0.28	0.28	0.28	0.30	0.33	0.37	0.42	0.46	0.50	0.54	0.56	0.57	0.57	0.57
150	0.30	0.28	0.28	0.28	0.28	0.29	0.30	0.31	0.35	0.39	0.43	0.49	0.54	0.59	0.64	0.67	0.68	0.68	0.67
160	0.30	0.28	0.28	0.28	0.29	0.29	0.32	0.36	0.40	0.45	0.50	0.55	0.59	0.64	0.68	0.70	0.71	0.71	0.71
170	0.30	0.28	0.28	0.28	0.29	0.31	0.34	0.38	0.44	0.50	0.55	0.61	0.65	0.68	0.70	0.70	0.71	0.71	0.72
180	0.30	0.28	0.28	0.28	0.29	0.32	0.35	0.40	0.46	0.52	0.59	0.64	0.69	0.71	0.71	0.71	0.70	0.68	0.71

H(°) Range:-90 - 90DEG

H(°) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-09-06

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:BlazeLine Slim-600mm-RGBW DS-RED-50D-Rev1	TYPE:RGBW DS-RED	WEIGHT:
SPEC.:50 DEG	DIM.:600MM	SERIAL No.:IES001648
MFR.:	SUR.:	Shielding Angle:

Table--2

UNIT: cd

H (DEG) V (DEG)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-180	0.59	0.57	0.49	0.44	0.41	0.34	0.27	0.22	0.15	0.12	0.07	0.05	0.05	0.05	0.05	0.05	0.05	0.05	
-170	0.56	0.53	0.51	0.46	0.41	0.35	0.29	0.22	0.16	0.13	0.08	0.06	0.05	0.05	0.05	0.05	0.05	0.05	
-160	0.47	0.44	0.42	0.39	0.36	0.32	0.26	0.21	0.16	0.11	0.08	0.06	0.05	0.05	0.05	0.05	0.05	0.05	
-150	0.36	0.34	0.30	0.29	0.26	0.23	0.20	0.17	0.13	0.10	0.08	0.07	0.05	0.05	0.05	0.05	0.05	0.05	
-140	0.24	0.22	0.20	0.17	0.16	0.15	0.13	0.11	0.09	0.09	0.07	0.07	0.06	0.05	0.05	0.05	0.05	0.05	
-130	0.14	0.13	0.12	0.09	0.08	0.07	0.07	0.08	0.08	0.07	0.07	0.06	0.06	0.05	0.05	0.05	0.05	0.05	
-120	0.08	0.08	0.07	0.06	0.06	0.06	0.05	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05	0.05	0.05	0.05	
-110	0.06	0.06	0.05	0.05	0.04	0.04	0.05	0.05	0.06	0.05	0.06	0.06	0.06	0.05	0.05	0.05	0.05	0.05	
-100	0.05	0.05	0.05	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.06	0.06	0.05	0.05	0.05	0.05	0.05	0.05	
-90	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	
-80	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	
-70	0.20	0.20	0.20	0.19	0.18	0.17	0.14	0.12	0.09	0.07	0.06	0.06	0.08	0.07	0.06	0.06	0.05	0.05	
-60	0.95	0.89	0.81	0.71	0.62	0.53	0.44	0.35	0.28	0.21	0.15	0.12	0.13	0.14	0.10	0.06	0.06	0.05	
-50	4.68	4.23	3.63	2.92	2.28	1.73	1.27	0.92	0.66	0.47	0.34	0.26	0.21	0.19	0.17	0.09	0.06	0.05	
-40	16.1	14.4	12.2	9.83	7.65	5.67	3.90	2.52	1.54	0.96	0.63	0.44	0.33	0.26	0.23	0.13	0.07	0.05	
-30	38.2	34.2	28.9	23.4	18.1	13.2	9.10	5.84	3.41	1.88	1.06	0.67	0.46	0.33	0.27	0.18	0.07	0.05	
-20	71.1	63.1	53.7	43.0	32.5	23.4	16.0	10.2	6.02	3.22	1.62	0.91	0.59	0.41	0.30	0.22	0.07	0.05	
-10	101	89.7	76.1	61.5	46.6	33.1	22.2	14.1	8.31	4.47	2.18	1.12	0.69	0.47	0.33	0.25	0.07	0.05	
0	115	102	86.6	69.8	53.1	37.7	25.0	15.8	9.34	5.02	2.45	1.23	0.75	0.51	0.36	0.28	0.07	0.05	
10	106	93.9	79.2	63.9	48.3	34.4	23.2	14.8	8.81	4.83	2.43	1.30	0.82	0.55	0.38	0.28	0.08	0.05	
20	77.8	69.9	59.2	47.2	35.6	25.6	17.7	11.4	6.86	3.86	2.11	1.26	0.83	0.56	0.39	0.27	0.09	0.05	
30	44.8	40.3	34.3	27.8	21.5	15.8	11.1	7.21	4.51	2.70	1.69	1.13	0.78	0.54	0.40	0.25	0.10	0.05	
40	20.4	18.6	16.1	13.3	10.6	7.89	5.62	3.86	2.66	1.87	1.34	0.97	0.70	0.50	0.39	0.21	0.10	0.05	
50	7.28	6.71	5.93	5.07	4.17	3.26	2.54	1.99	1.59	1.29	1.03	0.79	0.59	0.46	0.34	0.18	0.10	0.05	
60	2.23	2.13	1.99	1.82	1.63	1.46	1.29	1.14	0.99	0.87	0.75	0.61	0.49	0.39	0.26	0.16	0.10	0.05	
70	0.98	0.96	0.92	0.87	0.81	0.76	0.72	0.66	0.61	0.57	0.53	0.47	0.39	0.30	0.22	0.16	0.10	0.05	
80	0.49	0.48	0.47	0.45	0.44	0.42	0.42	0.41	0.41	0.39	0.39	0.38	0.32	0.26	0.21	0.15	0.10	0.05	
90	0.33	0.32	0.32	0.31	0.30	0.29	0.30	0.30	0.31	0.31	0.32	0.32	0.28	0.23	0.18	0.14	0.09	0.05	
100	0.28	0.28	0.27	0.27	0.26	0.26	0.26	0.27	0.28	0.28	0.29	0.29	0.26	0.22	0.18	0.13	0.09	0.05	
110	0.27	0.28	0.28	0.28	0.28	0.27	0.27	0.27	0.27	0.27	0.27	0.27	0.23	0.20	0.16	0.13	0.09	0.05	
120	0.32	0.32	0.33	0.34	0.33	0.33	0.30	0.29	0.28	0.28	0.27	0.25	0.21	0.18	0.15	0.12	0.08	0.05	
130	0.44	0.45	0.46	0.45	0.44	0.41	0.38	0.35	0.32	0.29	0.26	0.23	0.20	0.16	0.14	0.11	0.08	0.05	
140	0.58	0.59	0.59	0.58	0.54	0.51	0.46	0.42	0.38	0.32	0.25	0.20	0.17	0.15	0.12	0.10	0.07	0.05	
150	0.69	0.69	0.70	0.66	0.63	0.59	0.54	0.50	0.40	0.32	0.24	0.18	0.15	0.12	0.10	0.08	0.07	0.05	
160	0.72	0.72	0.71	0.71	0.67	0.63	0.54	0.45	0.36	0.27	0.20	0.15	0.12	0.10	0.09	0.07	0.06	0.05	
170	0.71	0.71	0.71	0.67	0.59	0.52	0.44	0.35	0.27	0.21	0.15	0.10	0.09	0.07	0.07	0.06	0.05	0.05	
180	0.59	0.57	0.49	0.44	0.41	0.34	0.27	0.22	0.15	0.12	0.07	0.05	0.05	0.05	0.05	0.05	0.05	0.05	

H_b Range:-90 - 90DEGH_b Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-09-06

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks: