

Floodlight Summary:

Report based on lamp delivering 1000 lumens.


Maximum Intensity		10768.7 cd per klm.
(Luminaire orientation as tested.)		0.0 degrees vertical
		0.0 degrees horizontal
Beam Spread	At 10% of Imax	27.0V x 27.1H
	At 50% of Imax	14.0V x 14.2H
	At 90% of Imax	5.7V x 5.6H
Beam Flux	Total	1000.5 lumens per klm.
	To 10% of Imax	692.6 lumens per klm.
	To 50% of Imax	374.1 lumens per klm.
	To 90% of Imax	77.9 lumens per klm.
	Upward LOR	2.2 %
	Downward LOR	97.9 %
Luminaire Efficiency(Light Output Ratio)		100.0 %

H(B) Range:-90 - 90DEG
H(B) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-10-07

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME:Blazeline Max-598mm-RGBW DS-RED-15D-Rev1	TYPE:RGBW DS-RED	WEIGHT:
SPEC.:15 DEG	DIM.:598MM	SERIAL No.:IES001820
MFR.:	SUR.:	Shielding Angle:



DATA OF LAMP		Eff:60.13lm/W	
MODEL		Imax(cd)	3626
NOMINAL POWER(W)	5.57	AVAILABILITY(%)	69.0
RATED VOLTAGE(V)	220	Avai. FLUX(lm)	232.4
NOMINAL FLUX(lm)	336.7	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	336.7
TEST VOLTAGE(V)	220	q @50%(H,V)	14,14DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm		F t	F a
	0.08	0.09	0.10	0.11	0.13	0.14	0.16	0.17	0.17	0.17	0.17	0.16	0.15	0.13	0.11	0.10	0.08	0.07	2.31	0.00
18	0.08	0.09	0.10	0.11	0.13	0.14	0.16	0.17	0.17	0.17	0.17	0.16	0.15	0.13	0.11	0.10	0.08	0.07	2.31	0.00
16	0.09	0.10	0.12	0.14	0.17	0.19	0.22	0.24	0.25	0.26	0.26	0.24	0.21	0.18	0.15	0.12	0.10	0.08	3.12	0.00
14	0.10	0.12	0.15	0.18	0.22	0.27	0.33	0.37	0.39	0.40	0.40	0.37	0.32	0.25	0.20	0.15	0.12	0.09	4.43	0.45
12	0.11	0.14	0.18	0.24	0.31	0.40	0.49	0.58	0.64	0.66	0.64	0.57	0.46	0.36	0.26	0.19	0.15	0.11	6.51	3.97
10	0.13	0.17	0.23	0.31	0.42	0.58	0.77	0.97	1.11	1.15	1.10	0.92	0.69	0.50	0.35	0.25	0.18	0.13	9.95	7.81
8	0.14	0.20	0.27	0.39	0.57	0.84	1.21	1.57	1.80	1.89	1.80	1.47	1.05	0.70	0.46	0.31	0.22	0.15	15.0	13.4
6	0.16	0.22	0.32	0.48	0.75	1.18	1.72	2.30	2.69	2.83	2.65	2.09	1.48	0.97	0.62	0.40	0.27	0.18	21.3	19.8
4	0.17	0.24	0.37	0.57	0.94	1.49	2.18	2.96	3.53	3.70	3.34	2.65	1.96	1.33	0.83	0.50	0.31	0.20	27.3	25.9
2	0.17	0.25	0.39	0.64	1.08	1.73	2.54	3.35	4.02	4.21	3.83	3.24	2.44	1.64	1.01	0.58	0.35	0.22	31.7	30.4
0	0.18	0.26	0.41	0.68	1.17	1.91	2.80	3.67	4.23	4.34	4.09	3.46	2.61	1.75	1.07	0.61	0.37	0.23	33.8	32.6
-2	0.18	0.27	0.42	0.69	1.20	1.95	2.83	3.51	3.96	4.07	3.79	3.22	2.43	1.63	0.99	0.58	0.36	0.22	32.3	31.1
-4	0.17	0.26	0.40	0.64	1.07	1.66	2.29	2.87	3.31	3.41	3.15	2.65	2.01	1.36	0.85	0.52	0.33	0.21	27.1	25.9
-6	0.16	0.23	0.35	0.53	0.80	1.19	1.63	2.09	2.47	2.55	2.33	1.94	1.47	1.01	0.67	0.43	0.28	0.19	20.3	18.9
-8	0.14	0.20	0.29	0.41	0.57	0.78	1.06	1.38	1.62	1.68	1.54	1.28	0.97	0.70	0.50	0.35	0.24	0.16	13.9	12.1
-10	0.12	0.17	0.23	0.31	0.41	0.53	0.67	0.84	0.97	1.01	0.93	0.79	0.63	0.49	0.37	0.27	0.19	0.14	9.07	6.87
-12	0.10	0.14	0.18	0.24	0.30	0.37	0.45	0.53	0.59	0.61	0.58	0.51	0.43	0.35	0.27	0.21	0.15	0.11	6.15	3.30
-14	0.09	0.11	0.14	0.18	0.22	0.27	0.32	0.37	0.40	0.40	0.39	0.35	0.31	0.26	0.21	0.16	0.12	0.09	4.38	0.00
-16	0.07	0.09	0.11	0.14	0.17	0.20	0.22	0.25	0.27	0.27	0.26	0.24	0.22	0.19	0.16	0.12	0.10	0.07	3.13	0.00
-18	0.07	0.09	0.11	0.14	0.17	0.20	0.22	0.25	0.27	0.27	0.26	0.24	0.22	0.19	0.16	0.12	0.10	0.07	3.13	0.00
	-18	-16	-14	-12	-10	-8	-6	-4	HORIZONTAL (DEG)	4	6	8	10	12	14	16	18			
F t	2.37	3.25	4.66	6.87	10.5	15.7	21.9	28.0	32.4	33.6	31.2	26.1	19.8	13.8	9.07	5.86	3.91	2.65	272	---
F a	0.00	0.00	0.68	4.35	8.38	14.0	20.3	26.6	31.1	32.3	29.9	24.8	18.3	11.9	6.78	3.04	0.00	0.00	---	232

one-half-peak spread: U:7.3,D:6.7 , L:7.2,R:7.2


NEMA Beam Type: Type 2

H(B) Range:-90 - 90DEG
H(B) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-10-07

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

NAME:Blazeline Max-598mm-RGBW DS-RED-15D-Rev1	TYPE:RGBW DS-RED	WEIGHT:
SPEC.:15 DEG	DIM.:598MM	SERIAL No.:IES001820
MFR.:	SUR.:	Shielding Angle:




H(θ) Range:-90 - 90DEG
H(θ) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-10-07

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME:Blazeline Max-598mm-RGBW DS-RED-15D-Rev1	TYPE:RGBW DS-RED	WEIGHT:
SPEC.:15 DEG	DIM.:598MM	SERIAL No.:IES001820
MFR.:	SUR.:	Shielding Angle:



H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-10-07

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H(θ) Range:-90 - 90DEG
H(θ) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-10-07

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME:Blazeline Max-598mm-RGBW DS-RED-15D-Rev1	TYPE:RGBW DS-RED	WEIGHT:
SPEC.:15 DEG	DIM.:598MM	SERIAL No.:IES001820
MFR.:	SUR.:	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-10-07

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:Blazeline Max-598mm-RGBW DS-RED-15D-Rev1	TYPE:RGBW DS-RED	WEIGHT:
SPEC.:15 DEG	DIM.:598MM	SERIAL No.:IES001820
MFR.:	SUR.:	Shielding Angle:

Table--1

UNIT: cd

H (DEG) V (DEG)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	1.12	0.96	0.81	0.76	0.77	0.81	0.94	1.26	1.76	2.29	2.66	2.74	2.68	2.54	2.43	2.37	2.29	2.22	2.27
-170	1.12	0.95	0.80	0.75	0.74	0.75	0.80	1.00	1.31	1.65	1.90	2.00	2.01	2.07	2.18	2.31	2.43	2.61	2.66
-160	1.12	0.95	0.80	0.73	0.72	0.70	0.68	0.72	0.84	0.97	1.06	1.11	1.19	1.45	1.75	2.03	2.19	2.31	2.36
-150	1.12	0.95	0.81	0.73	0.71	0.67	0.60	0.52	0.49	0.44	0.39	0.54	0.72	0.93	1.13	1.31	1.45	1.52	1.54
-140	1.12	0.95	0.82	0.73	0.70	0.66	0.59	0.48	0.33	0.27	0.27	0.28	0.34	0.41	0.50	0.60	0.68	0.73	0.74
-130	1.12	0.96	0.84	0.75	0.69	0.67	0.62	0.54	0.46	0.38	0.31	0.27	0.25	0.24	0.23	0.23	0.24	0.25	0.26
-120	1.12	0.98	0.86	0.77	0.71	0.67	0.65	0.61	0.60	0.57	0.54	0.50	0.46	0.42	0.37	0.33	0.30	0.28	0.27
-110	1.12	0.99	0.88	0.80	0.73	0.68	0.64	0.63	0.64	0.63	0.64	0.64	0.64	0.64	0.64	0.63	0.62	0.61	0.60
-100	1.12	1.00	0.90	0.81	0.73	0.67	0.62	0.62	0.62	0.62	0.63	0.63	0.63	0.63	0.63	0.64	0.64	0.64	0.64
-90	1.12	1.02	0.92	0.81	0.71	0.61	0.50	0.50	0.50	0.49	0.49	0.48	0.48	0.48	0.48	0.49	0.49	0.49	0.50
-80	1.12	1.04	0.95	0.83	0.71	0.57	0.40	0.38	0.37	0.36	0.36	0.35	0.35	0.34	0.33	0.33	0.32	0.31	0.30
-70	1.12	1.07	0.99	0.90	0.77	0.62	0.45	0.41	0.44	0.48	0.52	0.58	0.63	0.68	0.71	0.74	0.76	0.77	0.77
-60	1.12	1.10	1.07	0.99	0.91	0.81	0.69	0.60	0.72	0.87	1.05	1.26	1.51	1.75	1.96	2.15	2.28	2.37	2.39
-50	1.12	1.14	1.15	1.14	1.15	1.16	1.13	1.06	1.25	1.70	2.26	2.92	3.64	4.34	5.01	5.58	6.00	6.25	6.31
-40	1.12	1.18	1.24	1.33	1.49	1.62	1.74	1.97	2.37	3.23	4.47	5.88	7.35	8.77	10.1	11.1	11.7	12.0	12.0
-30	1.12	1.23	1.35	1.55	1.86	2.16	2.57	3.27	4.36	5.77	7.37	9.56	12.0	14.4	17.1	20.0	23.3	26.3	27.6
-20	1.12	1.27	1.46	1.80	2.25	2.73	3.51	4.81	6.70	9.01	11.5	14.2	17.4	23.5	35.0	53.8	80.6	110	126
-10	1.12	1.31	1.56	2.02	2.61	3.31	4.41	6.28	8.91	12.1	16.0	21.0	28.8	43.4	75.1	157	343	682	1072
0	1.12	1.35	1.65	2.20	2.90	3.75	5.10	7.35	10.5	14.5	19.6	27.1	38.9	57.4	94.5	212	701	2175	3488
10	1.12	1.34	1.64	2.15	2.81	3.61	4.85	6.91	9.82	13.4	17.9	24.2	34.3	50.1	76.6	133	259	502	696
20	1.12	1.33	1.60	2.05	2.64	3.30	4.32	5.96	8.32	11.3	14.7	18.8	24.7	33.4	45.0	58.8	73.7	86.0	89.3
30	1.12	1.31	1.55	1.91	2.40	2.93	3.65	4.76	6.39	8.52	11.0	13.7	16.6	20.1	24.3	29.0	33.2	36.5	37.7
40	1.12	1.28	1.48	1.76	2.14	2.53	2.98	3.62	4.54	5.82	7.45	9.20	11.0	12.7	14.2	15.6	16.6	17.3	17.5
50	1.12	1.25	1.42	1.61	1.86	2.15	2.43	2.73	3.17	3.80	4.60	5.52	6.47	7.43	8.27	8.96	9.51	9.87	10.00
60	1.12	1.22	1.36	1.47	1.63	1.80	1.99	2.14	2.33	2.55	2.82	3.15	3.51	3.88	4.22	4.51	4.73	4.88	4.92
70	1.12	1.19	1.27	1.37	1.44	1.53	1.62	1.71	1.80	1.88	1.96	2.03	2.10	2.18	2.26	2.32	2.37	2.39	2.40
80	1.12	1.16	1.20	1.24	1.29	1.34	1.38	1.40	1.42	1.44	1.46	1.48	1.49	1.51	1.53	1.55	1.57	1.58	1.59
90	1.12	1.13	1.14	1.14	1.15	1.16	1.16	1.16	1.15	1.14	1.14	1.13	1.12	1.13	1.14	1.14	1.15	1.16	1.17
100	1.12	1.10	1.07	1.05	1.02	1.00	0.97	0.93	0.90	0.87	0.84	0.82	0.80	0.80	0.81	0.82	0.83	0.83	0.84
110	1.12	1.07	1.02	0.96	0.91	0.87	0.84	0.82	0.80	0.79	0.79	0.79	0.79	0.80	0.80	0.80	0.80	0.80	0.81
120	1.12	1.05	0.96	0.88	0.83	0.80	0.79	0.79	0.79	0.79	0.79	0.80	0.83	0.85	0.85	0.86	0.86	0.86	0.85
130	1.12	1.02	0.92	0.83	0.78	0.78	0.78	0.78	0.79	0.84	0.91	1.01	1.12	1.26	1.40	1.53	1.63	1.69	1.70
140	1.12	1.00	0.87	0.79	0.77	0.77	0.78	0.80	0.91	1.09	1.35	1.66	2.00	2.29	2.52	2.65	2.73	2.76	2.76
150	1.12	0.99	0.85	0.77	0.77	0.78	0.80	0.93	1.18	1.56	2.01	2.41	2.70	2.88	2.98	3.05	3.05	3.04	3.02
160	1.12	0.97	0.83	0.76	0.76	0.79	0.87	1.08	1.48	1.99	2.46	2.77	2.94	2.99	3.04	3.11	3.17	3.20	3.24
170	1.12	0.96	0.82	0.76	0.77	0.80	0.92	1.22	1.70	2.24	2.65	2.82	2.85	2.84	2.89	2.95	2.92	2.96	3.12
180	1.12	0.96	0.81	0.76	0.77	0.81	0.94	1.26	1.76	2.29	2.66	2.74	2.68	2.54	2.43	2.37	2.29	2.22	2.29

H_b Range:-90 - 90DEGH_b Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-10-07

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:Blazeline Max-598mm-RGBW DS-RED-15D-Rev1	TYPE:RGBW DS-RED	WEIGHT:
SPEC.:15 DEG	DIM.:598MM	SERIAL No.:IES001820
MFR.:	SUR.:	Shielding Angle:

Table--2

UNIT: cd

H(°) V(°)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-180	1.97	1.92	1.86	1.71	1.55	1.33	1.02	0.69	0.41	0.27	0.27	0.35	0.49	0.60	0.62	0.60	0.52	0.40	
-170	2.59	2.39	2.23	1.96	1.64	1.31	0.96	0.64	0.39	0.27	0.27	0.35	0.49	0.60	0.62	0.60	0.52	0.40	
-160	2.27	2.11	1.89	1.64	1.34	1.03	0.73	0.48	0.31	0.26	0.28	0.39	0.52	0.61	0.62	0.60	0.51	0.40	
-150	1.48	1.37	1.20	1.01	0.81	0.61	0.43	0.31	0.26	0.25	0.32	0.44	0.56	0.61	0.62	0.59	0.51	0.40	
-140	0.70	0.63	0.54	0.43	0.34	0.28	0.24	0.24	0.25	0.31	0.42	0.52	0.59	0.62	0.62	0.58	0.50	0.40	
-130	0.25	0.23	0.22	0.21	0.22	0.24	0.26	0.32	0.39	0.46	0.53	0.59	0.61	0.62	0.61	0.56	0.49	0.40	
-120	0.28	0.30	0.33	0.37	0.41	0.45	0.49	0.53	0.57	0.59	0.60	0.61	0.62	0.61	0.58	0.53	0.47	0.40	
-110	0.60	0.61	0.62	0.62	0.62	0.62	0.62	0.62	0.62	0.62	0.62	0.62	0.61	0.59	0.55	0.50	0.45	0.40	
-100	0.63	0.63	0.62	0.61	0.61	0.60	0.60	0.60	0.60	0.59	0.58	0.57	0.54	0.52	0.48	0.46	0.42	0.40	
-90	0.48	0.47	0.46	0.45	0.44	0.42	0.43	0.43	0.43	0.44	0.44	0.44	0.43	0.43	0.42	0.41	0.40	0.40	
-80	0.30	0.31	0.31	0.31	0.31	0.31	0.31	0.31	0.32	0.32	0.32	0.34	0.35	0.36	0.37	0.37	0.38	0.40	
-70	0.75	0.73	0.69	0.65	0.61	0.57	0.52	0.47	0.43	0.39	0.36	0.34	0.34	0.35	0.35	0.36	0.36	0.40	
-60	2.30	2.14	1.95	1.73	1.51	1.28	1.07	0.88	0.73	0.61	0.52	0.48	0.43	0.39	0.36	0.35	0.36	0.40	
-50	6.00	5.52	4.90	4.23	3.57	2.96	2.37	1.83	1.37	1.00	0.78	0.69	0.61	0.50	0.40	0.36	0.36	0.40	
-40	11.5	10.8	9.80	8.63	7.26	5.89	4.63	3.54	2.55	1.76	1.25	0.96	0.81	0.66	0.48	0.37	0.36	0.40	
-30	26.6	23.3	18.9	14.7	11.5	9.10	7.19	5.61	4.15	2.86	1.91	1.31	1.01	0.82	0.58	0.40	0.35	0.40	
-20	118	90.1	57.6	34.4	20.7	13.4	9.49	7.34	5.65	3.98	2.60	1.68	1.21	0.96	0.68	0.43	0.36	0.40	
-10	819	415	180	73.1	36.1	19.7	12.4	8.70	6.63	4.78	3.14	1.99	1.36	1.07	0.75	0.45	0.36	0.40	
0	2858	1154	308	96.2	41.9	22.2	13.6	9.26	6.97	5.08	3.36	2.14	1.46	1.15	0.79	0.47	0.36	0.40	
10	588	300	136	68.5	42.0	26.2	16.7	11.3	8.34	5.96	3.91	2.49	1.69	1.28	0.88	0.53	0.39	0.40	
20	87.0	75.0	58.6	43.9	32.4	23.2	15.9	11.6	8.59	6.02	3.98	2.61	1.82	1.36	0.93	0.57	0.42	0.40	
30	37.1	34.4	29.9	24.2	19.2	15.4	12.6	10.3	7.64	5.33	3.63	2.50	1.84	1.37	0.94	0.60	0.44	0.40	
40	17.2	16.3	15.2	13.7	12.0	10.4	8.76	7.13	5.64	4.25	3.09	2.29	1.76	1.32	0.92	0.62	0.46	0.40	
50	9.78	9.33	8.71	7.98	7.14	6.22	5.33	4.48	3.73	3.10	2.55	2.05	1.62	1.24	0.89	0.64	0.48	0.40	
60	4.85	4.69	4.45	4.16	3.84	3.48	3.11	2.79	2.50	2.28	2.09	1.79	1.45	1.13	0.86	0.65	0.49	0.40	
70	2.39	2.36	2.31	2.24	2.15	2.06	1.99	1.92	1.84	1.78	1.70	1.55	1.29	1.05	0.84	0.66	0.50	0.40	
80	1.58	1.56	1.54	1.52	1.50	1.47	1.46	1.45	1.44	1.42	1.40	1.37	1.17	0.99	0.82	0.65	0.51	0.40	
90	1.16	1.16	1.15	1.15	1.14	1.14	1.15	1.16	1.16	1.17	1.18	1.19	1.06	0.93	0.80	0.66	0.53	0.40	
100	0.83	0.83	0.82	0.81	0.81	0.81	0.84	0.87	0.89	0.93	0.97	1.00	0.94	0.87	0.78	0.67	0.54	0.40	
110	0.80	0.80	0.80	0.79	0.79	0.79	0.79	0.79	0.80	0.81	0.83	0.85	0.83	0.80	0.75	0.67	0.55	0.40	
120	0.86	0.85	0.84	0.83	0.82	0.81	0.80	0.79	0.79	0.79	0.79	0.78	0.77	0.76	0.72	0.66	0.55	0.40	
130	1.67	1.59	1.47	1.34	1.20	1.07	0.95	0.87	0.80	0.79	0.77	0.76	0.74	0.73	0.70	0.66	0.56	0.40	
140	2.74	2.70	2.60	2.43	2.18	1.87	1.54	1.24	1.01	0.83	0.72	0.71	0.72	0.70	0.69	0.64	0.56	0.40	
150	3.02	3.01	2.98	2.92	2.81	2.60	2.28	1.85	1.29	0.88	0.68	0.64	0.67	0.68	0.67	0.64	0.55	0.40	
160	3.23	3.21	3.12	3.05	2.97	2.86	2.42	1.86	1.28	0.85	0.61	0.56	0.61	0.66	0.65	0.63	0.54	0.40	
170	3.09	3.07	3.07	2.84	2.53	2.20	1.83	1.40	0.96	0.63	0.47	0.46	0.54	0.63	0.64	0.62	0.53	0.40	
180	1.97	1.92	1.86	1.71	1.55	1.33	1.02	0.69	0.41	0.27	0.27	0.35	0.49	0.60	0.62	0.60	0.52	0.40	

H(°) Range:-90 - 90DEG

H(°) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-10-07

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks: