

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity (Luminaire orientation as tested.)	2386.5 cd per klm. 0.0 degrees vertical 0.0 degrees horizontal
---	--

Beam Spread	At 10% of Imax	63.6V x 63.8H
	At 50% of Imax	30.0V x 30.0H
	At 90% of Imax	11.1V x 11.2H

Beam Flux	Total	1000.0 lumens per klm.
	To 10% of Imax	761.2 lumens per klm.
	To 50% of Imax	359.6 lumens per klm.
	To 90% of Imax	63.7 lumens per klm.

Upward LOR	1.4 %
Downward LOR	98.6 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-10-07

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME:Blazeline Max-598mm-RGBW DS-BLUE-30D-Rev1	TYPE:RGBW DS-BLUE	WEIGHT:
SPEC.:30 DEG	DIM.:598MM	SERIAL No.:IES001827
MFR.:	SUR.:	Shielding Angle:



DATA OF LAMP		Eff:7.38lm/W	
MODEL		Imax(cd)	125.5
NOMINAL POWER(W)	7.12	AVAILABILITY(%)	76.2
RATED VOLTAGE(V)	220	Avai. FLUX(lm)	40.03
NOMINAL FLUX(lm)	52.57	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	52.57
TEST VOLTAGE(V)	220	q @50%(H,V)	30,30DEG

		AREA FLUX DIAGRAM															UNIT:lm				F t	F a
VERTICAL (DEG)	45	0.01	0.02	0.02	0.02	0.03	0.03	0.04	0.04	0.04	0.04	0.04	0.04	0.03	0.03	0.03	0.02	0.02	0.01	0.52	0.00	
	40	0.01	0.02	0.02	0.03	0.04	0.05	0.05	0.06	0.06	0.06	0.06	0.05	0.05	0.04	0.03	0.03	0.02	0.02	0.70	0.00	
	35	0.02	0.02	0.03	0.04	0.05	0.06	0.08	0.09	0.09	0.09	0.09	0.08	0.07	0.05	0.04	0.03	0.02	0.02	0.97	0.16	
	30	0.02	0.03	0.04	0.05	0.07	0.09	0.11	0.13	0.15	0.15	0.14	0.12	0.09	0.07	0.05	0.04	0.03	0.02	1.39	0.89	
	25	0.02	0.03	0.04	0.06	0.09	0.13	0.17	0.21	0.24	0.24	0.22	0.18	0.13	0.10	0.07	0.05	0.03	0.02	2.05	1.66	
	20	0.03	0.04	0.05	0.08	0.12	0.18	0.26	0.33	0.38	0.38	0.33	0.26	0.19	0.13	0.08	0.06	0.04	0.02	2.97	2.65	
	15	0.03	0.04	0.06	0.10	0.16	0.25	0.37	0.49	0.56	0.56	0.48	0.36	0.25	0.16	0.10	0.07	0.04	0.03	4.11	3.83	
	10	0.03	0.04	0.07	0.11	0.19	0.31	0.47	0.65	0.76	0.76	0.63	0.46	0.31	0.20	0.12	0.07	0.04	0.03	5.27	5.01	
	5	0.03	0.05	0.07	0.12	0.21	0.35	0.54	0.75	0.90	0.89	0.74	0.55	0.36	0.22	0.13	0.08	0.05	0.03	6.06	5.82	
	0	0.03	0.05	0.07	0.12	0.21	0.35	0.55	0.77	0.90	0.90	0.76	0.56	0.37	0.22	0.13	0.08	0.05	0.03	6.16	5.92	
	-5	0.03	0.04	0.07	0.12	0.20	0.32	0.50	0.67	0.77	0.77	0.65	0.49	0.33	0.20	0.12	0.07	0.04	0.03	5.42	5.17	
	-10	0.03	0.04	0.06	0.10	0.16	0.26	0.38	0.50	0.57	0.57	0.49	0.37	0.26	0.17	0.10	0.06	0.04	0.03	4.18	3.91	
	-15	0.02	0.03	0.05	0.08	0.12	0.18	0.26	0.33	0.38	0.38	0.33	0.26	0.19	0.13	0.08	0.05	0.03	0.02	2.94	2.63	
	-20	0.02	0.03	0.04	0.06	0.09	0.12	0.17	0.21	0.23	0.23	0.21	0.17	0.13	0.09	0.06	0.04	0.03	0.02	1.95	1.57	
	-25	0.02	0.02	0.03	0.05	0.06	0.08	0.11	0.13	0.14	0.14	0.13	0.11	0.08	0.06	0.05	0.03	0.02	0.02	1.28	0.76	
	-30	0.01	0.02	0.03	0.03	0.04	0.06	0.07	0.08	0.09	0.09	0.08	0.07	0.06	0.05	0.03	0.03	0.02	0.01	0.85	0.06	
-35	0.01	0.02	0.02	0.03	0.03	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.04	0.03	0.03	0.02	0.02	0.01	0.59	0.00		
-40	0.01	0.01	0.02	0.02	0.02	0.03	0.03	0.03	0.04	0.04	0.03	0.03	0.03	0.02	0.02	0.02	0.01	0.01	0.42	0.00		
-45	-45	-40	-35	-30	-25	-20	-15	-10	HORIZONTAL (DEG)			10	15	20	25	30	35	40	45			
F t	0.38	0.55	0.81	1.23	1.90	2.90	4.20	5.51	6.37	6.34	5.47	4.20	2.96	1.98	1.29	0.84	0.55	0.38	48	---		
F a	0.00	0.00	0.07	0.71	1.47	2.53	3.86	5.20	6.06	6.03	5.16	3.87	2.59	1.57	0.78	0.12	0.00	0.00	---	40		

one-half-peak spread: U:14.8,D:15.5 , L:14.9,R:15.4


NEMA Beam Type: Type 4

H_(b) Range: -90 - 90DEG
 H_(b) Interval: 0.5DEG
 Test Speed: LOW
 Temperature: 25.3DEG
 Operators: Fan
 Test Date: 2023-10-07

V(B) Range: -180 - 180DEG
 V(B) Interval: 0.5DEG
 Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
 Humidity: 65.0%
 Test Distance: 8.630m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

NAME:Blazeline Max-598mm-RGBW DS-BLUE-30D-Rev1	TYPE:RGBW DS-BLUE	WEIGHT:
SPEC.:30 DEG	DIM.:598MM	SERIAL No.:IES001827
MFR.:	SUR.:	Shielding Angle:




H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-10-07

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME:Blazeline Max-598mm-RGBW DS-BLUE-30D-Rev1	TYPE:RGBW DS-BLUE	WEIGHT:
SPEC.:30 DEG	DIM.:598MM	SERIAL No.:IES001827
MFR.:	SUR.:	Shielding Angle:



H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-10-07

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H(b) Range: -90 - 90DEG
H(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-10-07

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME:Blazeline Max-598mm-RGBW DS-BLUE-30D-Rev1	TYPE:RGBW DS-BLUE	WEIGHT:
SPEC.:30 DEG	DIM.:598MM	SERIAL No.:IES001827
MFR.:	SUR.:	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-10-07

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:Blazeline Max-598mm-RGBW DS-BLUE-30D-Rev1	TYPE:RGBW DS-BLUE	WEIGHT:
SPEC.:30 DEG	DIM.:598MM	SERIAL No.:IES001827
MFR.:	SUR.:	Shielding Angle:

Table--1

UNIT: cd

H(°) \ V(°)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	0.13	0.12	0.11	0.11	0.11	0.12	0.15	0.18	0.21	0.26	0.30	0.33	0.32	0.32	0.32	0.31	0.30	0.30	0.28
-170	0.13	0.12	0.11	0.10	0.10	0.11	0.11	0.13	0.16	0.18	0.20	0.22	0.22	0.22	0.22	0.23	0.23	0.23	0.28
-160	0.13	0.12	0.10	0.09	0.09	0.09	0.08	0.09	0.10	0.10	0.10	0.11	0.10	0.13	0.15	0.17	0.19	0.22	0.24
-150	0.13	0.11	0.10	0.08	0.07	0.07	0.06	0.05	0.04	0.04	0.03	0.04	0.05	0.06	0.07	0.09	0.13	0.15	0.17
-140	0.13	0.11	0.09	0.08	0.06	0.05	0.04	0.02	0.01	0.00	0.01	0.01	0.01	0.01	0.01	0.03	0.04	0.07	0.09
-130	0.13	0.11	0.09	0.07	0.05	0.04	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.02
-120	0.13	0.11	0.09	0.07	0.05	0.03	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-110	0.13	0.11	0.08	0.06	0.04	0.03	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-100	0.13	0.11	0.09	0.06	0.04	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90	0.13	0.11	0.09	0.07	0.04	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-80	0.13	0.11	0.09	0.07	0.05	0.03	0.00	0.00	0.00	0.00	0.01	0.01	0.02	0.02	0.02	0.02	0.02	0.02	0.02
-70	0.13	0.12	0.10	0.09	0.07	0.05	0.03	0.05	0.10	0.15	0.20	0.25	0.31	0.36	0.41	0.45	0.48	0.50	0.51
-60	0.13	0.12	0.12	0.12	0.13	0.17	0.19	0.25	0.37	0.51	0.66	0.81	0.94	1.08	1.18	1.28	1.36	1.41	1.43
-50	0.13	0.13	0.14	0.18	0.26	0.34	0.45	0.60	0.81	1.05	1.30	1.55	1.80	2.05	2.28	2.49	2.65	2.77	2.82
-40	0.13	0.13	0.17	0.27	0.39	0.56	0.78	1.05	1.31	1.64	2.07	2.53	3.03	3.58	4.12	4.71	5.22	5.60	5.77
-30	0.13	0.14	0.22	0.36	0.53	0.80	1.15	1.52	1.93	2.42	3.05	3.94	5.09	6.53	8.24	10.2	12.2	13.7	14.4
-20	0.13	0.15	0.26	0.44	0.68	1.03	1.47	1.98	2.56	3.33	4.41	6.02	8.46	12.3	17.6	24.2	31.4	37.5	40.2
-10	0.13	0.16	0.29	0.50	0.80	1.22	1.76	2.36	3.11	4.16	5.75	8.23	12.6	20.0	32.3	49.7	69.0	84.7	91.8
0	0.13	0.17	0.31	0.54	0.87	1.34	1.94	2.60	3.44	4.65	6.48	9.34	14.4	23.3	38.3	60.8	88.5	113	124
10	0.13	0.17	0.31	0.52	0.84	1.28	1.85	2.48	3.28	4.36	5.97	8.47	12.7	19.7	30.9	47.1	66.7	83.7	89.0
20	0.13	0.16	0.29	0.49	0.76	1.15	1.64	2.21	2.86	3.71	4.85	6.49	8.95	12.7	17.9	24.8	32.3	38.0	40.0
30	0.13	0.16	0.27	0.43	0.65	0.96	1.36	1.83	2.33	2.93	3.66	4.59	5.80	7.35	9.21	11.3	13.3	14.8	15.4
40	0.13	0.15	0.23	0.37	0.53	0.75	1.04	1.39	1.75	2.16	2.63	3.14	3.70	4.32	4.97	5.60	6.13	6.49	6.63
50	0.13	0.15	0.20	0.30	0.41	0.55	0.73	0.94	1.19	1.47	1.75	2.03	2.32	2.61	2.88	3.11	3.31	3.43	3.49
60	0.13	0.15	0.18	0.23	0.31	0.39	0.47	0.58	0.71	0.85	1.01	1.17	1.32	1.47	1.60	1.72	1.82	1.88	1.92
70	0.13	0.14	0.16	0.19	0.21	0.26	0.30	0.34	0.38	0.43	0.47	0.53	0.59	0.65	0.72	0.77	0.82	0.85	0.87
80	0.13	0.14	0.15	0.17	0.18	0.19	0.21	0.21	0.21	0.21	0.21	0.22	0.22	0.23	0.25	0.27	0.28	0.29	0.30
90	0.13	0.14	0.15	0.16	0.16	0.17	0.18	0.17	0.16	0.15	0.14	0.14	0.13	0.13	0.14	0.15	0.16	0.16	0.17
100	0.13	0.14	0.14	0.15	0.15	0.16	0.16	0.15	0.14	0.13	0.12	0.11	0.11	0.11	0.11	0.11	0.12	0.12	0.13
110	0.13	0.14	0.14	0.14	0.14	0.14	0.14	0.13	0.12	0.12	0.11	0.11	0.11	0.11	0.11	0.11	0.11	0.10	0.10
120	0.13	0.13	0.13	0.13	0.13	0.12	0.12	0.12	0.11	0.11	0.11	0.11	0.12	0.12	0.12	0.12	0.12	0.11	0.10
130	0.13	0.13	0.13	0.12	0.12	0.12	0.11	0.11	0.11	0.11	0.12	0.14	0.16	0.17	0.18	0.18	0.18	0.17	0.16
140	0.13	0.13	0.12	0.12	0.11	0.11	0.11	0.11	0.11	0.13	0.14	0.18	0.21	0.24	0.27	0.27	0.28	0.27	0.27
150	0.13	0.13	0.12	0.12	0.11	0.11	0.12	0.12	0.14	0.16	0.19	0.22	0.27	0.29	0.32	0.34	0.34	0.33	0.32
160	0.13	0.13	0.12	0.11	0.11	0.12	0.12	0.14	0.17	0.21	0.23	0.27	0.29	0.31	0.33	0.34	0.35	0.35	0.35
170	0.13	0.12	0.11	0.11	0.11	0.12	0.13	0.16	0.20	0.24	0.27	0.30	0.31	0.32	0.32	0.32	0.32	0.32	0.35
180	0.13	0.12	0.11	0.11	0.11	0.12	0.15	0.18	0.21	0.26	0.30	0.33	0.32	0.32	0.32	0.31	0.30	0.30	0.32

H_b Range: -90 - 90DEGH_b Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-10-07

V(B) Range: -180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:Blazeline Max-598mm-RGBW DS-BLUE-30D-Rev1	TYPE:RGBW DS-BLUE	WEIGHT:
SPEC.:30 DEG	DIM.:598MM	SERIAL No.:IES001827
MFR.:	SUR.:	Shielding Angle:

Table--2

UNIT: cd

H(°) \ V(°)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90
-180	0.26	0.21	0.20	0.18	0.14	0.12	0.07	0.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-170	0.23	0.23	0.23	0.21	0.17	0.12	0.08	0.04	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-160	0.22	0.19	0.17	0.16	0.14	0.12	0.08	0.04	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-150	0.15	0.14	0.11	0.08	0.07	0.05	0.04	0.03	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-140	0.07	0.05	0.03	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-130	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-120	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-80	0.03	0.03	0.04	0.04	0.04	0.04	0.02	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-70	0.52	0.51	0.50	0.47	0.43	0.38	0.33	0.27	0.21	0.16	0.11	0.06	0.03	0.03	0.01	0.00	0.00	0.00
-60	1.42	1.39	1.34	1.26	1.16	1.04	0.92	0.78	0.65	0.51	0.38	0.27	0.17	0.10	0.05	0.02	0.00	0.00
-50	2.78	2.68	2.53	2.34	2.12	1.90	1.66	1.42	1.18	0.95	0.74	0.56	0.38	0.22	0.12	0.05	0.00	0.00
-40	5.63	5.28	4.79	4.21	3.66	3.12	2.63	2.19	1.79	1.43	1.14	0.87	0.61	0.37	0.20	0.08	0.00	0.00
-30	13.8	12.4	10.4	8.46	6.73	5.23	4.06	3.17	2.49	1.96	1.53	1.17	0.84	0.52	0.27	0.12	0.01	0.00
-20	37.6	31.5	24.6	18.0	12.7	8.77	6.14	4.40	3.26	2.46	1.88	1.43	1.03	0.66	0.34	0.15	0.02	0.00
-10	83.8	67.7	49.0	32.8	20.8	13.1	8.33	5.56	3.90	2.85	2.14	1.61	1.17	0.76	0.40	0.17	0.02	0.00
0	115	90.4	63.3	40.9	25.2	15.3	9.43	6.09	4.22	3.04	2.26	1.70	1.24	0.81	0.43	0.18	0.02	0.00
10	82.4	65.3	46.6	31.7	20.7	13.3	8.63	5.83	4.13	3.03	2.26	1.70	1.23	0.80	0.43	0.18	0.03	0.00
20	38.1	32.7	25.4	18.6	13.3	9.41	6.73	4.91	3.66	2.78	2.11	1.59	1.14	0.73	0.39	0.18	0.03	0.00
30	15.0	13.6	11.8	9.61	7.68	6.06	4.80	3.82	3.03	2.37	1.83	1.39	0.99	0.63	0.34	0.16	0.03	0.00
40	6.56	6.25	5.77	5.17	4.49	3.86	3.29	2.77	2.31	1.87	1.48	1.11	0.79	0.50	0.28	0.14	0.02	0.00
50	3.46	3.37	3.20	2.98	2.73	2.45	2.17	1.88	1.60	1.34	1.07	0.81	0.57	0.37	0.23	0.11	0.03	0.00
60	1.90	1.86	1.79	1.69	1.57	1.43	1.29	1.13	0.98	0.82	0.67	0.52	0.37	0.26	0.17	0.08	0.03	0.00
70	0.87	0.85	0.81	0.77	0.72	0.65	0.60	0.54	0.48	0.42	0.37	0.32	0.25	0.18	0.11	0.06	0.03	0.00
80	0.30	0.29	0.28	0.27	0.25	0.24	0.23	0.23	0.22	0.22	0.22	0.21	0.17	0.13	0.10	0.06	0.03	0.00
90	0.16	0.16	0.15	0.14	0.14	0.13	0.14	0.14	0.15	0.16	0.16	0.17	0.14	0.11	0.09	0.06	0.03	0.00
100	0.12	0.12	0.11	0.11	0.11	0.10	0.11	0.12	0.12	0.13	0.14	0.15	0.13	0.10	0.08	0.06	0.03	0.00
110	0.10	0.11	0.11	0.11	0.10	0.10	0.11	0.11	0.11	0.12	0.12	0.12	0.10	0.09	0.07	0.05	0.03	0.00
120	0.11	0.12	0.12	0.12	0.12	0.12	0.11	0.11	0.11	0.11	0.11	0.10	0.09	0.07	0.06	0.04	0.02	0.00
130	0.17	0.18	0.18	0.19	0.18	0.16	0.14	0.12	0.11	0.11	0.10	0.09	0.08	0.06	0.05	0.04	0.02	0.00
140	0.27	0.28	0.28	0.27	0.24	0.22	0.19	0.15	0.12	0.11	0.09	0.07	0.06	0.05	0.04	0.03	0.02	0.00
150	0.33	0.34	0.34	0.33	0.30	0.27	0.23	0.20	0.14	0.10	0.07	0.06	0.05	0.04	0.03	0.02	0.01	0.00
160	0.35	0.35	0.34	0.33	0.31	0.28	0.24	0.17	0.12	0.08	0.05	0.04	0.03	0.03	0.02	0.02	0.01	0.00
170	0.33	0.33	0.33	0.30	0.26	0.21	0.16	0.12	0.07	0.05	0.03	0.02	0.02	0.01	0.01	0.01	0.00	0.00
180	0.26	0.21	0.20	0.18	0.14	0.12	0.07	0.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

H_(b) Range: -90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-10-07

V(B) Range: -180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks: