

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity (Luminaire orientation as tested.)	6033.5 cd per klm. 0.0 degrees vertical 0.0 degrees horizontal
---	--

Beam Spread	At 10% of Imax	38.5V x 37.4H
	At 50% of Imax	16.5V x 16.3H
	At 90% of Imax	6.1V x 6.1H

Beam Flux	Total	1000.4 lumens per klm.
	To 10% of Imax	641.4 lumens per klm.
	To 50% of Imax	280.3 lumens per klm.
	To 90% of Imax	57.2 lumens per klm.

Upward LOR	1.8 %
Downward LOR	98.3 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-08-14

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME:DecoBody-330mm-RGBW BLUE-15D-Rev1	TYPE:RGBW-Blue	WEIGHT:
SPEC.:15 DEG	DIM.:330mm	SERIAL No.:IES001500
MFR.:	SUR.:	Shielding Angle:



DATA OF LAMP		Eff:9.78lm/W	
MODEL		Imax(cd)	666.7
NOMINAL POWER(W)	11.2	AVAILABILITY(%)	64.3
RATED VOLTAGE(V)	220	Avai. FLUX(lm)	71.03
NOMINAL FLUX(lm)	110.5	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	110.5
TEST VOLTAGE(V)	221.4	q @50%(H,V)	16,17DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm		F t	F a
	0.03	0.04	0.05	0.06	0.06	0.07	0.08	0.08	0.09	0.09	0.08	0.08	0.07	0.06	0.05	0.04	0.04	0.03	1.10	0.00
27	0.03	0.04	0.05	0.06	0.06	0.07	0.08	0.08	0.09	0.09	0.08	0.08	0.07	0.06	0.05	0.04	0.04	0.03	1.10	0.00
24	0.04	0.05	0.06	0.07	0.08	0.09	0.10	0.11	0.11	0.11	0.11	0.10	0.09	0.08	0.06	0.05	0.04	0.04	1.40	0.00
21	0.04	0.06	0.07	0.08	0.10	0.12	0.14	0.15	0.16	0.16	0.15	0.13	0.11	0.10	0.08	0.06	0.05	0.04	1.81	0.00
18	0.05	0.06	0.08	0.10	0.13	0.16	0.19	0.22	0.23	0.22	0.21	0.18	0.15	0.12	0.10	0.08	0.06	0.05	2.39	1.10
15	0.06	0.07	0.10	0.13	0.17	0.22	0.28	0.32	0.34	0.34	0.30	0.25	0.20	0.15	0.12	0.09	0.07	0.05	3.25	2.29
12	0.06	0.09	0.11	0.16	0.22	0.30	0.40	0.50	0.54	0.52	0.45	0.35	0.26	0.19	0.14	0.10	0.08	0.06	4.53	3.70
9	0.07	0.10	0.13	0.19	0.27	0.40	0.57	0.77	0.87	0.83	0.69	0.50	0.34	0.24	0.17	0.12	0.09	0.06	6.39	5.64
	0.08	0.10	0.15	0.21	0.32	0.50	0.77	1.09	1.29	1.23	0.97	0.67	0.46	0.30	0.20	0.14	0.10	0.07	8.65	8.00
	0.08	0.11	0.15	0.23	0.36	0.58	0.93	1.34	1.65	1.59	1.29	0.92	0.59	0.37	0.23	0.15	0.10	0.07	10.8	10.2
	0.08	0.11	0.16	0.24	0.38	0.64	1.04	1.50	1.78	1.75	1.46	1.02	0.64	0.39	0.24	0.16	0.11	0.07	11.8	11.2
	0.08	0.11	0.16	0.24	0.39	0.64	1.01	1.37	1.58	1.52	1.25	0.90	0.57	0.36	0.23	0.15	0.10	0.07	10.7	10.1
-9	0.07	0.10	0.15	0.22	0.35	0.53	0.78	1.02	1.18	1.13	0.92	0.67	0.46	0.30	0.20	0.14	0.09	0.07	8.38	7.76
	0.07	0.09	0.13	0.19	0.28	0.39	0.53	0.68	0.77	0.74	0.62	0.47	0.34	0.24	0.17	0.12	0.08	0.06	5.97	5.28
-12	0.06	0.08	0.11	0.15	0.21	0.28	0.36	0.43	0.48	0.46	0.40	0.32	0.25	0.18	0.14	0.10	0.07	0.05	4.14	3.32
-15	0.05	0.07	0.09	0.12	0.16	0.20	0.24	0.28	0.30	0.30	0.26	0.22	0.18	0.14	0.11	0.08	0.06	0.05	2.90	1.88
-18	0.04	0.06	0.07	0.09	0.12	0.14	0.17	0.19	0.20	0.20	0.18	0.16	0.13	0.11	0.08	0.07	0.05	0.04	2.09	0.55
-21	0.04	0.05	0.06	0.07	0.09	0.10	0.12	0.13	0.14	0.14	0.13	0.11	0.10	0.08	0.07	0.05	0.04	0.03	1.53	0.00
-24	0.03	0.04	0.05	0.06	0.07	0.08	0.09	0.09	0.10	0.10	0.09	0.08	0.07	0.06	0.05	0.04	0.04	0.03	1.14	0.00
-27	-27	-24	-21	-18	-15	-12	-9	-6	HORIZONTAL (DEG)	6	9	12	15	18	21	24	27			
F t	1.03	1.38	1.88	2.62	3.74	5.45	7.80	10.3	11.8	11.4	9.56	7.13	4.99	3.46	2.43	1.75	1.28	0.95	89	---
F a	0.00	0.00	0.18	1.46	2.83	4.66	7.09	9.64	11.1	10.8	8.89	6.41	4.14	2.48	1.20	0.12	0.00	0.00	---	71

one-half-peak spread: U:9.5,D:7.1 , L:8.5,R:7.9


NEMA Beam Type: Type 3

H_(b) Range: -90 - 90DEG
 H_(b) Interval: 0.5DEG
 Test Speed: LOW
 Temperature: 25.3DEG
 Operators: Fan
 Test Date: 2023-08-14

V(B) Range: -180 - 180DEG
 V(B) Interval: 0.5DEG
 Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
 Humidity: 65.0%
 Test Distance: 8.630m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

NAME:DecoBody-330mm-RGBW BLUE-15D-Rev1	TYPE:RGBW-Blue	WEIGHT:
SPEC.:15 DEG	DIM.:330mm	SERIAL No.:IES001500
MFR.:	SUR.:	Shielding Angle:




H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME:DecoBody-330mm-RGBW BLUE-15D-Rev1	TYPE:RGBW-Blue	WEIGHT:
SPEC.:15 DEG	DIM.:330mm	SERIAL No.:IES001500
MFR.:	SUR.:	Shielding Angle:



H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-08-14

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-08-14

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME:DecoBody-330mm-RGBW BLUE-15D-Rev1	TYPE:RGBW-Blue	WEIGHT:
SPEC.:15 DEG	DIM.:330mm	SERIAL No.:IES001500
MFR.:	SUR.:	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:DecoBody-330mm-RGBW BLUE-15D-Rev1	TYPE:RGBW-Blue	WEIGHT:
SPEC.:15 DEG	DIM.:330mm	SERIAL No.:IES001500
MFR.:	SUR.:	Shielding Angle:

Table--1

UNIT: cd

H(°) \ V(°)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	0.43	0.32	0.27	0.24	0.25	0.26	0.31	0.38	0.51	0.65	0.77	0.78	0.78	0.77	0.75	0.73	0.71	0.63	0.64
-170	0.43	0.31	0.25	0.22	0.22	0.23	0.25	0.29	0.37	0.46	0.53	0.55	0.55	0.57	0.59	0.62	0.63	0.65	0.66
-160	0.43	0.31	0.24	0.21	0.20	0.20	0.20	0.21	0.23	0.26	0.27	0.28	0.29	0.36	0.44	0.49	0.54	0.59	0.63
-150	0.43	0.32	0.24	0.19	0.18	0.16	0.15	0.14	0.12	0.10	0.08	0.12	0.16	0.21	0.26	0.30	0.35	0.40	0.42
-140	0.43	0.31	0.24	0.19	0.16	0.14	0.12	0.09	0.06	0.05	0.05	0.06	0.06	0.07	0.10	0.13	0.16	0.19	0.21
-130	0.43	0.32	0.24	0.19	0.15	0.12	0.10	0.07	0.06	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.06	0.07	0.08
-120	0.43	0.32	0.24	0.19	0.14	0.11	0.08	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05
-110	0.43	0.34	0.26	0.20	0.15	0.10	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05
-100	0.43	0.36	0.28	0.22	0.16	0.11	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
-90	0.43	0.37	0.30	0.24	0.18	0.12	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
-80	0.43	0.37	0.32	0.26	0.20	0.13	0.06	0.08	0.11	0.14	0.16	0.19	0.21	0.22	0.24	0.25	0.25	0.26	0.26
-70	0.43	0.38	0.34	0.30	0.28	0.26	0.26	0.32	0.39	0.48	0.56	0.63	0.71	0.77	0.83	0.88	0.91	0.93	0.94
-60	0.43	0.39	0.38	0.39	0.43	0.49	0.55	0.65	0.82	0.98	1.15	1.33	1.50	1.67	1.81	1.95	2.04	2.11	2.14
-50	0.43	0.41	0.44	0.51	0.62	0.76	0.92	1.10	1.34	1.65	1.99	2.35	2.72	3.11	3.48	3.82	4.09	4.29	4.38
-40	0.43	0.43	0.50	0.64	0.82	1.06	1.34	1.66	2.01	2.48	3.10	3.82	4.64	5.55	6.51	7.49	8.29	8.88	9.15
-30	0.43	0.45	0.56	0.76	1.04	1.37	1.80	2.30	2.89	3.61	4.54	5.92	7.69	9.87	12.6	15.6	18.6	21.0	22.0
-20	0.43	0.47	0.63	0.88	1.22	1.67	2.24	2.94	3.84	5.02	6.60	8.79	12.2	17.6	25.9	37.4	51.1	63.4	68.9
-10	0.43	0.50	0.68	0.97	1.38	1.92	2.62	3.50	4.69	6.32	8.62	12.2	18.1	28.8	49.3	89.7	161	257	309
0	0.43	0.51	0.71	1.03	1.48	2.08	2.86	3.87	5.23	7.12	9.81	14.1	21.1	33.1	56.8	109	238	492	666
10	0.43	0.51	0.70	1.01	1.45	2.02	2.76	3.71	4.96	6.67	9.08	12.7	18.4	27.6	43.1	71.1	122	189	211
20	0.43	0.50	0.69	0.97	1.35	1.86	2.51	3.32	4.34	5.66	7.41	9.84	13.2	18.2	25.0	33.9	44.2	52.0	54.4
30	0.43	0.49	0.65	0.89	1.22	1.63	2.16	2.79	3.54	4.45	5.57	7.01	8.81	11.0	13.6	16.4	18.9	20.6	21.2
40	0.43	0.48	0.61	0.80	1.05	1.36	1.75	2.21	2.72	3.32	4.01	4.80	5.67	6.63	7.62	8.51	9.26	9.78	9.98
50	0.43	0.47	0.57	0.71	0.88	1.10	1.35	1.65	1.97	2.34	2.74	3.16	3.58	4.01	4.41	4.75	5.03	5.21	5.27
60	0.43	0.46	0.52	0.61	0.72	0.86	1.00	1.18	1.35	1.54	1.74	1.94	2.15	2.34	2.52	2.67	2.79	2.86	2.89
70	0.43	0.45	0.49	0.53	0.59	0.66	0.73	0.80	0.88	0.95	1.03	1.11	1.18	1.27	1.33	1.39	1.43	1.46	1.47
80	0.43	0.44	0.46	0.48	0.50	0.53	0.55	0.57	0.58	0.59	0.60	0.62	0.63	0.65	0.67	0.69	0.70	0.72	0.73
90	0.43	0.43	0.44	0.45	0.45	0.46	0.46	0.46	0.45	0.44	0.44	0.43	0.42	0.43	0.44	0.44	0.45	0.45	0.46
100	0.43	0.42	0.40	0.39	0.38	0.37	0.36	0.34	0.32	0.30	0.29	0.28	0.27	0.27	0.28	0.28	0.28	0.28	0.29
110	0.43	0.40	0.36	0.34	0.32	0.30	0.29	0.28	0.27	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.25	0.25	0.25
120	0.43	0.38	0.33	0.30	0.28	0.26	0.26	0.26	0.26	0.25	0.25	0.26	0.27	0.28	0.28	0.28	0.28	0.28	0.28
130	0.43	0.36	0.31	0.28	0.26	0.25	0.25	0.25	0.25	0.26	0.28	0.31	0.35	0.40	0.43	0.46	0.47	0.48	0.48
140	0.43	0.35	0.29	0.26	0.25	0.25	0.25	0.25	0.28	0.30	0.37	0.46	0.55	0.62	0.69	0.72	0.73	0.74	0.73
150	0.43	0.34	0.28	0.25	0.25	0.25	0.26	0.28	0.32	0.42	0.52	0.62	0.72	0.77	0.81	0.84	0.85	0.86	0.86
160	0.43	0.33	0.27	0.24	0.24	0.26	0.28	0.32	0.41	0.53	0.65	0.73	0.77	0.82	0.86	0.86	0.86	0.87	0.87
170	0.43	0.32	0.27	0.24	0.25	0.26	0.29	0.36	0.48	0.62	0.73	0.78	0.79	0.83	0.84	0.85	0.83	0.80	0.83
180	0.43	0.32	0.27	0.24	0.25	0.26	0.31	0.38	0.51	0.65	0.77	0.78	0.78	0.77	0.75	0.73	0.71	0.63	0.67

H_b Range: -90 - 90DEGH_b Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-08-14

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:DecoBody-330mm-RGBW BLUE-15D-Rev1	TYPE:RGBW-Blue	WEIGHT:
SPEC.:15 DEG	DIM.:330mm	SERIAL No.:IES001500
MFR.:	SUR.:	Shielding Angle:

Table--2
UNIT: cd

H(DEC) V(DEC)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-180	0.56	0.56	0.55	0.50	0.44	0.36	0.27	0.17	0.09	0.04	0.04	0.05	0.06	0.06	0.06	0.05	0.05	0.05	
-170	0.64	0.61	0.60	0.56	0.46	0.36	0.26	0.17	0.09	0.05	0.04	0.06	0.06	0.06	0.06	0.05	0.05	0.05	
-160	0.60	0.55	0.50	0.45	0.38	0.30	0.21	0.13	0.08	0.04	0.05	0.05	0.05	0.06	0.06	0.05	0.05	0.05	
-150	0.40	0.36	0.31	0.27	0.22	0.17	0.12	0.09	0.04	0.05	0.05	0.05	0.05	0.06	0.06	0.05	0.05	0.05	
-140	0.19	0.17	0.13	0.11	0.08	0.06	0.06	0.05	0.05	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.05	0.05	
-130	0.07	0.06	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.06	0.05	0.05	
-120	0.05	0.05	0.05	0.06	0.07	0.07	0.06	0.06	0.06	0.05	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	
-110	0.06	0.06	0.06	0.07	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	
-100	0.06	0.06	0.07	0.07	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	
-90	0.06	0.06	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	
-80	0.26	0.25	0.24	0.23	0.22	0.21	0.19	0.16	0.13	0.11	0.08	0.06	0.06	0.06	0.06	0.06	0.05	0.05	
-70	0.93	0.90	0.86	0.81	0.76	0.69	0.62	0.55	0.47	0.39	0.31	0.24	0.18	0.13	0.09	0.07	0.06	0.05	
-60	2.10	2.02	1.91	1.77	1.62	1.46	1.30	1.13	0.97	0.80	0.65	0.50	0.37	0.26	0.16	0.10	0.07	0.05	
-50	4.25	4.02	3.72	3.37	2.99	2.63	2.27	1.93	1.62	1.32	1.05	0.81	0.60	0.41	0.26	0.14	0.07	0.05	
-40	8.75	8.06	7.17	6.17	5.29	4.45	3.69	3.01	2.42	1.92	1.50	1.14	0.83	0.57	0.35	0.19	0.08	0.05	
-30	20.4	17.7	14.6	11.7	9.29	7.30	5.67	4.38	3.38	2.60	1.97	1.47	1.06	0.72	0.44	0.23	0.09	0.05	
-20	60.5	46.8	33.9	23.6	16.3	11.4	8.15	5.96	4.38	3.25	2.40	1.75	1.24	0.84	0.51	0.26	0.10	0.05	
-10	231	140	78.1	44.3	26.0	16.1	10.6	7.32	5.18	3.73	2.71	1.95	1.38	0.92	0.56	0.29	0.11	0.05	
0	519	257	116	56.8	30.9	18.2	11.6	7.84	5.47	3.91	2.82	2.02	1.43	0.95	0.58	0.30	0.11	0.05	
10	170	107	62.9	39.3	25.2	16.4	11.1	7.74	5.51	3.99	2.90	2.09	1.47	0.98	0.60	0.32	0.12	0.05	
20	50.0	41.2	31.4	23.2	17.0	12.4	9.12	6.71	4.99	3.72	2.75	2.01	1.42	0.96	0.59	0.32	0.13	0.05	
30	20.2	18.2	15.6	12.9	10.5	8.43	6.72	5.35	4.17	3.22	2.44	1.81	1.30	0.90	0.57	0.31	0.13	0.05	
40	9.69	9.11	8.32	7.39	6.42	5.50	4.65	3.88	3.22	2.61	2.02	1.53	1.13	0.79	0.51	0.29	0.13	0.05	
50	5.18	4.98	4.68	4.32	3.91	3.50	3.07	2.67	2.28	1.92	1.57	1.23	0.93	0.67	0.45	0.26	0.13	0.05	
60	2.85	2.77	2.64	2.48	2.30	2.10	1.90	1.70	1.50	1.32	1.15	0.94	0.74	0.55	0.38	0.24	0.13	0.05	
70	1.45	1.42	1.37	1.31	1.24	1.16	1.09	1.01	0.94	0.87	0.80	0.71	0.57	0.44	0.32	0.21	0.13	0.05	
80	0.72	0.70	0.69	0.66	0.64	0.62	0.61	0.61	0.60	0.58	0.57	0.55	0.45	0.37	0.28	0.20	0.12	0.05	
90	0.45	0.44	0.43	0.43	0.42	0.41	0.42	0.43	0.43	0.44	0.45	0.46	0.39	0.32	0.25	0.19	0.12	0.05	
100	0.28	0.28	0.27	0.27	0.27	0.27	0.28	0.28	0.29	0.31	0.33	0.35	0.31	0.27	0.22	0.17	0.12	0.05	
110	0.25	0.25	0.25	0.26	0.26	0.26	0.26	0.26	0.26	0.26	0.27	0.27	0.25	0.22	0.19	0.16	0.11	0.05	
120	0.28	0.29	0.29	0.28	0.28	0.27	0.26	0.26	0.25	0.25	0.25	0.23	0.21	0.19	0.17	0.14	0.10	0.05	
130	0.49	0.48	0.46	0.44	0.41	0.36	0.32	0.29	0.26	0.25	0.24	0.21	0.19	0.16	0.15	0.12	0.10	0.05	
140	0.74	0.73	0.73	0.69	0.64	0.56	0.47	0.38	0.31	0.26	0.21	0.19	0.16	0.14	0.13	0.11	0.09	0.05	
150	0.86	0.86	0.85	0.82	0.78	0.72	0.64	0.53	0.38	0.26	0.20	0.16	0.14	0.12	0.11	0.10	0.08	0.05	
160	0.87	0.87	0.86	0.85	0.82	0.78	0.66	0.51	0.36	0.24	0.16	0.13	0.12	0.10	0.09	0.08	0.07	0.05	
170	0.79	0.83	0.85	0.80	0.71	0.60	0.49	0.37	0.25	0.16	0.11	0.10	0.09	0.08	0.08	0.07	0.06	0.05	
180	0.56	0.56	0.55	0.50	0.44	0.36	0.27	0.17	0.09	0.04	0.04	0.05	0.06	0.06	0.06	0.05	0.05	0.05	

H_b Range:-90 - 90DEG
H_b Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks: