

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	2833.6 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	58.7V x 57.8H
	At 50% of Imax	27.0V x 27.0H
	At 90% of Imax	10.0V x 10.1H

Beam Flux	Total	1000.2 lumens per klm.
	To 10% of Imax	740.1 lumens per klm.
	To 50% of Imax	347.1 lumens per klm.
	To 90% of Imax	61.0 lumens per klm.

Upward LOR	1.8 %
Downward LOR	98.2 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME:DecoBody-330mm-RGBW BLUE-25D-Rev1	TYPE:RGBW-Blue	WEIGHT:
SPEC.:25 DEG	DIM.:330mm	SERIAL No.:IES001517
MFR.:	SUR.:	Shielding Angle:



DATA OF LAMP		Eff:9.63lm/W	
MODEL		Imax(cd)	305.5
NOMINAL POWER(W)	11.3	AVAILABILITY(%)	74.1
RATED VOLTAGE(V)	220	Avai. FLUX(lm)	79.89
NOMINAL FLUX(lm)	107.8	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	107.8
TEST VOLTAGE(V)	221.4	q @50%(H,V)	27,27DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm				F t	F a
	0.02	0.03	0.04	0.05	0.06	0.07	0.08	0.09	0.09	0.09	0.08	0.08	0.07	0.06	0.05	0.04	0.03	0.02	1.04	0.00		
	0.03	0.04	0.05	0.06	0.08	0.10	0.11	0.13	0.13	0.13	0.12	0.11	0.09	0.07	0.06	0.05	0.04	0.03	1.42	0.00		
	0.03	0.04	0.06	0.08	0.11	0.14	0.17	0.19	0.20	0.20	0.18	0.15	0.13	0.10	0.08	0.06	0.04	0.03	1.99	0.10		
	0.04	0.05	0.08	0.11	0.15	0.20	0.25	0.30	0.32	0.32	0.28	0.23	0.18	0.13	0.10	0.07	0.05	0.04	2.88	1.58		
	0.04	0.06	0.09	0.14	0.20	0.29	0.39	0.48	0.54	0.52	0.45	0.35	0.25	0.18	0.12	0.08	0.06	0.04	4.29	3.28		
	0.05	0.07	0.11	0.17	0.26	0.41	0.60	0.79	0.89	0.87	0.72	0.53	0.36	0.23	0.15	0.10	0.06	0.04	6.40	5.58		
	0.05	0.08	0.13	0.21	0.34	0.55	0.86	1.20	1.41	1.36	1.09	0.75	0.48	0.29	0.18	0.11	0.07	0.05	9.21	8.48		
	0.06	0.09	0.14	0.23	0.40	0.68	1.12	1.62	1.95	1.87	1.47	0.98	0.60	0.36	0.21	0.12	0.08	0.05	12.0	11.4		
	0.06	0.09	0.15	0.25	0.43	0.75	1.24	1.83	2.24	2.15	1.73	1.18	0.70	0.40	0.23	0.13	0.08	0.05	13.7	13.0		
	0.06	0.09	0.14	0.24	0.42	0.73	1.20	1.74	2.09	2.07	1.69	1.16	0.70	0.40	0.22	0.13	0.08	0.05	13.2	12.6		
	0.05	0.08	0.13	0.22	0.37	0.63	1.01	1.40	1.64	1.61	1.32	0.93	0.58	0.34	0.20	0.12	0.07	0.04	10.8	10.1		
	0.05	0.07	0.11	0.18	0.30	0.48	0.72	0.95	1.10	1.08	0.90	0.66	0.43	0.27	0.17	0.10	0.06	0.04	7.69	6.94		
	0.04	0.06	0.09	0.15	0.23	0.34	0.47	0.60	0.68	0.66	0.56	0.43	0.30	0.20	0.13	0.08	0.06	0.04	5.11	4.25		
	0.03	0.05	0.07	0.11	0.16	0.22	0.30	0.36	0.40	0.39	0.34	0.27	0.20	0.14	0.10	0.07	0.05	0.03	3.32	2.22		
	0.03	0.04	0.06	0.08	0.11	0.15	0.19	0.22	0.24	0.23	0.21	0.17	0.14	0.10	0.08	0.05	0.04	0.03	2.17	0.47		
	0.02	0.03	0.05	0.06	0.08	0.10	0.12	0.14	0.15	0.14	0.13	0.11	0.09	0.07	0.06	0.04	0.03	0.02	1.46	0.00		
	0.02	0.03	0.04	0.05	0.06	0.07	0.08	0.09	0.09	0.09	0.09	0.08	0.06	0.05	0.04	0.03	0.03	0.02	1.01	0.00		
	0.02	0.02	0.03	0.03	0.04	0.05	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.04	0.03	0.03	0.02	0.72	0.00		
	-45	-40	-35	-30	-25	-20	-15	-10	HORIZONTAL (DEG)				10	15	20	25	30	35	40	45		
F t	0.69	1.03	1.56	2.42	3.80	5.95	8.95	12.2	14.2	13.9	11.4	8.22	5.41	3.45	2.20	1.42	0.93	0.62	98	---		
F a	0.00	0.00	0.00	0.93	2.71	5.02	8.10	11.4	13.5	13.1	10.6	7.33	4.43	2.29	0.56	0.00	0.00	0.00	---	80		

one-half-peak spread: U:13.7,D:13.6 , L:13.6,R:13.6


NEMA Beam Type: Type 4

H_(b) Range: -90 - 90DEG
 H_(b) Interval: 0.5DEG
 Test Speed: LOW
 Temperature: 25.3DEG
 Operators: Fan
 Test Date: 2023-08-14

V(B) Range: -180 - 180DEG
 V(B) Interval: 0.5DEG
 Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
 Humidity: 65.0%
 Test Distance: 8.630m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

NAME:DecoBody-330mm-RGBW BLUE-25D-Rev1	TYPE:RGBW-Blue	WEIGHT:
SPEC.:25 DEG	DIM.:330mm	SERIAL No.:IES001517
MFR.:	SUR.:	Shielding Angle:




H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME:DecoBody-330mm-RGBW BLUE-25D-Rev1	TYPE:RGBW-Blue	WEIGHT:
SPEC.:25 DEG	DIM.:330mm	SERIAL No.:IES001517
MFR.:	SUR.:	Shielding Angle:



H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-08-14

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H(b) Range: -90 - 90DEG
H(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-08-14

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME:DecoBody-330mm-RGBW BLUE-25D-Rev1	TYPE:RGBW-Blue	WEIGHT:
SPEC.:25 DEG	DIM.:330mm	SERIAL No.:IES001517
MFR.:	SUR.:	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:DecoBody-330mm-RGBW BLUE-25D-Rev1	TYPE:RGBW-Blue	WEIGHT:
SPEC.:25 DEG	DIM.:330mm	SERIAL No.:IES001517
MFR.:	SUR.:	Shielding Angle:

Table--1

UNIT: cd

H(°) \ V(°)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	0.37	0.32	0.28	0.28	0.28	0.31	0.34	0.41	0.51	0.61	0.70	0.76	0.77	0.77	0.76	0.73	0.70	0.66	0.71
-170	0.37	0.31	0.27	0.26	0.26	0.26	0.29	0.32	0.38	0.45	0.50	0.54	0.55	0.56	0.56	0.57	0.59	0.59	0.64
-160	0.37	0.31	0.26	0.24	0.23	0.23	0.22	0.24	0.26	0.28	0.29	0.30	0.31	0.37	0.43	0.48	0.51	0.56	0.59
-150	0.37	0.31	0.25	0.22	0.21	0.19	0.18	0.16	0.15	0.13	0.12	0.16	0.20	0.24	0.28	0.33	0.38	0.42	0.44
-140	0.37	0.31	0.24	0.21	0.18	0.16	0.14	0.11	0.08	0.07	0.07	0.08	0.10	0.13	0.14	0.18	0.21	0.24	0.26
-130	0.37	0.30	0.24	0.20	0.17	0.14	0.11	0.08	0.06	0.06	0.06	0.06	0.06	0.05	0.06	0.07	0.09	0.11	0.12
-120	0.37	0.30	0.25	0.19	0.15	0.12	0.09	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.06	0.06	0.06	0.06	0.07
-110	0.37	0.30	0.25	0.20	0.15	0.11	0.07	0.06	0.06	0.06	0.06	0.06	0.05	0.06	0.06	0.06	0.06	0.07	0.07
-100	0.37	0.31	0.25	0.20	0.16	0.11	0.07	0.06	0.06	0.06	0.05	0.05	0.06	0.06	0.06	0.06	0.06	0.07	0.07
-90	0.37	0.32	0.27	0.21	0.16	0.11	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.06
-80	0.37	0.32	0.28	0.23	0.17	0.12	0.05	0.06	0.09	0.12	0.15	0.18	0.20	0.22	0.23	0.24	0.25	0.26	0.26
-70	0.37	0.33	0.30	0.26	0.25	0.24	0.25	0.31	0.41	0.49	0.58	0.67	0.76	0.84	0.91	0.97	1.02	1.05	1.07
-60	0.37	0.35	0.33	0.36	0.42	0.50	0.57	0.66	0.84	1.04	1.25	1.47	1.69	1.89	2.06	2.21	2.32	2.39	2.41
-50	0.37	0.37	0.39	0.49	0.63	0.79	0.95	1.14	1.42	1.79	2.19	2.63	3.09	3.54	3.94	4.29	4.57	4.76	4.82
-40	0.37	0.37	0.46	0.63	0.87	1.12	1.42	1.76	2.17	2.75	3.50	4.35	5.32	6.35	7.46	8.45	9.28	9.83	10.0
-30	0.37	0.39	0.54	0.78	1.10	1.47	1.92	2.50	3.20	4.09	5.27	6.99	9.14	11.8	14.9	18.3	21.5	23.7	24.3
-20	0.37	0.41	0.61	0.92	1.31	1.79	2.42	3.24	4.32	5.79	7.84	10.9	15.5	22.4	31.9	43.6	55.6	65.6	68.7
-10	0.37	0.43	0.66	1.03	1.48	2.06	2.85	3.88	5.32	7.37	10.4	15.4	23.7	37.8	61.1	96.1	137	171	182
0	0.37	0.44	0.69	1.10	1.60	2.24	3.12	4.27	5.93	8.31	12.0	18.0	28.3	46.3	78.1	131	203	271	302
10	0.37	0.44	0.69	1.09	1.58	2.21	3.06	4.18	5.76	8.01	11.4	16.8	25.8	41.1	66.7	107	162	212	227
20	0.37	0.44	0.67	1.03	1.49	2.06	2.81	3.79	5.10	6.87	9.40	13.1	18.6	27.0	39.1	55.5	74.0	87.1	91.6
30	0.37	0.43	0.63	0.94	1.36	1.83	2.44	3.21	4.18	5.42	7.01	9.20	12.0	15.6	20.1	25.0	29.3	32.3	33.4
40	0.37	0.42	0.58	0.83	1.17	1.55	1.99	2.56	3.22	4.03	5.01	6.18	7.52	9.01	10.6	12.0	13.2	14.0	14.3
50	0.37	0.42	0.52	0.70	0.95	1.26	1.56	1.92	2.35	2.85	3.41	4.02	4.68	5.37	5.95	6.45	6.86	7.12	7.22
60	0.37	0.42	0.47	0.58	0.74	0.93	1.16	1.38	1.62	1.88	2.18	2.49	2.81	3.12	3.37	3.60	3.77	3.89	3.95
70	0.37	0.40	0.43	0.48	0.56	0.67	0.77	0.90	1.03	1.16	1.30	1.42	1.54	1.68	1.79	1.90	1.99	2.06	2.10
80	0.37	0.39	0.41	0.44	0.46	0.49	0.53	0.56	0.59	0.64	0.68	0.73	0.78	0.82	0.86	0.89	0.92	0.95	0.97
90	0.37	0.38	0.39	0.41	0.42	0.43	0.44	0.43	0.43	0.42	0.42	0.41	0.41	0.41	0.41	0.42	0.42	0.43	0.43
100	0.37	0.37	0.37	0.37	0.38	0.38	0.38	0.37	0.35	0.34	0.33	0.31	0.30	0.30	0.31	0.32	0.32	0.33	0.34
110	0.37	0.36	0.35	0.35	0.34	0.34	0.33	0.31	0.31	0.29	0.29	0.28	0.28	0.28	0.28	0.29	0.29	0.29	0.29
120	0.37	0.35	0.34	0.32	0.31	0.30	0.30	0.29	0.28	0.28	0.28	0.29	0.30	0.31	0.31	0.30	0.30	0.30	0.29
130	0.37	0.34	0.32	0.30	0.30	0.29	0.28	0.28	0.28	0.29	0.30	0.33	0.37	0.40	0.42	0.43	0.44	0.44	0.43
140	0.37	0.34	0.31	0.29	0.29	0.28	0.29	0.29	0.29	0.32	0.37	0.44	0.50	0.55	0.60	0.62	0.64	0.64	0.63
150	0.37	0.33	0.29	0.29	0.28	0.28	0.29	0.30	0.35	0.41	0.48	0.56	0.63	0.69	0.74	0.78	0.79	0.78	0.77
160	0.37	0.33	0.29	0.28	0.28	0.29	0.31	0.35	0.42	0.50	0.58	0.65	0.71	0.76	0.78	0.80	0.80	0.81	0.82
170	0.37	0.32	0.28	0.28	0.28	0.30	0.33	0.39	0.47	0.57	0.66	0.72	0.76	0.77	0.78	0.78	0.78	0.78	0.82
180	0.37	0.32	0.28	0.28	0.28	0.31	0.34	0.41	0.51	0.61	0.70	0.76	0.77	0.77	0.76	0.73	0.70	0.66	0.73

H_(b) Range: -90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-08-14

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:DecoBody-330mm-RGBW BLUE-25D-Rev1	TYPE:RGBW-Blue	WEIGHT:
SPEC.:25 DEG	DIM.:330mm	SERIAL No.:IES001517
MFR.:	SUR.:	Shielding Angle:

Table--2

UNIT: cd

H(°) \ V(°)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90
-180	0.58	0.56	0.55	0.49	0.42	0.34	0.27	0.19	0.11	0.06	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
-170	0.57	0.58	0.57	0.52	0.45	0.36	0.27	0.19	0.12	0.07	0.06	0.06	0.06	0.06	0.05	0.05	0.05	0.05
-160	0.55	0.51	0.48	0.44	0.38	0.32	0.24	0.17	0.11	0.07	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05
-150	0.42	0.38	0.34	0.30	0.25	0.21	0.17	0.13	0.09	0.07	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05
-140	0.24	0.21	0.19	0.15	0.13	0.10	0.09	0.08	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05
-130	0.11	0.09	0.08	0.07	0.06	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05
-120	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05	0.05
-110	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05	0.05
-100	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05	0.05
-90	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05	0.05
-80	0.25	0.25	0.24	0.22	0.21	0.19	0.16	0.14	0.12	0.08	0.07	0.06	0.06	0.06	0.06	0.05	0.05	0.05
-70	1.05	1.02	0.97	0.91	0.84	0.76	0.66	0.56	0.47	0.37	0.29	0.22	0.15	0.11	0.08	0.06	0.05	0.05
-60	2.37	2.29	2.17	2.02	1.84	1.65	1.44	1.23	1.02	0.82	0.63	0.48	0.36	0.24	0.15	0.09	0.06	0.05
-50	4.70	4.47	4.15	3.78	3.37	2.98	2.57	2.16	1.77	1.40	1.08	0.82	0.59	0.40	0.24	0.12	0.05	0.05
-40	9.65	8.94	8.01	6.92	5.98	5.05	4.20	3.42	2.73	2.13	1.62	1.20	0.85	0.56	0.35	0.17	0.07	0.05
-30	23.0	20.3	16.9	13.7	10.9	8.50	6.60	5.08	3.90	2.96	2.20	1.59	1.11	0.72	0.44	0.21	0.08	0.05
-20	63.1	51.6	39.6	28.8	20.2	14.0	9.93	7.16	5.19	3.79	2.73	1.94	1.33	0.86	0.52	0.25	0.09	0.05
-10	164	126	86.4	54.9	34.1	21.3	13.7	9.14	6.31	4.44	3.13	2.18	1.48	0.95	0.57	0.28	0.09	0.05
0	273	204	129	75.8	43.8	25.8	15.8	10.2	6.85	4.73	3.30	2.29	1.54	0.99	0.59	0.29	0.09	0.05
10	197	144	92.6	58.2	36.4	22.9	14.9	9.98	6.89	4.85	3.42	2.38	1.61	1.04	0.62	0.31	0.10	0.05
20	82.5	66.6	49.0	34.3	23.8	16.7	11.9	8.57	6.20	4.51	3.24	2.30	1.57	1.02	0.63	0.31	0.11	0.05
30	31.2	27.4	22.7	18.2	14.3	11.1	8.65	6.70	5.13	3.86	2.86	2.07	1.44	0.96	0.59	0.30	0.11	0.05
40	13.7	12.7	11.4	9.94	8.51	7.14	5.92	4.85	3.91	3.09	2.35	1.74	1.24	0.85	0.54	0.28	0.11	0.05
50	7.04	6.72	6.26	5.74	5.16	4.52	3.90	3.32	2.77	2.27	1.81	1.37	1.01	0.72	0.45	0.25	0.11	0.05
60	3.87	3.74	3.55	3.31	3.06	2.76	2.44	2.13	1.83	1.55	1.30	1.03	0.79	0.56	0.37	0.22	0.12	0.05
70	2.05	1.98	1.89	1.78	1.66	1.52	1.38	1.24	1.11	0.98	0.87	0.73	0.56	0.42	0.29	0.19	0.11	0.05
80	0.94	0.91	0.87	0.82	0.78	0.73	0.69	0.65	0.61	0.57	0.54	0.51	0.42	0.33	0.26	0.18	0.11	0.05
90	0.43	0.42	0.41	0.41	0.40	0.40	0.40	0.41	0.41	0.42	0.43	0.43	0.37	0.30	0.24	0.17	0.11	0.05
100	0.33	0.32	0.31	0.31	0.30	0.30	0.31	0.32	0.33	0.34	0.36	0.37	0.32	0.27	0.22	0.16	0.11	0.05
110	0.29	0.29	0.29	0.28	0.28	0.28	0.28	0.28	0.29	0.29	0.31	0.31	0.28	0.24	0.20	0.15	0.10	0.05
120	0.30	0.30	0.30	0.31	0.30	0.30	0.29	0.28	0.28	0.28	0.28	0.27	0.24	0.21	0.18	0.14	0.10	0.05
130	0.44	0.44	0.44	0.42	0.40	0.37	0.34	0.30	0.28	0.28	0.26	0.23	0.21	0.18	0.15	0.13	0.09	0.05
140	0.64	0.65	0.64	0.61	0.57	0.51	0.45	0.39	0.33	0.28	0.23	0.20	0.18	0.16	0.14	0.11	0.08	0.05
150	0.78	0.79	0.78	0.75	0.70	0.65	0.57	0.50	0.38	0.28	0.21	0.17	0.15	0.13	0.12	0.09	0.07	0.05
160	0.81	0.80	0.80	0.79	0.77	0.72	0.61	0.47	0.34	0.24	0.18	0.14	0.12	0.11	0.10	0.08	0.06	0.05
170	0.77	0.79	0.79	0.74	0.66	0.57	0.46	0.35	0.25	0.16	0.12	0.10	0.09	0.08	0.08	0.07	0.05	0.05
180	0.58	0.56	0.55	0.49	0.42	0.34	0.27	0.19	0.11	0.06	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05

H_(b) Range: -90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-08-14

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks: