

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity (Luminaire orientation as tested.)	369.2 cd per klm. 0.0 degrees vertical 0.0 degrees horizontal
---	---

Beam Spread	At 10% of Imax	157.2V x 156.8H
	At 50% of Imax	108.8V x 110.3H
	At 90% of Imax	45.7V x 47.3H

Beam Flux	Total	1000.0 lumens per klm.
	To 10% of Imax	974.9 lumens per klm.
	To 50% of Imax	714.2 lumens per klm.
	To 90% of Imax	155.3 lumens per klm.

Upward LOR	0.9 %
Downward LOR	99.1 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME:ScapeDirect-1000mm-RGB BLUE-110D-Rev1	TYPE:RGB-BLUE	WEIGHT:
SPEC.:110 DEG	DIM.:1000mm	SERIAL No.:IES001540
MFR.:	SUR.:	Shielding Angle:



DATA OF LAMP		Eff:3.79lm/W	
MODEL		Imax(cd)	9.558
NOMINAL POWER(W)	6.84	AVAILABILITY(%)	97.5
RATED VOLTAGE(V)	24	Avai. FLUX(lm)	25.24
NOMINAL FLUX(lm)	25.89	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	25.89
TEST VOLTAGE(V)	24	q @50%(H,V)	110,109DEG

		AREA FLUX DIAGRAM																UNIT:lm			F t	F a
VERTICAL (DEG)	90	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.08	0.00		
	80	0.00	0.00	0.00	0.01	0.02	0.03	0.04	0.04	0.05	0.05	0.04	0.04	0.03	0.02	0.01	0.00	0.00	0.37	0.29		
	70	0.00	0.00	0.01	0.02	0.04	0.06	0.08	0.09	0.10	0.10	0.09	0.08	0.06	0.04	0.02	0.01	0.00	0.80	0.78		
	60	0.00	0.00	0.02	0.04	0.06	0.09	0.12	0.14	0.15	0.15	0.14	0.12	0.09	0.06	0.04	0.02	0.00	1.23	1.22		
	50	0.00	0.01	0.02	0.05	0.09	0.12	0.15	0.18	0.19	0.19	0.18	0.15	0.12	0.09	0.05	0.02	0.01	1.62	1.62		
	40	0.00	0.01	0.03	0.06	0.10	0.15	0.18	0.21	0.23	0.23	0.21	0.18	0.15	0.10	0.06	0.03	0.01	1.96	1.95		
	30	0.00	0.01	0.04	0.07	0.12	0.17	0.21	0.24	0.26	0.26	0.24	0.21	0.16	0.12	0.07	0.04	0.01	2.21	2.21		
		0.00	0.01	0.04	0.08	0.13	0.18	0.22	0.26	0.28	0.28	0.26	0.22	0.18	0.13	0.08	0.04	0.01	2.38	2.38		
		0.00	0.01	0.04	0.08	0.13	0.18	0.23	0.26	0.28	0.28	0.26	0.23	0.18	0.13	0.08	0.04	0.01	2.45	2.44		
		0.00	0.01	0.04	0.08	0.13	0.18	0.23	0.26	0.28	0.28	0.26	0.22	0.18	0.13	0.08	0.04	0.01	2.42	2.41		
		0.00	0.01	0.04	0.08	0.13	0.17	0.21	0.25	0.27	0.27	0.25	0.21	0.17	0.12	0.08	0.04	0.01	2.31	2.31		
	-30	0.00	0.01	0.03	0.07	0.11	0.16	0.20	0.23	0.25	0.25	0.23	0.20	0.16	0.11	0.07	0.03	0.01	2.13	2.12		
	-40	0.00	0.01	0.03	0.06	0.10	0.14	0.17	0.20	0.22	0.22	0.20	0.17	0.14	0.10	0.06	0.03	0.01	1.86	1.86		
	-50	0.00	0.01	0.02	0.05	0.08	0.11	0.14	0.17	0.18	0.18	0.17	0.14	0.11	0.08	0.05	0.02	0.01	1.53	1.53		
	-60	0.00	0.00	0.02	0.04	0.06	0.09	0.11	0.13	0.14	0.14	0.13	0.11	0.09	0.06	0.04	0.02	0.00	1.16	1.15		
	-70	0.00	0.00	0.01	0.02	0.04	0.06	0.07	0.08	0.09	0.09	0.08	0.07	0.06	0.04	0.02	0.01	0.00	0.75	0.73		
-80	0.00	0.00	0.00	0.01	0.02	0.03	0.03	0.04	0.04	0.04	0.04	0.03	0.03	0.02	0.01	0.00	0.00	0.35	0.26			
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.05	0.00			
		-90	-80	-70	-60	-50	-40	-30	-20	HORIZONTAL (DEG)				20	30	40	50	60	70	80	90	
F t	0.01	0.11	0.40	0.84	1.37	1.92	2.42	2.80	3.01	3.00	2.78	2.40	1.90	1.35	0.83	0.40	0.12	0.01	26	---		
F a	0.00	0.08	0.38	0.82	1.35	1.90	2.40	2.77	2.98	2.98	2.76	2.37	1.87	1.33	0.80	0.37	0.08	0.00	---	25		

one-half-peak spread: U:52.5,D:49.4 , L:53.4,R:52.0


NEMA Beam Type: Type 7

H_(b) Range: -90 - 90DEG
 H_(b) Interval: 0.5DEG
 Test Speed: LOW
 Temperature:25.3DEG
 Operators:Fan
 Test Date:2023-08-14

V(B) Range: -180 - 180DEG
 V(B) Interval: 0.5DEG
 Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
 Humidity:65.0%
 Test Distance:8.630m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

NAME:ScapeDirect-1000mm-RGB BLUE-110D-Rev1	TYPE:RGB-BLUE	WEIGHT:
SPEC.:110 DEG	DIM.:1000mm	SERIAL No.:IES001540
MFR.:	SUR.:	Shielding Angle:




H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME:ScapeDirect-1000mm-RGB BLUE-110D-Rev1	TYPE:RGB-BLUE	WEIGHT:
SPEC.:110 DEG	DIM.:1000mm	SERIAL No.:IES001540
MFR.:	SUR.:	Shielding Angle:



H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-08-14

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H_b Range: -90 - 90DEG
H_b Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-08-14

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME:ScapeDirect-1000mm-RGB BLUE-110D-Rev1	TYPE:RGB-BLUE	WEIGHT:
SPEC.:110 DEG	DIM.:1000mm	SERIAL No.:IES001540
MFR.:	SUR.:	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:ScapeDirect-1000mm-RGB BLUE-110D-Rev1	TYPE:RGB-BLUE	WEIGHT:
SPEC.:110 DEG	DIM.:1000mm	SERIAL No.:IES001540
MFR.:	SUR.:	Shielding Angle:

Table--1

UNIT: cd

H(°) \ V(°)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05
-170	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.05	0.05	0.04	0.04	0.04	0.04	0.04	0.04	0.04	0.03	0.01	0.05
-160	0.06	0.06	0.06	0.05	0.05	0.04	0.04	0.03	0.03	0.02	0.02	0.02	0.02	0.01	0.01	0.01	0.00	0.02	0.04
-150	0.06	0.06	0.05	0.05	0.04	0.04	0.03	0.02	0.02	0.01	0.00	0.00	0.01	0.01	0.00	0.00	0.01	0.02	0.02
-140	0.06	0.06	0.05	0.04	0.04	0.03	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01
-130	0.06	0.06	0.05	0.04	0.03	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-120	0.06	0.05	0.04	0.04	0.03	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-110	0.06	0.05	0.04	0.03	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-100	0.06	0.05	0.04	0.03	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90	0.06	0.05	0.04	0.03	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-80	0.06	0.05	0.04	0.03	0.05	0.09	0.15	0.23	0.31	0.38	0.46	0.53	0.59	0.63	0.66	0.69	0.71	0.71	0.71
-70	0.06	0.05	0.06	0.16	0.32	0.51	0.71	0.92	1.12	1.32	1.50	1.67	1.81	1.93	2.03	2.11	2.16	2.19	2.20
-60	0.06	0.05	0.16	0.39	0.69	1.03	1.38	1.73	2.05	2.36	2.64	2.91	3.14	3.33	3.49	3.62	3.70	3.74	3.75
-50	0.06	0.07	0.28	0.65	1.10	1.57	2.05	2.51	2.94	3.36	3.73	4.07	4.38	4.64	4.85	5.02	5.15	5.22	5.24
-40	0.06	0.10	0.41	0.90	1.47	2.07	2.66	3.22	3.74	4.23	4.69	5.11	5.48	5.81	6.09	6.30	6.46	6.55	6.59
-30	0.06	0.12	0.52	1.12	1.80	2.50	3.18	3.82	4.42	4.98	5.47	5.96	6.40	6.78	7.11	7.39	7.59	7.71	7.76
-20	0.06	0.14	0.61	1.29	2.05	2.82	3.58	4.29	4.97	5.58	6.13	6.63	7.07	7.50	7.88	8.20	8.45	8.60	8.68
-10	0.06	0.16	0.66	1.39	2.21	3.03	3.84	4.61	5.33	6.00	6.61	7.15	7.63	8.03	8.35	8.64	8.93	9.18	9.29
0	0.06	0.16	0.68	1.42	2.26	3.11	3.94	4.74	5.51	6.20	6.85	7.43	7.94	8.36	8.71	8.99	9.17	9.28	9.30
10	0.06	0.16	0.66	1.39	2.22	3.05	3.87	4.66	5.42	6.11	6.75	7.33	7.85	8.29	8.66	8.96	9.19	9.35	9.47
20	0.06	0.15	0.61	1.30	2.07	2.86	3.64	4.39	5.11	5.78	6.40	6.96	7.46	7.89	8.25	8.54	8.75	8.90	8.97
30	0.06	0.13	0.52	1.13	1.82	2.54	3.26	3.95	4.61	5.23	5.80	6.31	6.77	7.17	7.50	7.77	7.96	8.09	8.14
40	0.06	0.11	0.41	0.90	1.48	2.11	2.73	3.34	3.91	4.46	4.97	5.43	5.83	6.18	6.47	6.70	6.87	6.97	7.01
50	0.06	0.08	0.29	0.65	1.10	1.59	2.10	2.60	3.07	3.53	3.95	4.33	4.67	4.97	5.21	5.39	5.53	5.61	5.64
60	0.06	0.07	0.18	0.40	0.69	1.04	1.40	1.76	2.12	2.47	2.79	3.08	3.34	3.57	3.74	3.89	3.99	4.05	4.08
70	0.06	0.07	0.10	0.20	0.34	0.52	0.72	0.93	1.15	1.36	1.56	1.75	1.92	2.07	2.18	2.27	2.34	2.38	2.40
80	0.06	0.07	0.08	0.09	0.13	0.17	0.22	0.28	0.34	0.41	0.48	0.55	0.61	0.67	0.72	0.76	0.79	0.81	0.82
90	0.06	0.07	0.08	0.08	0.09	0.10	0.10	0.10	0.09	0.09	0.08	0.07	0.07	0.07	0.08	0.09	0.09	0.10	0.11
100	0.06	0.07	0.08	0.08	0.08	0.09	0.10	0.09	0.08	0.08	0.07	0.07	0.06	0.07	0.07	0.07	0.08	0.08	0.08
110	0.06	0.07	0.07	0.08	0.08	0.08	0.08	0.08	0.07	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.07	0.07	0.07
120	0.06	0.07	0.07	0.07	0.08	0.08	0.08	0.08	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
130	0.06	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
140	0.06	0.07	0.07	0.07	0.07	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
150	0.06	0.07	0.07	0.07	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
160	0.06	0.06	0.07	0.07	0.07	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
170	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
180	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06

H_b Range: -90 - 90DEGH_b Interval: 0.5DEG

Test Speed: LOW

Temperature: 25.3DEG

Operators: Fan

Test Date: 2023-08-14

V(B) Range: -180 - 180DEG

V(B) Interval: 0.5DEG

Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity: 65.0%

Test Distance: 8.630m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:ScapeDirect-1000mm-RGB BLUE-110D-Rev1	TYPE:RGB-BLUE	WEIGHT:
SPEC.:110 DEG	DIM.:1000mm	SERIAL No.:IES001540
MFR.:	SUR.:	Shielding Angle:

Table--2

UNIT: cd

H(°) \ V(°)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90
-180	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-170	0.01	0.03	0.04	0.03	0.02	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-160	0.02	0.00	0.01	0.02	0.02	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-150	0.02	0.01	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-140	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-130	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-120	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-80	0.70	0.68	0.66	0.62	0.58	0.53	0.47	0.41	0.34	0.27	0.20	0.12	0.07	0.03	0.00	0.00	0.00	0.00
-70	2.18	2.14	2.07	1.98	1.87	1.74	1.60	1.44	1.27	1.08	0.88	0.68	0.49	0.31	0.15	0.04	0.00	0.00
-60	3.73	3.68	3.58	3.45	3.28	3.08	2.86	2.60	2.32	2.01	1.69	1.36	1.02	0.69	0.40	0.15	0.00	0.00
-50	5.21	5.13	5.00	4.83	4.60	4.34	4.04	3.70	3.33	2.92	2.48	2.03	1.56	1.10	0.66	0.29	0.03	0.00
-40	6.55	6.46	6.29	6.07	5.80	5.47	5.10	4.68	4.22	3.72	3.19	2.64	2.06	1.48	0.92	0.43	0.07	0.00
-30	7.72	7.60	7.40	7.12	6.80	6.41	5.97	5.49	4.96	4.39	3.78	3.15	2.48	1.81	1.15	0.55	0.11	0.00
-20	8.62	8.48	8.24	7.91	7.54	7.11	6.63	6.10	5.52	4.90	4.23	3.53	2.80	2.05	1.32	0.65	0.14	0.00
-10	9.22	8.99	8.70	8.38	8.00	7.55	7.04	6.48	5.87	5.21	4.51	3.77	3.00	2.21	1.43	0.71	0.16	0.00
0	9.27	9.11	8.87	8.56	8.17	7.72	7.20	6.63	6.00	5.33	4.61	3.85	3.08	2.27	1.47	0.74	0.16	0.00
10	9.30	9.13	8.91	8.60	8.20	7.72	7.19	6.60	5.97	5.28	4.56	3.80	3.02	2.22	1.43	0.71	0.16	0.00
20	8.87	8.70	8.48	8.20	7.84	7.42	6.90	6.32	5.69	5.02	4.32	3.59	2.83	2.06	1.32	0.65	0.14	0.00
30	8.07	7.92	7.71	7.45	7.12	6.73	6.28	5.77	5.18	4.55	3.89	3.22	2.52	1.82	1.15	0.56	0.12	0.00
40	6.95	6.83	6.65	6.41	6.12	5.77	5.38	4.93	4.43	3.88	3.30	2.70	2.09	1.49	0.92	0.44	0.08	0.00
50	5.60	5.50	5.35	5.15	4.90	4.61	4.27	3.89	3.49	3.03	2.56	2.07	1.57	1.11	0.67	0.31	0.05	0.00
60	4.04	3.96	3.84	3.69	3.50	3.27	3.02	2.73	2.41	2.08	1.72	1.37	1.02	0.70	0.41	0.18	0.02	0.00
70	2.37	2.31	2.23	2.13	2.00	1.84	1.68	1.50	1.30	1.10	0.89	0.69	0.51	0.34	0.19	0.08	0.02	0.00
80	0.80	0.77	0.72	0.68	0.62	0.56	0.50	0.44	0.37	0.31	0.26	0.21	0.16	0.11	0.06	0.04	0.02	0.00
90	0.10	0.09	0.09	0.08	0.07	0.06	0.07	0.08	0.08	0.09	0.10	0.10	0.09	0.07	0.05	0.03	0.02	0.00
100	0.08	0.08	0.07	0.07	0.07	0.06	0.07	0.07	0.08	0.08	0.09	0.09	0.08	0.06	0.05	0.03	0.02	0.00
110	0.07	0.07	0.07	0.07	0.06	0.06	0.07	0.07	0.07	0.07	0.08	0.08	0.07	0.06	0.04	0.03	0.02	0.00
120	0.06	0.06	0.06	0.06	0.06	0.06	0.07	0.07	0.07	0.07	0.07	0.07	0.06	0.05	0.04	0.03	0.01	0.00
130	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.07	0.07	0.06	0.05	0.04	0.03	0.02	0.01	0.00
140	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.04	0.03	0.03	0.02	0.01	0.00
150	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.04	0.04	0.03	0.02	0.02	0.01	0.01	0.00
160	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.04	0.03	0.03	0.02	0.02	0.02	0.01	0.01	0.01	0.00
170	0.06	0.06	0.06	0.05	0.04	0.04	0.03	0.02	0.02	0.02	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.00
180	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

H_(b) Range: -90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature: 25.3DEG

Operators: Fan

Test Date: 2023-08-14

V(B) Range: -180 - 180DEG

V(B) Interval: 0.5DEG

Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity: 65.0%

Test Distance: 8.630m [K=1.0000]

Remarks: