

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	364.3 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	157.9V x 157.4H
	At 50% of Imax	109.1V x 110.5H
	At 90% of Imax	45.7V x 47.2H

Beam Flux	Total	1000.0 lumens per klm.
	To 10% of Imax	967.3 lumens per klm.
	To 50% of Imax	708.3 lumens per klm.
	To 90% of Imax	154.0 lumens per klm.

Upward LOR	1.6 %
Downward LOR	98.4 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H(θ) Range:-90 - 90DEG
H(θ) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME:ScapeDirect-1000mm-RGB RED-110D-Rev1	TYPE:RGB-RED	WEIGHT:
SPEC.:110 DEG	DIM.:1000 mm	SERIAL No.:IES001538
MFR.:	SUR.:	Shielding Angle:



DATA OF LAMP		Eff:7.84lm/W	
MODEL		Imax(cd)	19.59
NOMINAL POWER(W)	6.86	AVAILABILITY(%)	96.7
RATED VOLTAGE(V)	24	Avai. FLUX(lm)	52.02
NOMINAL FLUX(lm)	53.78	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	53.78
TEST VOLTAGE(V)	24	q @50%(H,V)	111,109DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM															UNIT:lm			F t	F a
	0.00	0.00	0.00	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.02	0.02	0.01	0.01	0.01	0.00	0.00	0.00	0.19	0.00
90	0.00	0.00	0.01	0.02	0.04	0.06	0.08	0.09	0.10	0.10	0.09	0.07	0.06	0.04	0.02	0.01	0.00	0.00	0.78	0.61
80	0.00	0.01	0.02	0.05	0.08	0.12	0.16	0.19	0.20	0.20	0.18	0.16	0.12	0.08	0.05	0.02	0.01	0.00	1.65	1.60
70	0.00	0.01	0.04	0.08	0.13	0.19	0.24	0.28	0.30	0.30	0.28	0.24	0.19	0.13	0.08	0.04	0.01	0.00	2.52	2.50
60	0.00	0.01	0.05	0.11	0.18	0.25	0.31	0.36	0.39	0.39	0.36	0.31	0.25	0.18	0.11	0.05	0.01	0.00	3.32	3.30
50	0.00	0.02	0.06	0.13	0.21	0.30	0.38	0.43	0.47	0.46	0.43	0.37	0.30	0.21	0.13	0.06	0.02	0.00	4.00	3.99
40	0.00	0.02	0.07	0.15	0.24	0.34	0.42	0.49	0.53	0.52	0.49	0.42	0.34	0.24	0.15	0.07	0.02	0.00	4.53	4.52
30	0.00	0.02	0.08	0.16	0.26	0.37	0.46	0.53	0.57	0.56	0.52	0.45	0.36	0.26	0.16	0.08	0.02	0.00	4.88	4.87
-30	0.00	0.03	0.08	0.17	0.27	0.38	0.47	0.54	0.58	0.58	0.54	0.46	0.37	0.27	0.17	0.08	0.03	0.00	5.02	5.01
	0.00	0.03	0.08	0.17	0.27	0.37	0.47	0.53	0.57	0.58	0.53	0.46	0.37	0.26	0.17	0.08	0.03	0.00	4.97	4.96
	0.00	0.02	0.08	0.16	0.26	0.35	0.44	0.51	0.55	0.56	0.51	0.44	0.35	0.25	0.16	0.08	0.02	0.00	4.77	4.76
	0.00	0.02	0.07	0.15	0.24	0.32	0.41	0.47	0.51	0.51	0.47	0.41	0.33	0.23	0.15	0.07	0.02	0.00	4.39	4.38
	0.00	0.02	0.06	0.13	0.21	0.29	0.36	0.42	0.45	0.45	0.42	0.36	0.29	0.21	0.13	0.06	0.02	0.00	3.85	3.84
-40	0.00	0.01	0.05	0.11	0.17	0.24	0.30	0.34	0.37	0.37	0.34	0.30	0.24	0.17	0.10	0.05	0.01	0.00	3.18	3.17
-50	0.00	0.01	0.04	0.08	0.13	0.18	0.23	0.26	0.28	0.28	0.26	0.23	0.18	0.13	0.08	0.04	0.01	0.00	2.42	2.39
-60	0.00	0.01	0.02	0.05	0.08	0.12	0.15	0.18	0.19	0.19	0.17	0.15	0.12	0.08	0.05	0.02	0.01	0.00	1.59	1.54
-70	0.00	0.00	0.01	0.02	0.04	0.06	0.07	0.09	0.09	0.09	0.09	0.07	0.05	0.04	0.02	0.01	0.00	0.00	0.76	0.58
-80	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.14	0.00
-90	-90	-80	-70	-60	-50	-40	-30	-20	HORIZONTAL (DEG)			20	30	40	50	60	70	80	90	
F t	0.02	0.25	0.84	1.75	2.84	3.96	4.98	5.75	6.19	6.18	5.73	4.94	3.92	2.79	1.72	0.83	0.25	0.02	53	---
F a	0.00	0.18	0.79	1.69	2.78	3.91	4.93	5.70	6.14	6.13	5.67	4.88	3.86	2.74	1.66	0.78	0.18	0.00	---	52

one-half-peak spread: U:56.1,D:51.2 , L:54.6,R:53.6


NEMA Beam Type: Type 7

H(B) Range:-90 - 90DEG
H(B) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

NAME:ScapeDirect-1000mm-RGB RED-110D-Rev1	TYPE:RGB-RED	WEIGHT:
SPEC.:110 DEG	DIM.:1000 mm	SERIAL No.:IES001538
MFR.:	SUR.:	Shielding Angle:




H(θ) Range:-90 - 90DEG
H(θ) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME:ScapeDirect-1000mm-RGB RED-110D-Rev1	TYPE:RGB-RED	WEIGHT:
SPEC.:110 DEG	DIM.:1000 mm	SERIAL No.:IES001538
MFR.:	SUR.:	Shielding Angle:



H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H(θ) Range:-90 - 90DEG
H(θ) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME:ScapeDirect-1000mm-RGB RED-110D-Rev1	TYPE:RGB-RED	WEIGHT:
SPEC.:110 DEG	DIM.:1000 mm	SERIAL No.:IES001538
MFR.:	SUR.:	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-08-14

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:ScapeDirect-1000mm-RGB RED-110D-Rev1	TYPE:RGB-RED	WEIGHT:
SPEC.:110 DEG	DIM.:1000 mm	SERIAL No.:IES001538
MFR.:	SUR.:	Shielding Angle:

Table--1

UNIT: cd

H (DEG) V (DEG)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	0.26	0.23	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.21
-170	0.26	0.22	0.20	0.20	0.19	0.19	0.18	0.18	0.18	0.17	0.17	0.17	0.17	0.16	0.16	0.17	0.16	0.15	0.19
-160	0.26	0.21	0.19	0.18	0.17	0.16	0.15	0.14	0.13	0.13	0.12	0.12	0.12	0.12	0.12	0.13	0.13	0.14	0.16
-150	0.26	0.21	0.18	0.16	0.15	0.13	0.12	0.10	0.10	0.08	0.07	0.08	0.09	0.08	0.08	0.07	0.10	0.11	0.13
-140	0.26	0.20	0.17	0.15	0.13	0.11	0.08	0.07	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.07	0.08	0.09	0.09
-130	0.26	0.20	0.17	0.13	0.11	0.08	0.06	0.04	0.03	0.03	0.02	0.02	0.02	0.01	0.03	0.04	0.06	0.07	0.07
-120	0.26	0.21	0.16	0.12	0.09	0.06	0.03	0.01	0.01	0.02	0.01	0.01	0.00	0.00	0.01	0.02	0.03	0.04	0.05
-110	0.26	0.20	0.16	0.12	0.08	0.05	0.01	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.02
-100	0.26	0.21	0.16	0.12	0.08	0.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90	0.26	0.21	0.17	0.13	0.09	0.04	0.00	0.00	0.01	0.01	0.01	0.02	0.02	0.02	0.01	0.01	0.01	0.00	0.00
-80	0.26	0.23	0.19	0.19	0.23	0.32	0.43	0.59	0.74	0.89	1.04	1.17	1.30	1.40	1.48	1.54	1.59	1.62	1.63
-70	0.26	0.23	0.27	0.47	0.78	1.16	1.58	2.00	2.41	2.81	3.18	3.52	3.82	4.07	4.29	4.46	4.58	4.65	4.67
-60	0.26	0.24	0.46	0.93	1.54	2.23	2.95	3.65	4.31	4.94	5.53	6.06	6.52	6.93	7.26	7.53	7.72	7.83	7.87
-50	0.26	0.28	0.70	1.45	2.36	3.34	4.31	5.26	6.15	6.98	7.75	8.44	9.07	9.61	10.1	10.4	10.7	10.9	10.9
-40	0.26	0.33	0.96	1.96	3.14	4.36	5.56	6.71	7.78	8.77	9.71	10.6	11.3	12.0	12.6	13.0	13.4	13.6	13.7
-30	0.26	0.38	1.19	2.42	3.80	5.23	6.62	7.94	9.16	10.3	11.3	12.3	13.2	14.0	14.6	15.2	15.6	15.9	16.0
-20	0.26	0.43	1.37	2.76	4.31	5.89	7.42	8.89	10.3	11.5	12.7	13.7	14.6	15.4	16.2	16.8	17.4	17.7	17.9
-10	0.26	0.46	1.48	2.97	4.63	6.31	7.95	9.52	11.0	12.4	13.6	14.7	15.7	16.5	17.2	17.8	18.3	18.8	19.1
0	0.26	0.47	1.52	3.04	4.74	6.47	8.17	9.79	11.3	12.8	14.1	15.2	16.3	17.2	17.9	18.5	18.8	19.1	19.1
10	0.26	0.46	1.48	2.97	4.63	6.33	8.00	9.60	11.1	12.5	13.8	15.0	16.1	17.0	17.7	18.3	18.8	19.1	19.3
20	0.26	0.44	1.36	2.75	4.31	5.92	7.50	9.03	10.5	11.8	13.1	14.2	15.2	16.1	16.8	17.4	17.9	18.2	18.3
30	0.26	0.39	1.18	2.40	3.79	5.26	6.70	8.10	9.43	10.7	11.8	12.9	13.8	14.6	15.3	15.9	16.3	16.5	16.6
40	0.26	0.35	0.95	1.94	3.12	4.37	5.62	6.84	8.01	9.11	10.1	11.1	11.9	12.6	13.2	13.7	14.0	14.2	14.3
50	0.26	0.30	0.71	1.42	2.32	3.31	4.32	5.32	6.28	7.22	8.08	8.85	9.55	10.2	10.6	11.0	11.3	11.4	11.5
60	0.26	0.28	0.48	0.91	1.50	2.17	2.89	3.63	4.36	5.06	5.72	6.31	6.86	7.31	7.67	7.95	8.15	8.27	8.30
70	0.26	0.28	0.33	0.51	0.78	1.13	1.51	1.94	2.38	2.81	3.23	3.62	3.97	4.26	4.50	4.67	4.80	4.88	4.90
80	0.26	0.28	0.28	0.30	0.35	0.43	0.52	0.63	0.77	0.91	1.06	1.21	1.34	1.45	1.53	1.60	1.66	1.69	1.70
90	0.26	0.26	0.27	0.28	0.28	0.29	0.30	0.29	0.29	0.28	0.28	0.27	0.27	0.27	0.28	0.29	0.30	0.30	0.31
100	0.26	0.26	0.26	0.26	0.26	0.27	0.27	0.26	0.25	0.24	0.24	0.22	0.21	0.21	0.22	0.23	0.24	0.24	0.25
110	0.26	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.24	0.23	0.22	0.21	0.21	0.21	0.21	0.22	0.22	0.22	0.23
120	0.26	0.25	0.24	0.24	0.24	0.24	0.24	0.23	0.22	0.22	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21
130	0.26	0.24	0.24	0.23	0.23	0.23	0.23	0.22	0.22	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21
140	0.26	0.23	0.23	0.23	0.23	0.22	0.22	0.22	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21
150	0.26	0.23	0.22	0.22	0.22	0.22	0.22	0.21	0.21	0.21	0.20	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21
160	0.26	0.23	0.22	0.22	0.22	0.22	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21
170	0.26	0.23	0.22	0.22	0.22	0.22	0.22	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21
180	0.26	0.23	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.22	0.21

H_(b) Range:-90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-08-14

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:ScapeDirect-1000mm-RGB RED-110D-Rev1	TYPE:RGB-RED	WEIGHT:
SPEC.:110 DEG	DIM.:1000 mm	SERIAL No.:IES001538
MFR.:	SUR.:	Shielding Angle:

Table--2

UNIT: cd

H(°) V(°)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-180	0.16	0.15	0.14	0.14	0.12	0.09	0.08	0.06	0.06	0.05	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	
-170	0.15	0.16	0.16	0.15	0.13	0.11	0.09	0.08	0.07	0.05	0.03	0.01	0.00	0.00	0.00	0.00	0.00	0.00	
-160	0.15	0.14	0.13	0.12	0.12	0.11	0.09	0.08	0.07	0.05	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00	
-150	0.12	0.09	0.07	0.07	0.08	0.08	0.08	0.07	0.06	0.04	0.03	0.02	0.01	0.01	0.00	0.00	0.00	0.00	
-140	0.09	0.08	0.07	0.06	0.06	0.05	0.06	0.05	0.05	0.04	0.03	0.02	0.01	0.00	0.00	0.00	0.00	0.00	
-130	0.06	0.06	0.05	0.03	0.02	0.03	0.03	0.02	0.03	0.03	0.03	0.01	0.01	0.00	0.00	0.00	0.00	0.00	
-120	0.04	0.03	0.02	0.01	0.00	0.00	0.01	0.01	0.02	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	
-110	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.01	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
-100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
-80	1.60	1.55	1.48	1.40	1.30	1.18	1.07	0.95	0.82	0.68	0.54	0.40	0.27	0.16	0.08	0.02	0.00	0.00	
-70	4.63	4.54	4.40	4.20	3.97	3.70	3.41	3.09	2.73	2.35	1.95	1.54	1.13	0.75	0.42	0.17	0.02	0.00	
-60	7.82	7.68	7.48	7.19	6.84	6.43	5.98	5.46	4.88	4.26	3.61	2.92	2.21	1.53	0.91	0.40	0.07	0.00	
-50	10.8	10.7	10.4	10.0	9.55	9.02	8.41	7.72	6.96	6.12	5.23	4.28	3.33	2.36	1.46	0.68	0.14	0.00	
-40	13.6	13.4	13.0	12.6	12.0	11.3	10.6	9.72	8.79	7.78	6.68	5.53	4.33	3.14	1.99	0.96	0.22	0.00	
-30	15.9	15.7	15.2	14.7	14.0	13.3	12.4	11.4	10.3	9.12	7.87	6.55	5.18	3.79	2.44	1.21	0.30	0.00	
-20	17.7	17.4	16.9	16.3	15.6	14.7	13.7	12.6	11.4	10.1	8.75	7.31	5.81	4.28	2.78	1.40	0.36	0.00	
-10	18.9	18.5	17.9	17.3	16.5	15.5	14.5	13.3	12.1	10.7	9.30	7.78	6.21	4.59	3.00	1.53	0.40	0.00	
0	19.0	18.7	18.2	17.5	16.7	15.8	14.8	13.6	12.3	10.9	9.48	7.94	6.34	4.69	3.07	1.57	0.41	0.00	
10	19.0	18.7	18.2	17.6	16.8	15.8	14.7	13.5	12.2	10.8	9.36	7.81	6.22	4.59	2.99	1.52	0.40	0.00	
20	18.1	17.8	17.3	16.8	16.0	15.2	14.1	12.9	11.6	10.3	8.85	7.37	5.83	4.27	2.77	1.40	0.37	0.00	
30	16.4	16.2	15.8	15.2	14.5	13.7	12.8	11.8	10.6	9.32	7.99	6.60	5.19	3.78	2.41	1.20	0.31	0.00	
40	14.2	13.9	13.6	13.1	12.5	11.8	11.0	10.1	9.05	7.94	6.77	5.55	4.32	3.10	1.95	0.96	0.24	0.00	
50	11.4	11.2	10.9	10.5	10.0	9.44	8.76	7.99	7.14	6.21	5.26	4.26	3.27	2.31	1.43	0.69	0.17	0.00	
60	8.24	8.10	7.88	7.57	7.18	6.73	6.20	5.61	4.97	4.28	3.56	2.84	2.15	1.49	0.91	0.43	0.10	0.00	
70	4.85	4.75	4.60	4.40	4.14	3.83	3.50	3.13	2.73	2.30	1.88	1.46	1.10	0.76	0.46	0.23	0.06	0.00	
80	1.67	1.62	1.55	1.46	1.36	1.24	1.12	0.99	0.85	0.72	0.60	0.50	0.40	0.30	0.20	0.12	0.05	0.00	
90	0.30	0.30	0.29	0.28	0.28	0.27	0.27	0.28	0.28	0.29	0.29	0.30	0.25	0.20	0.15	0.10	0.05	0.00	
100	0.24	0.24	0.23	0.23	0.22	0.21	0.22	0.23	0.24	0.25	0.26	0.27	0.23	0.18	0.14	0.10	0.05	0.00	
110	0.22	0.22	0.22	0.22	0.21	0.21	0.22	0.22	0.23	0.23	0.24	0.24	0.20	0.17	0.13	0.09	0.05	0.00	
120	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.22	0.22	0.23	0.23	0.21	0.18	0.15	0.11	0.08	0.04	0.00	
130	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.22	0.22	0.21	0.18	0.15	0.13	0.10	0.07	0.04	0.00	
140	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.20	0.17	0.15	0.13	0.10	0.08	0.06	0.03	0.00	
150	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.19	0.17	0.14	0.12	0.10	0.08	0.06	0.04	0.02	0.00	
160	0.21	0.21	0.21	0.21	0.21	0.21	0.19	0.17	0.16	0.13	0.11	0.08	0.07	0.05	0.04	0.03	0.02	0.00	
170	0.21	0.21	0.21	0.20	0.18	0.15	0.14	0.12	0.11	0.09	0.06	0.04	0.03	0.03	0.02	0.01	0.01	0.00	
180	0.16	0.15	0.14	0.14	0.12	0.09	0.08	0.06	0.06	0.05	0.02	0.01	0.00	0.00	0.00	0.00	0.00	0.00	

H(°) Range:-90 - 90DEG

H(°) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-08-14

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE GO-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks: