

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity (Luminaire orientation as tested.)	2046.8 cd per klm. 0.0 degrees vertical 0.0 degrees horizontal
---	--

Beam Spread	At 10% of Imax	70.1V x 69.6H
	At 50% of Imax	33.1V x 33.0H
	At 90% of Imax	12.5V x 12.4H

Beam Flux	Total	1000.2 lumens per klm.
	To 10% of Imax	786.3 lumens per klm.
	To 50% of Imax	377.4 lumens per klm.
	To 90% of Imax	72.5 lumens per klm.

Upward LOR	2.1 %
Downward LOR	97.9 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-05-18

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME: Medusa-510mm-RGBW 3000K-35D-ReV1	TYPE: RGBW-3000K	WEIGHT:
SPEC.: 35 DEG	DIM.: 510mm	SERIAL No.: IES001036-W
MFR.:	SUR.:	Shielding Angle:



DATA OF LAMP		Eff: 31.07lm/W	
MODEL		Imax(cd)	470.6
NOMINAL POWER(W)	7.4	AVAILABILITY(%)	78.4
RATED VOLTAGE(V)	48	Avai. FLUX(lm)	180.4
NOMINAL FLUX(lm)	229.9	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	229.9
TEST VOLTAGE(V)	48	q @50%(H,V)	33,33DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT: lm		F t	F a
	0.01	0.02	0.03	0.04	0.05	0.06	0.07	0.08	0.08	0.08	0.08	0.07	0.06	0.05	0.04	0.03	0.02	0.01	0.88	0.00
72	0.01	0.02	0.04	0.06	0.08	0.10	0.12	0.13	0.14	0.14	0.13	0.11	0.09	0.07	0.05	0.04	0.02	0.01	1.36	0.00
64	0.01	0.03	0.05	0.08	0.11	0.15	0.18	0.21	0.23	0.23	0.21	0.18	0.14	0.11	0.08	0.05	0.03	0.01	2.09	0.00
56	0.02	0.04	0.07	0.11	0.16	0.23	0.30	0.36	0.40	0.40	0.36	0.29	0.22	0.15	0.10	0.06	0.03	0.01	3.32	0.00
48	0.02	0.04	0.08	0.14	0.23	0.35	0.51	0.66	0.76	0.76	0.65	0.50	0.34	0.22	0.14	0.08	0.04	0.01	5.53	0.44
40	0.02	0.05	0.10	0.19	0.32	0.55	0.88	1.25	1.50	1.49	1.23	0.86	0.54	0.31	0.17	0.09	0.04	0.02	9.63	6.34
32	0.02	0.06	0.12	0.23	0.44	0.83	1.49	2.33	2.98	2.97	2.30	1.45	0.81	0.43	0.22	0.11	0.05	0.02	16.9	14.4
24	0.02	0.06	0.14	0.28	0.57	1.17	2.28	3.93	5.36	5.37	3.91	2.26	1.15	0.55	0.25	0.12	0.05	0.02	27.5	25.4
	0.02	0.07	0.15	0.31	0.66	1.42	2.96	5.40	7.70	7.79	5.56	3.09	1.45	0.63	0.28	0.12	0.05	0.02	37.7	35.8
	0.02	0.07	0.15	0.31	0.68	1.50	3.19	5.97	8.41	8.28	5.98	3.26	1.50	0.65	0.28	0.12	0.05	0.02	40.4	38.6
	0.02	0.06	0.14	0.29	0.62	1.35	2.78	4.84	6.49	6.34	4.60	2.62	1.27	0.57	0.26	0.12	0.05	0.02	32.4	30.5
	0.02	0.06	0.12	0.24	0.49	1.00	1.86	2.99	3.82	3.74	2.81	1.72	0.91	0.45	0.21	0.10	0.05	0.01	20.6	18.5
-24	0.02	0.05	0.10	0.18	0.35	0.64	1.07	1.58	1.93	1.90	1.50	1.00	0.59	0.32	0.17	0.09	0.04	0.01	11.5	8.74
-32	0.02	0.04	0.07	0.13	0.23	0.38	0.59	0.79	0.93	0.92	0.76	0.55	0.36	0.22	0.12	0.07	0.03	0.01	6.22	1.55
-40	0.01	0.03	0.06	0.09	0.15	0.23	0.32	0.40	0.46	0.45	0.39	0.30	0.22	0.14	0.09	0.05	0.03	0.01	3.43	0.00
-48	0.01	0.02	0.04	0.07	0.10	0.14	0.18	0.21	0.24	0.23	0.21	0.17	0.13	0.09	0.06	0.04	0.02	0.01	1.97	0.00
-56	0.01	0.02	0.03	0.05	0.06	0.08	0.10	0.12	0.13	0.13	0.12	0.10	0.08	0.06	0.04	0.03	0.02	0.01	1.18	0.00
-64	0.01	0.01	0.02	0.03	0.04	0.05	0.06	0.07	0.07	0.07	0.07	0.06	0.05	0.04	0.03	0.02	0.01	0.00	0.71	0.00
-72	-72	-64	-56	-48	-40	-32	-24	-16	HORIZONTAL (DEG)	16	24	32	40	48	56	64	72			
F t	0.30	0.75	1.51	2.82	5.34	10.2	18.9	31.3	41.6	41.3	30.9	18.6	9.90	5.06	2.59	1.33	0.63	0.22	223	---
F a	0.00	0.00	0.00	0.00	0.75	6.84	16.0	28.5	38.9	38.6	28.1	15.6	6.48	0.53	0.00	0.00	0.00	0.00	---	180


one-half-peak spread: U:16.7,D:16.7 , L:16.6, ~~NEVA~~ Beam Type: Type 4 x 5 (H x V)

H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-05-18

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

NAME: Medusa-510mm-RGBW 3000K-35D-ReV1	TYPE: RGBW-3000K	WEIGHT:
SPEC.: 35 DEG	DIM.: 510mm	SERIAL No.: IES001036-W
MFR.:	SUR.:	Shielding Angle:




H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-05-18

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME: Medusa-510mm-RGBW 3000K-35D-ReV1	TYPE: RGBW-3000K	WEIGHT:
SPEC.: 35 DEG	DIM.: 510mm	SERIAL No.: IES001036-W
MFR.:	SUR.:	Shielding Angle:



H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-05-18

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H_b Range: -90 - 90DEG
H_b Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-05-18

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME: Medusa-510mm-RGBW 3000K-35D-Rev1	TYPE: RGBW-3000K	WEIGHT:
SPEC.: 35 DEG	DIM.: 510mm	SERIAL No.: IES001036-W
MFR.:	SUR.:	Shielding Angle:



Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-05-18

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: Medusa-510mm-RGBW 3000K-35D-ReV1	TYPE: RGBW-3000K	WEIGHT:
SPEC.: 35 DEG	DIM.: 510mm	SERIAL No.: IES001036-W
MFR.:	SUR.:	Shielding Angle:

Table--1

UNIT: cd

H(°) \ V(°)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	0.82	0.74	0.72	0.72	0.75	0.80	0.89	1.01	1.16	1.33	1.46	1.58	1.67	1.72	1.72	1.70	1.67	1.65	1.64
-170	0.82	0.73	0.70	0.68	0.69	0.72	0.77	0.85	0.93	1.02	1.10	1.15	1.20	1.22	1.22	1.24	1.33	1.39	1.46
-160	0.82	0.72	0.67	0.65	0.63	0.64	0.65	0.67	0.69	0.71	0.72	0.71	0.72	0.83	0.95	1.04	1.12	1.19	1.22
-150	0.82	0.72	0.65	0.61	0.58	0.56	0.54	0.52	0.49	0.44	0.40	0.46	0.54	0.61	0.70	0.76	0.82	0.88	0.91
-140	0.82	0.71	0.63	0.58	0.54	0.49	0.46	0.40	0.35	0.32	0.33	0.35	0.38	0.42	0.45	0.50	0.54	0.57	0.59
-130	0.82	0.70	0.62	0.55	0.50	0.45	0.39	0.33	0.30	0.30	0.30	0.30	0.30	0.30	0.31	0.34	0.35	0.36	0.37
-120	0.82	0.71	0.60	0.53	0.47	0.41	0.35	0.31	0.30	0.30	0.29	0.29	0.29	0.29	0.28	0.29	0.29	0.29	0.30
-110	0.82	0.71	0.61	0.52	0.44	0.37	0.31	0.29	0.29	0.29	0.28	0.28	0.28	0.28	0.28	0.28	0.29	0.29	0.29
-100	0.82	0.71	0.62	0.52	0.43	0.34	0.27	0.26	0.26	0.26	0.25	0.25	0.24	0.24	0.25	0.26	0.26	0.27	0.27
-90	0.82	0.72	0.62	0.53	0.43	0.34	0.24	0.25	0.26	0.27	0.28	0.29	0.29	0.29	0.28	0.27	0.27	0.26	0.25
-80	0.82	0.74	0.67	0.62	0.60	0.60	0.61	0.71	0.80	0.89	0.98	1.06	1.13	1.18	1.23	1.27	1.29	1.31	1.31
-70	0.82	0.76	0.74	0.78	0.87	1.01	1.20	1.41	1.63	1.84	2.06	2.27	2.48	2.66	2.82	2.95	3.06	3.14	3.17
-60	0.82	0.79	0.83	0.95	1.15	1.42	1.79	2.25	2.68	3.15	3.63	4.13	4.64	5.11	5.56	5.96	6.27	6.50	6.61
-50	0.82	0.82	0.91	1.10	1.38	1.80	2.53	3.29	4.06	4.94	5.95	7.12	8.38	9.72	11.0	12.2	13.2	13.9	14.2
-40	0.82	0.85	0.98	1.21	1.57	2.42	3.45	4.57	5.88	7.51	9.62	12.3	15.5	19.2	23.2	27.0	30.2	32.4	33.2
-30	0.82	0.88	1.03	1.27	1.83	3.03	4.43	6.26	8.39	11.2	15.2	20.9	28.6	38.2	49.6	61.8	72.8	80.8	83.7
-20	0.82	0.90	1.07	1.30	2.17	3.63	5.67	8.14	11.1	15.5	22.4	32.9	48.9	71.1	100	135	169	193	201
-10	0.82	0.91	1.07	1.28	2.35	4.02	6.43	9.47	13.2	19.1	28.4	43.4	67.6	105	161	233	309	367	387
0	0.82	0.92	1.06	1.23	2.40	4.10	6.99	10.2	14.3	20.5	30.2	45.7	70.4	109	167	246	341	421	458
10	0.82	0.93	1.11	1.35	2.45	4.16	6.60	9.66	13.3	18.8	27.3	40.3	60.5	90.8	135	192	254	308	327
20	0.82	0.93	1.14	1.43	2.36	3.89	6.02	8.52	11.4	15.4	21.3	29.7	41.6	58.3	80.1	106	131	150	157
30	0.82	0.92	1.13	1.45	2.10	3.40	4.93	6.85	9.04	11.6	15.0	19.7	25.6	32.9	41.3	50.3	58.1	63.5	65.1
40	0.82	0.91	1.11	1.42	1.90	2.87	4.03	5.32	6.74	8.33	10.2	12.5	15.1	18.0	21.0	23.8	26.1	27.6	28.1
50	0.82	0.89	1.06	1.34	1.74	2.30	3.17	4.08	4.94	5.83	6.80	7.86	8.98	10.1	11.2	12.1	12.8	13.2	13.4
60	0.82	0.87	0.99	1.20	1.51	1.92	2.45	3.03	3.47	3.93	4.41	4.91	5.41	5.87	6.25	6.58	6.82	6.97	7.01
70	0.82	0.86	0.92	1.04	1.22	1.48	1.79	2.06	2.28	2.51	2.73	2.94	3.14	3.32	3.47	3.58	3.67	3.72	3.73
80	0.82	0.85	0.87	0.91	0.97	1.05	1.15	1.23	1.32	1.40	1.48	1.54	1.60	1.66	1.71	1.75	1.78	1.79	1.79
90	0.82	0.82	0.83	0.84	0.85	0.86	0.87	0.86	0.85	0.84	0.83	0.82	0.81	0.82	0.82	0.83	0.84	0.85	0.85
100	0.82	0.81	0.81	0.80	0.80	0.80	0.80	0.78	0.76	0.75	0.74	0.73	0.73	0.73	0.73	0.73	0.73	0.73	0.73
110	0.82	0.81	0.78	0.77	0.76	0.76	0.75	0.74	0.74	0.73	0.73	0.73	0.73	0.73	0.74	0.73	0.73	0.73	0.72
120	0.82	0.79	0.76	0.74	0.74	0.74	0.73	0.73	0.73	0.74	0.75	0.78	0.81	0.84	0.85	0.86	0.87	0.87	0.87
130	0.82	0.78	0.75	0.73	0.73	0.73	0.73	0.73	0.75	0.81	0.87	0.93	1.00	1.06	1.11	1.14	1.17	1.18	1.18
140	0.82	0.77	0.73	0.73	0.73	0.73	0.74	0.78	0.85	0.93	1.03	1.13	1.23	1.33	1.42	1.46	1.49	1.51	1.51
150	0.82	0.76	0.73	0.73	0.73	0.75	0.79	0.87	0.96	1.07	1.20	1.32	1.44	1.54	1.63	1.69	1.72	1.73	1.73
160	0.82	0.75	0.72	0.72	0.73	0.77	0.84	0.94	1.06	1.21	1.35	1.46	1.56	1.65	1.72	1.76	1.79	1.79	1.81
170	0.82	0.75	0.72	0.72	0.74	0.79	0.87	0.99	1.14	1.29	1.43	1.55	1.64	1.70	1.72	1.72	1.72	1.72	1.78
180	0.82	0.74	0.72	0.72	0.75	0.80	0.89	1.01	1.16	1.33	1.46	1.58	1.67	1.72	1.72	1.70	1.67	1.65	1.66

H_(b) Range: -90 - 90DEG
 H_(b) Interval: 0.5DEG
 Test Speed: LOW
 Temperature: 25.3DEG
 Operators: Fan
 Test Date: 2023-05-18

V(B) Range: -180 - 180DEG
 V(B) Interval: 0.5DEG
 Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
 Humidity: 65.0%
 Test Distance: 8.630m [K=1.0000]
 Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: Medusa-510mm-RGBW 3000K-35D-ReV1	TYPE: RGBW-3000K	WEIGHT:
SPEC.: 35 DEG	DIM.: 510mm	SERIAL No.: IES001036-W
MFR.:	SUR.:	Shielding Angle:

Table--2

UNIT: cd

H(°) \ V(°)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90
-180	1.49	1.38	1.28	1.14	1.01	0.86	0.69	0.55	0.44	0.35	0.29	0.27	0.27	0.27	0.25	0.23	0.21	0.15
-170	1.38	1.33	1.25	1.13	0.99	0.84	0.68	0.55	0.44	0.35	0.29	0.28	0.28	0.27	0.26	0.24	0.21	0.15
-160	1.19	1.11	1.04	0.95	0.84	0.73	0.61	0.50	0.41	0.34	0.30	0.29	0.28	0.27	0.25	0.24	0.21	0.15
-150	0.88	0.83	0.77	0.70	0.63	0.56	0.49	0.43	0.37	0.32	0.30	0.29	0.29	0.28	0.25	0.24	0.21	0.15
-140	0.57	0.54	0.51	0.46	0.42	0.39	0.37	0.34	0.33	0.31	0.30	0.29	0.29	0.28	0.25	0.23	0.21	0.15
-130	0.36	0.35	0.34	0.31	0.30	0.29	0.30	0.30	0.30	0.30	0.31	0.29	0.29	0.27	0.25	0.23	0.21	0.15
-120	0.29	0.29	0.29	0.28	0.28	0.28	0.28	0.29	0.29	0.29	0.30	0.29	0.28	0.26	0.24	0.22	0.20	0.15
-110	0.28	0.28	0.28	0.27	0.27	0.27	0.27	0.28	0.28	0.29	0.28	0.28	0.27	0.25	0.23	0.22	0.19	0.15
-100	0.27	0.26	0.25	0.25	0.24	0.23	0.24	0.25	0.25	0.26	0.26	0.26	0.25	0.23	0.22	0.20	0.17	0.15
-90	0.25	0.26	0.26	0.26	0.26	0.27	0.26	0.25	0.25	0.24	0.24	0.23	0.22	0.20	0.19	0.18	0.17	0.15
-80	1.29	1.26	1.23	1.18	1.13	1.07	0.99	0.90	0.81	0.72	0.63	0.54	0.40	0.31	0.23	0.19	0.16	0.15
-70	3.11	3.02	2.89	2.73	2.56	2.37	2.16	1.94	1.73	1.51	1.30	1.04	0.74	0.50	0.33	0.23	0.17	0.15
-60	6.45	6.18	5.82	5.39	4.91	4.42	3.93	3.43	2.95	2.51	2.10	1.55	1.06	0.69	0.42	0.26	0.17	0.15
-50	13.7	12.9	11.9	10.6	9.28	7.99	6.75	5.63	4.65	3.80	3.01	2.19	1.42	0.82	0.49	0.27	0.18	0.15
-40	31.9	29.3	25.8	21.9	18.0	14.6	11.5	9.01	7.03	5.46	4.10	2.91	1.91	0.98	0.51	0.28	0.18	0.15
-30	79.2	70.0	58.3	46.3	35.4	26.4	19.3	14.0	10.2	7.49	5.53	3.77	2.43	1.23	0.48	0.26	0.17	0.15
-20	188	160	126	92.7	65.2	44.5	30.1	20.3	13.8	9.58	6.77	4.56	2.82	1.44	0.41	0.23	0.16	0.15
-10	355	296	221	153	100	63.9	40.4	25.9	16.8	11.2	7.68	5.36	3.07	1.54	0.37	0.18	0.15	0.15
0	435	362	267	181	115	71.7	44.3	27.8	17.8	11.7	7.99	5.53	3.17	1.53	0.27	0.13	0.14	0.15
10	310	254	189	134	90.4	59.5	38.7	25.4	16.9	11.4	7.92	5.56	3.22	1.65	0.44	0.22	0.17	0.15
20	150	130	104	78.2	56.7	40.4	28.5	20.0	14.1	10.1	7.22	4.94	3.11	1.65	0.54	0.30	0.20	0.15
30	63.0	57.2	49.1	40.3	32.0	24.8	19.0	14.5	11.0	8.26	6.20	4.31	2.83	1.52	0.67	0.37	0.22	0.15
40	27.5	25.8	23.4	20.5	17.5	14.6	12.1	9.88	8.02	6.43	4.92	3.55	2.40	1.33	0.74	0.41	0.24	0.15
50	13.2	12.7	11.9	10.9	9.82	8.72	7.61	6.57	5.62	4.76	3.88	2.89	1.95	1.20	0.74	0.42	0.26	0.15
60	6.93	6.75	6.48	6.12	5.72	5.25	4.76	4.27	3.80	3.35	2.92	2.24	1.58	1.07	0.68	0.42	0.26	0.15
70	3.70	3.63	3.53	3.40	3.24	3.06	2.86	2.65	2.43	2.20	1.98	1.66	1.23	0.87	0.60	0.41	0.27	0.15
80	1.78	1.75	1.72	1.67	1.61	1.55	1.49	1.42	1.34	1.26	1.18	1.09	0.88	0.70	0.54	0.40	0.27	0.15
90	0.85	0.84	0.84	0.83	0.83	0.82	0.83	0.84	0.85	0.86	0.87	0.88	0.76	0.64	0.52	0.40	0.27	0.15
100	0.74	0.74	0.74	0.74	0.74	0.74	0.75	0.76	0.76	0.78	0.79	0.80	0.71	0.61	0.51	0.40	0.28	0.15
110	0.73	0.74	0.74	0.75	0.75	0.75	0.75	0.74	0.75	0.75	0.76	0.74	0.66	0.58	0.49	0.40	0.28	0.15
120	0.88	0.88	0.88	0.88	0.86	0.83	0.81	0.78	0.76	0.75	0.75	0.70	0.62	0.55	0.47	0.38	0.28	0.15
130	1.19	1.19	1.17	1.14	1.10	1.03	0.97	0.90	0.85	0.79	0.73	0.65	0.58	0.50	0.44	0.36	0.28	0.15
140	1.52	1.52	1.50	1.46	1.38	1.29	1.18	1.08	0.98	0.85	0.71	0.61	0.54	0.47	0.41	0.34	0.27	0.15
150	1.75	1.75	1.74	1.68	1.60	1.50	1.38	1.25	1.03	0.83	0.67	0.56	0.48	0.43	0.37	0.32	0.25	0.15
160	1.80	1.80	1.79	1.76	1.70	1.62	1.39	1.15	0.92	0.74	0.59	0.49	0.42	0.38	0.33	0.30	0.24	0.15
170	1.74	1.77	1.77	1.67	1.49	1.30	1.10	0.90	0.72	0.57	0.45	0.39	0.35	0.32	0.30	0.27	0.22	0.15
180	1.49	1.38	1.28	1.14	1.01	0.86	0.69	0.55	0.44	0.35	0.29	0.27	0.27	0.27	0.25	0.23	0.21	0.15

H_b Range: -90 - 90DEGH_b Interval: 0.5DEG

Test Speed: LOW

Temperature: 25.3DEG

Operators: Fan

Test Date: 2023-05-18

V(B) Range: -180 - 180DEG

V(B) Interval: 0.5DEG

Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity: 65.0%

Test Distance: 8.630m [K=1.0000]

Remarks: