

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity (Luminaire orientation as tested.)	4350.4 cd per klm. 0.0 degrees vertical 0.0 degrees horizontal
---	--

Beam Spread	At 10% of Imax	47.0V x 46.4H
	At 50% of Imax	19.6V x 19.5H
	At 90% of Imax	6.8V x 6.9H

Beam Flux	Total	1000.2 lumens per klm.
	To 10% of Imax	676.7 lumens per klm.
	To 50% of Imax	274.2 lumens per klm.
	To 90% of Imax	41.4 lumens per klm.

Upward LOR	2.2 %
Downward LOR	97.8 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-10-12

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME:Blazeline Max-598mm-RGBW GREEN-20D-Rev1	TYPE:RGBW-GREEN	WEIGHT:
SPEC.:20 DEG	DIM.:598MM	SERIAL No.:IES001866
MFR.:	SUR.:	Shielding Angle:



DATA OF LAMP		Eff:60.91lm/W	
MODEL		Imax(cd)	1847
NOMINAL POWER(W)	6.96	AVAILABILITY(%)	67.6
RATED VOLTAGE(V)	220	Avai. FLUX(lm)	287.1
NOMINAL FLUX(lm)	424.5	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	424.5
TEST VOLTAGE(V)	221.4	q @50%(H,V)	20,20DEG

		AREA FLUX DIAGRAM															UNIT:lm				F t	F a
VERTICAL (DEG)	45	0.09	0.12	0.15	0.19	0.24	0.28	0.31	0.33	0.33	0.32	0.30	0.27	0.23	0.19	0.16	0.12	0.10	0.07	3.79	0.00	
	40	0.11	0.15	0.20	0.26	0.32	0.39	0.44	0.47	0.48	0.47	0.43	0.37	0.31	0.25	0.20	0.16	0.12	0.09	5.20	0.00	
	35	0.13	0.18	0.25	0.33	0.44	0.55	0.64	0.70	0.72	0.69	0.62	0.53	0.43	0.34	0.26	0.19	0.14	0.10	7.22	0.00	
	30	0.15	0.22	0.31	0.43	0.59	0.77	0.94	1.06	1.11	1.06	0.93	0.76	0.59	0.44	0.32	0.23	0.16	0.11	10.2	0.00	
	25	0.17	0.26	0.38	0.55	0.78	1.07	1.41	1.67	1.78	1.69	1.43	1.10	0.81	0.57	0.40	0.28	0.19	0.13	14.7	6.60	
	20	0.20	0.30	0.45	0.68	1.01	1.48	2.12	2.74	3.01	2.84	2.29	1.64	1.11	0.73	0.48	0.32	0.21	0.14	21.8	15.8	
	15	0.21	0.33	0.51	0.80	1.26	1.99	3.11	4.53	5.34	4.98	3.74	2.42	1.48	0.92	0.57	0.36	0.23	0.14	32.9	27.8	
	10	0.22	0.35	0.55	0.88	1.45	2.46	4.24	6.92	9.18	8.50	5.77	3.36	1.93	1.12	0.65	0.39	0.24	0.15	48.4	43.8	
	5	0.23	0.36	0.57	0.91	1.52	2.70	4.93	8.75	12.7	11.7	7.85	4.47	2.36	1.26	0.69	0.40	0.24	0.15	61.7	57.3	
	0	0.22	0.35	0.54	0.88	1.47	2.63	4.88	8.73	12.1	11.6	8.16	4.62	2.40	1.26	0.68	0.39	0.23	0.14	61.3	56.9	
	-5	0.20	0.32	0.49	0.78	1.30	2.27	4.01	6.42	8.28	7.99	5.90	3.61	2.00	1.10	0.62	0.36	0.22	0.14	46.0	41.4	
	-10	0.18	0.28	0.42	0.65	1.03	1.68	2.63	3.76	4.66	4.58	3.55	2.39	1.46	0.87	0.52	0.32	0.20	0.13	29.3	24.2	
	-15	0.16	0.23	0.34	0.51	0.76	1.14	1.61	2.12	2.49	2.45	2.02	1.48	1.00	0.64	0.41	0.26	0.17	0.11	17.9	11.6	
	-20	0.13	0.19	0.27	0.39	0.55	0.75	0.98	1.22	1.35	1.33	1.16	0.90	0.66	0.46	0.32	0.22	0.15	0.10	11.1	1.74	
	-25	0.11	0.15	0.21	0.29	0.39	0.50	0.61	0.72	0.78	0.77	0.69	0.57	0.44	0.33	0.24	0.17	0.12	0.08	7.17	0.00	
	-30	0.09	0.12	0.16	0.22	0.27	0.34	0.40	0.45	0.48	0.47	0.43	0.37	0.30	0.24	0.18	0.14	0.10	0.07	4.82	0.00	
-35	0.07	0.10	0.13	0.16	0.20	0.23	0.27	0.29	0.31	0.30	0.28	0.25	0.21	0.17	0.14	0.11	0.08	0.06	3.35	0.00		
-40	0.06	0.08	0.10	0.12	0.14	0.17	0.19	0.20	0.21	0.20	0.19	0.17	0.15	0.13	0.10	0.08	0.06	0.05	2.39	0.00		
-45	-45	-40	-35	-30	-25	-20	-15	-10	HORIZONTAL (DEG)			10	15	20	25	30	35	40	45			
F t	2.74	4.07	6.05	9.03	13.7	21.4	33.7	51.1	65.3	62.0	45.7	29.3	17.9	11.0	6.93	4.47	2.94	1.95	389	---		
F a	0.00	0.00	0.00	0.00	4.92	15.0	28.1	45.8	60.1	56.8	40.3	23.4	11.0	1.64	0.00	0.00	0.00	0.00	---	287		

one-half-peak spread: U:10.0,D:9.7 , L:9.9,R:9.8


NEMA Beam Type: Type 4

H_(b) Range: -90 - 90DEG
 H_(b) Interval: 0.5DEG
 Test Speed: LOW
 Temperature: 25.3DEG
 Operators: Fan
 Test Date: 2023-10-12

V(B) Range: -180 - 180DEG
 V(B) Interval: 0.5DEG
 Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
 Humidity: 65.0%
 Test Distance: 8.630m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

NAME:Blazeline Max-598mm-RGBW GREEN-20D-Rev1	TYPE:RGBW-GREEN	WEIGHT:
SPEC.:20 DEG	DIM.:598MM	SERIAL No.:IES001866
MFR.:	SUR.:	Shielding Angle:




H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-10-12

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME:Blazeline Max-598mm-RGBW GREEN-20D-Rev1	TYPE:RGBW-GREEN	WEIGHT:
SPEC.:20 DEG	DIM.:598MM	SERIAL No.:IES001866
MFR.:	SUR.:	Shielding Angle:



H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-10-12

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-10-12

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME:Blazeline Max-598mm-RGBW GREEN-20D-Rev1	TYPE:RGBW-GREEN	WEIGHT:
SPEC.:20 DEG	DIM.:598MM	SERIAL No.:IES001866
MFR.:	SUR.:	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-10-12

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:Blazeline Max-598mm-RGBW GREEN-20D-Rev1	TYPE:RGBW-GREEN	WEIGHT:
SPEC.:20 DEG	DIM.:598MM	SERIAL No.:IES001866
MFR.:	SUR.:	Shielding Angle:

Table--1

UNIT: cd

H(°) \ V(°)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	1.57	1.41	1.30	1.27	1.28	1.36	1.51	1.77	2.16	2.59	2.98	3.22	3.31	3.31	3.31	3.30	3.28	3.23	3.38
-170	1.57	1.39	1.26	1.21	1.19	1.22	1.30	1.45	1.68	1.94	2.17	2.31	2.39	2.43	2.48	2.59	2.83	3.05	3.24
-160	1.57	1.37	1.23	1.15	1.11	1.09	1.09	1.12	1.18	1.26	1.31	1.34	1.37	1.68	2.00	2.30	2.56	2.75	2.88
-150	1.57	1.36	1.21	1.10	1.04	0.98	0.91	0.86	0.79	0.71	0.64	0.80	0.99	1.22	1.44	1.66	1.85	1.99	2.08
-140	1.57	1.35	1.19	1.06	0.97	0.89	0.80	0.68	0.55	0.50	0.51	0.56	0.63	0.74	0.86	1.00	1.12	1.20	1.26
-130	1.57	1.35	1.18	1.03	0.92	0.83	0.73	0.61	0.54	0.51	0.50	0.49	0.49	0.48	0.51	0.56	0.61	0.65	0.68
-120	1.57	1.35	1.17	1.03	0.89	0.78	0.68	0.60	0.59	0.58	0.58	0.55	0.54	0.51	0.50	0.50	0.50	0.50	0.50
-110	1.57	1.35	1.17	1.01	0.88	0.76	0.63	0.60	0.60	0.61	0.61	0.61	0.61	0.61	0.60	0.59	0.58	0.58	0.57
-100	1.57	1.37	1.18	1.01	0.86	0.71	0.57	0.57	0.58	0.58	0.59	0.58	0.59	0.59	0.60	0.61	0.62	0.62	0.63
-90	1.57	1.38	1.20	1.02	0.84	0.65	0.47	0.47	0.46	0.46	0.46	0.45	0.45	0.46	0.47	0.48	0.50	0.51	0.52
-80	1.57	1.41	1.24	1.05	0.85	0.64	0.41	0.41	0.45	0.50	0.55	0.61	0.66	0.71	0.75	0.79	0.83	0.85	0.87
-70	1.57	1.45	1.30	1.15	1.02	0.92	0.87	1.06	1.34	1.63	1.93	2.23	2.52	2.79	3.05	3.25	3.39	3.48	3.52
-60	1.57	1.48	1.41	1.38	1.47	1.71	2.02	2.41	3.07	3.76	4.47	5.17	5.83	6.43	6.96	7.40	7.70	7.87	7.90
-50	1.57	1.54	1.56	1.75	2.20	2.85	3.56	4.28	5.27	6.50	7.84	9.23	10.6	12.0	13.2	14.3	15.1	15.6	15.7
-40	1.57	1.60	1.75	2.23	3.10	4.17	5.38	6.67	8.08	10.1	12.7	15.6	18.7	22.0	25.2	28.4	30.9	32.4	32.6
-30	1.57	1.66	1.97	2.74	4.02	5.56	7.34	9.43	12.0	15.4	19.6	25.5	32.7	41.2	50.7	60.7	70.4	77.3	79.1
-20	1.57	1.72	2.17	3.26	4.87	6.89	9.31	12.4	16.5	22.2	29.9	40.4	55.1	77.2	107	147	189	226	238
-10	1.57	1.77	2.34	3.66	5.56	7.96	11.0	15.1	20.7	28.9	40.9	58.7	86.2	131	209	349	545	753	853
0	1.57	1.82	2.47	3.92	6.01	8.66	12.1	16.8	23.4	33.4	48.3	70.9	106	165	276	485	885	1485	1816
10	1.57	1.82	2.44	3.84	5.87	8.47	11.8	16.3	22.8	32.5	46.8	68.2	101	154	242	389	617	875	930
20	1.57	1.80	2.37	3.59	5.44	7.83	10.8	14.7	20.0	27.8	38.9	54.7	76.8	107	148	201	260	294	296
30	1.57	1.78	2.25	3.21	4.79	6.78	9.22	12.2	16.2	21.4	28.6	37.9	49.5	63.6	80.5	96.7	109	115	114
40	1.57	1.75	2.09	2.80	4.00	5.53	7.40	9.56	12.1	15.3	19.4	24.1	29.8	36.0	42.3	46.9	50.5	52.2	51.8
50	1.57	1.71	1.96	2.41	3.15	4.22	5.48	6.94	8.59	10.5	12.6	15.0	17.5	20.1	22.2	23.7	24.9	25.5	25.4
60	1.57	1.68	1.84	2.08	2.47	3.02	3.77	4.61	5.56	6.59	7.67	8.81	9.91	11.0	11.8	12.5	12.9	13.1	13.1
70	1.57	1.65	1.74	1.86	2.01	2.23	2.49	2.82	3.22	3.68	4.16	4.61	5.04	5.45	5.80	6.07	6.26	6.36	6.39
80	1.57	1.62	1.67	1.72	1.77	1.83	1.89	1.94	2.01	2.09	2.17	2.26	2.36	2.44	2.51	2.57	2.61	2.64	2.65
90	1.57	1.58	1.60	1.62	1.63	1.65	1.66	1.66	1.65	1.64	1.63	1.63	1.62	1.62	1.62	1.62	1.62	1.62	1.62
100	1.57	1.56	1.54	1.53	1.52	1.50	1.49	1.46	1.42	1.39	1.36	1.34	1.31	1.30	1.30	1.30	1.30	1.30	1.30
110	1.57	1.53	1.49	1.45	1.41	1.38	1.35	1.31	1.27	1.25	1.23	1.23	1.22	1.22	1.22	1.22	1.22	1.22	1.22
120	1.57	1.50	1.44	1.38	1.33	1.29	1.27	1.24	1.23	1.23	1.23	1.24	1.27	1.30	1.32	1.33	1.35	1.36	1.36
130	1.57	1.48	1.40	1.33	1.28	1.26	1.24	1.23	1.24	1.30	1.37	1.46	1.57	1.68	1.80	1.90	1.99	2.05	2.07
140	1.57	1.46	1.36	1.29	1.26	1.25	1.26	1.30	1.38	1.52	1.71	1.94	2.18	2.41	2.62	2.79	2.91	2.99	3.02
150	1.57	1.44	1.34	1.27	1.26	1.27	1.32	1.42	1.61	1.87	2.18	2.51	2.81	3.06	3.25	3.39	3.48	3.52	3.55
160	1.57	1.42	1.31	1.27	1.27	1.29	1.39	1.57	1.86	2.23	2.61	2.93	3.17	3.36	3.52	3.64	3.76	3.83	3.88
170	1.57	1.42	1.30	1.27	1.27	1.33	1.46	1.71	2.06	2.48	2.87	3.15	3.33	3.41	3.48	3.54	3.62	3.69	3.80
180	1.57	1.41	1.30	1.27	1.28	1.36	1.51	1.77	2.16	2.59	2.98	3.22	3.31	3.31	3.31	3.30	3.28	3.23	3.42

H_(b) Range:-90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-10-12

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:Blazeline Max-598mm-RGBW GREEN-20D-Rev1	TYPE:RGBW-GREEN	WEIGHT:
SPEC.:20 DEG	DIM.:598MM	SERIAL No.:IES001866
MFR.:	SUR.:	Shielding Angle:

Table--2

UNIT: cd

H(°) \ V(°)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90
-180	3.02	2.89	2.73	2.50	2.19	1.86	1.52	1.19	0.91	0.63	0.51	0.52	0.56	0.59	0.59	0.59	0.54	0.48
-170	3.14	3.02	2.81	2.53	2.21	1.86	1.50	1.16	0.87	0.63	0.53	0.53	0.56	0.59	0.60	0.59	0.54	0.48
-160	2.81	2.68	2.48	2.22	1.93	1.62	1.30	1.01	0.76	0.60	0.54	0.54	0.57	0.59	0.60	0.59	0.54	0.48
-150	2.06	1.97	1.83	1.64	1.41	1.19	0.98	0.80	0.66	0.57	0.55	0.55	0.58	0.59	0.60	0.59	0.53	0.48
-140	1.24	1.19	1.11	0.99	0.87	0.76	0.67	0.60	0.58	0.56	0.56	0.57	0.59	0.60	0.59	0.58	0.52	0.48
-130	0.67	0.65	0.61	0.57	0.53	0.53	0.54	0.54	0.55	0.56	0.56	0.58	0.60	0.60	0.59	0.57	0.51	0.48
-120	0.50	0.51	0.51	0.51	0.53	0.54	0.56	0.57	0.58	0.59	0.60	0.61	0.60	0.60	0.58	0.56	0.50	0.48
-110	0.57	0.58	0.59	0.61	0.62	0.62	0.62	0.61	0.61	0.61	0.61	0.60	0.60	0.59	0.57	0.53	0.50	0.48
-100	0.62	0.62	0.62	0.61	0.60	0.59	0.60	0.60	0.60	0.60	0.60	0.60	0.58	0.56	0.53	0.51	0.49	0.48
-90	0.51	0.51	0.50	0.50	0.49	0.49	0.49	0.50	0.50	0.51	0.52	0.52	0.52	0.51	0.50	0.50	0.49	0.48
-80	0.86	0.84	0.81	0.78	0.74	0.70	0.66	0.61	0.57	0.52	0.49	0.48	0.48	0.49	0.49	0.49	0.48	0.48
-70	3.45	3.32	3.15	2.93	2.67	2.40	2.14	1.86	1.59	1.34	1.09	0.85	0.67	0.56	0.51	0.49	0.48	0.48
-60	7.74	7.44	7.04	6.53	5.97	5.36	4.72	4.05	3.42	2.81	2.25	1.74	1.28	0.88	0.63	0.51	0.49	0.48
-50	15.2	14.4	13.4	12.1	10.8	9.48	8.17	6.89	5.72	4.63	3.67	2.84	2.07	1.41	0.86	0.57	0.49	0.48
-40	31.4	29.1	26.0	22.5	19.2	16.1	13.1	10.6	8.49	6.73	5.27	4.00	2.92	1.97	1.17	0.67	0.49	0.48
-30	74.8	66.0	55.0	44.3	35.0	27.1	20.7	15.7	11.9	9.11	6.94	5.17	3.71	2.50	1.50	0.77	0.50	0.48
-20	219	177	132	92.5	64.0	44.2	31.0	22.1	15.9	11.5	8.49	6.18	4.38	2.93	1.75	0.86	0.51	0.48
-10	720	502	309	179	107	65.6	42.0	28.1	19.2	13.5	9.64	6.89	4.84	3.22	1.92	0.93	0.52	0.48
0	1451	880	465	245	135	77.3	47.5	30.8	20.7	14.2	10.1	7.19	5.02	3.34	1.98	0.95	0.53	0.48
10	756	492	295	182	113	71.6	46.7	31.4	21.5	15.0	10.7	7.58	5.28	3.50	2.08	1.02	0.56	0.48
20	261	207	153	109	77.3	54.7	38.9	27.7	19.8	14.2	10.3	7.44	5.20	3.45	2.06	1.03	0.59	0.48
30	106	92.3	76.5	61.4	48.1	37.3	28.7	21.9	16.5	12.4	9.28	6.78	4.80	3.20	1.94	1.02	0.61	0.48
40	49.1	44.8	39.7	34.1	28.8	23.9	19.5	15.8	12.8	10.1	7.75	5.77	4.15	2.80	1.69	0.99	0.63	0.48
50	24.5	23.1	21.2	19.2	17.1	14.9	12.8	10.9	9.11	7.50	6.02	4.58	3.34	2.29	1.45	0.93	0.64	0.48
60	12.8	12.3	11.6	10.8	9.90	8.92	7.91	6.92	5.96	5.08	4.26	3.36	2.50	1.78	1.27	0.89	0.66	0.48
70	6.27	6.09	5.83	5.51	5.14	4.74	4.31	3.89	3.49	3.09	2.70	2.31	1.85	1.45	1.13	0.87	0.66	0.48
80	2.62	2.57	2.51	2.44	2.36	2.27	2.18	2.09	2.00	1.92	1.86	1.78	1.53	1.29	1.07	0.86	0.66	0.48
90	1.61	1.60	1.59	1.58	1.56	1.55	1.56	1.56	1.57	1.57	1.57	1.58	1.40	1.21	1.03	0.85	0.66	0.48
100	1.29	1.28	1.28	1.27	1.27	1.28	1.29	1.31	1.34	1.36	1.39	1.41	1.28	1.13	0.98	0.82	0.66	0.48
110	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.22	1.23	1.24	1.27	1.26	1.17	1.07	0.95	0.81	0.65	0.48
120	1.37	1.37	1.36	1.34	1.32	1.30	1.27	1.24	1.23	1.23	1.23	1.17	1.08	1.00	0.91	0.80	0.63	0.48
130	2.08	2.05	1.98	1.89	1.78	1.67	1.56	1.44	1.36	1.28	1.19	1.10	1.01	0.94	0.86	0.77	0.63	0.48
140	3.02	2.99	2.91	2.78	2.59	2.37	2.12	1.88	1.66	1.41	1.18	1.03	0.95	0.87	0.81	0.74	0.62	0.48
150	3.56	3.54	3.50	3.38	3.23	3.02	2.75	2.42	1.89	1.44	1.14	0.96	0.87	0.81	0.76	0.71	0.60	0.48
160	3.87	3.84	3.76	3.65	3.53	3.36	2.89	2.34	1.79	1.32	1.02	0.85	0.78	0.75	0.71	0.67	0.59	0.48
170	3.75	3.74	3.70	3.48	3.14	2.75	2.32	1.88	1.44	1.04	0.81	0.70	0.67	0.67	0.65	0.63	0.57	0.48
180	3.02	2.89	2.73	2.50	2.19	1.86	1.52	1.19	0.91	0.63	0.51	0.52	0.56	0.59	0.59	0.59	0.54	0.48

H_(b) Range: -90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:Fan

Test Date:2023-10-12

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks: