

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	4855.0 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	40.4V x 41.0H
	At 50% of Imax	21.2V x 21.1H
	At 90% of Imax	8.4V x 8.3H

Beam Flux	Total	1000.8 lumens per klm.
	To 10% of Imax	794.5 lumens per klm.
	To 50% of Imax	475.1 lumens per klm.
	To 90% of Imax	163.5 lumens per klm.

Upward LOR	1.7 %
Downward LOR	98.4 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2025-02-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME:Astra D65-65mm-RGBW 6500K-20D-Rev2	TYPE:RGBW-6500K	WEIGHT:
SPEC.:20 DEG	DIA.:65MM	SERIAL No.:IES003426
MFR.:	SUR.:1	Shielding Angle:



DATA OF LAMP		Eff:65.72lm/W	
MODEL		Imax(cd)	765.6
NOMINAL POWER(W)	2.4	AVAILABILITY(%)	79.6
RATED VOLTAGE(V)	24	Avai. FLUX(lm)	125.6
NOMINAL FLUX(lm)	157.7	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	157.7
TEST VOLTAGE(V)	24	q @50%(H,V)	21,21DEG

		AREA FLUX DIAGRAM															UNIT:lm				F t	F a
		0.02	0.02	0.03	0.03	0.04	0.05	0.06	0.06	0.07	0.07	0.08	0.08	0.08	0.07	0.06	0.05	0.04	0.03	0.95	0.00	
VERTICAL (DEG)	27	0.02	0.03	0.03	0.04	0.05	0.07	0.08	0.09	0.10	0.11	0.13	0.14	0.13	0.11	0.09	0.07	0.06	0.04	1.41	0.00	
	24	0.03	0.03	0.04	0.06	0.07	0.09	0.12	0.14	0.15	0.18	0.21	0.22	0.21	0.18	0.15	0.11	0.08	0.06	2.13	0.49	
	21	0.03	0.04	0.05	0.07	0.10	0.13	0.17	0.21	0.24	0.29	0.35	0.37	0.34	0.29	0.22	0.16	0.11	0.08	3.27	2.17	
	18	0.03	0.05	0.07	0.09	0.13	0.19	0.27	0.34	0.40	0.49	0.58	0.59	0.54	0.44	0.33	0.23	0.15	0.10	5.03	4.26	
	15	0.04	0.05	0.08	0.12	0.18	0.27	0.39	0.53	0.65	0.78	0.88	0.89	0.80	0.65	0.47	0.32	0.21	0.13	7.43	6.78	
	12	0.04	0.06	0.09	0.14	0.22	0.35	0.54	0.77	0.99	1.16	1.27	1.24	1.11	0.89	0.64	0.42	0.27	0.16	10.4	9.83	
	9	0.04	0.06	0.10	0.16	0.25	0.41	0.67	1.01	1.35	1.57	1.64	1.60	1.42	1.13	0.81	0.52	0.32	0.19	13.3	12.8	
		0.04	0.06	0.10	0.16	0.26	0.43	0.71	1.10	1.56	1.84	1.94	1.91	1.69	1.35	0.95	0.61	0.37	0.21	15.3	14.9	
		0.05	0.07	0.11	0.18	0.30	0.50	0.81	1.23	1.72	2.00	2.06	2.01	1.76	1.39	0.97	0.62	0.37	0.21	16.4	15.9	
		0.05	0.08	0.13	0.22	0.37	0.61	0.95	1.38	1.83	2.05	2.01	1.88	1.61	1.25	0.87	0.55	0.34	0.19	16.4	16.0	
		0.05	0.08	0.13	0.22	0.38	0.61	0.93	1.31	1.69	1.86	1.80	1.64	1.37	1.04	0.72	0.46	0.29	0.17	14.7	14.3	
		0.05	0.07	0.12	0.20	0.33	0.53	0.80	1.10	1.38	1.50	1.45	1.30	1.06	0.80	0.55	0.36	0.23	0.14	12.0	11.5	
-9	0.04	0.07	0.10	0.16	0.26	0.41	0.60	0.81	0.99	1.08	1.04	0.92	0.75	0.56	0.40	0.27	0.17	0.11	8.74	8.13		
-12	0.04	0.06	0.08	0.13	0.19	0.28	0.40	0.52	0.63	0.68	0.66	0.59	0.49	0.38	0.28	0.19	0.13	0.08	5.81	5.07		
-15	0.03	0.04	0.06	0.09	0.13	0.19	0.25	0.32	0.37	0.40	0.40	0.36	0.31	0.24	0.18	0.13	0.09	0.06	3.68	2.74		
-18	0.03	0.03	0.05	0.07	0.09	0.12	0.16	0.19	0.22	0.23	0.23	0.22	0.19	0.15	0.12	0.09	0.06	0.05	2.30	0.78		
-21	0.02	0.03	0.04	0.05	0.06	0.08	0.10	0.12	0.13	0.14	0.14	0.13	0.11	0.10	0.08	0.06	0.04	0.03	1.45	0.00		
-24	-27	-24	-21	-18	-15	-12	-9	-6	HORIZONTAL (DEG)				6	9	12	15	18	21	24	27		
-27	F t	0.65	0.94	1.41	2.18	3.44	5.33	7.98	11.2	14.5	16.4	16.9	16.1	14.0	11.0	7.90	5.24	3.33	2.04	141	---	
	F a	0.00	0.00	0.00	0.49	2.39	4.56	7.28	10.6	13.9	15.9	16.4	15.6	13.5	10.4	7.23	4.45	2.34	0.59	---	126	

one-half-peak spread: U:10.7,D:10.7 , L:10.6,R:10.6


NEMA Beam Type: Type 3

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2025-02-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

NAME:Astra D65-65mm-RGBW 6500K-20D-Rev2	TYPE:RGBW-6500K	WEIGHT:
SPEC.:20 DEG	DIA.:65MM	SERIAL No.:IES003426
MFR.:	SUR.:1	Shielding Angle:




H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators:
Test Date: 2025-02-06

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME:Astra D65-65mm-RGBW 6500K-20D-Rev2	TYPE:RGBW-6500K	WEIGHT:
SPEC.:20 DEG	DIA.:65MM	SERIAL No.:IES003426
MFR.:	SUR.:1	Shielding Angle:



H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators:
Test Date: 2025-02-06

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H_b Range: -90 - 90DEG
H_b Interval: 0.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators:
Test Date: 2025-02-06

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME:Astra D65-65mm-RGBW 6500K-20D-Rev2	TYPE:RGBW-6500K	WEIGHT:
SPEC.:20 DEG	DIA.:65MM	SERIAL No.:IES003426
MFR.:	SUR.:1	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2025-02-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:Astra D65-65mm-RGBW 6500K-20D-Rev2	TYPE:RGBW-6500K	WEIGHT:
SPEC.:20 DEG	DIA.:65MM	SERIAL No.:IES003426
MFR.:	SUR.:1	Shielding Angle:

Table--1

UNIT: cd

H(°) \ V(°)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	0.35	0.32	0.29	0.29	0.32	0.37	0.50	0.70	0.92	1.08	1.14	1.14	1.14	1.13	1.08	1.00	0.86	0.82	0.86
-170	0.35	0.32	0.29	0.29	0.31	0.35	0.46	0.63	0.81	0.95	1.02	1.02	1.02	1.02	1.02	1.00	0.96	0.92	0.94
-160	0.35	0.32	0.29	0.29	0.29	0.33	0.40	0.52	0.67	0.79	0.86	0.88	0.88	0.88	0.88	0.89	0.89	0.89	0.86
-150	0.35	0.33	0.29	0.28	0.28	0.30	0.33	0.40	0.50	0.60	0.67	0.70	0.71	0.69	0.67	0.65	0.63	0.61	0.56
-140	0.35	0.33	0.28	0.28	0.28	0.28	0.29	0.31	0.35	0.41	0.45	0.48	0.49	0.48	0.45	0.42	0.36	0.30	0.23
-130	0.35	0.34	0.28	0.28	0.27	0.27	0.27	0.27	0.27	0.28	0.29	0.30	0.30	0.28	0.26	0.22	0.17	0.12	0.06
-120	0.35	0.34	0.30	0.28	0.27	0.27	0.26	0.25	0.25	0.24	0.23	0.22	0.20	0.19	0.16	0.14	0.12	0.09	0.06
-110	0.35	0.34	0.33	0.29	0.27	0.26	0.26	0.25	0.25	0.24	0.23	0.22	0.21	0.20	0.19	0.18	0.17	0.16	0.15
-100	0.35	0.34	0.33	0.32	0.31	0.29	0.27	0.25	0.24	0.24	0.23	0.22	0.22	0.21	0.21	0.20	0.19	0.19	0.18
-90	0.35	0.34	0.33	0.32	0.31	0.30	0.28	0.27	0.26	0.25	0.24	0.23	0.22	0.21	0.19	0.18	0.17	0.16	0.15
-80	0.35	0.36	0.35	0.34	0.34	0.33	0.33	0.31	0.30	0.30	0.29	0.28	0.27	0.26	0.25	0.24	0.23	0.21	0.20
-70	0.35	0.36	0.37	0.38	0.37	0.38	0.40	0.42	0.44	0.46	0.48	0.50	0.51	0.52	0.52	0.52	0.51	0.50	0.48
-60	0.35	0.37	0.39	0.40	0.43	0.48	0.53	0.60	0.66	0.72	0.79	0.85	0.91	0.95	0.98	1.01	1.01	1.00	0.97
-50	0.35	0.38	0.40	0.45	0.52	0.60	0.70	0.83	0.95	1.09	1.24	1.38	1.53	1.67	1.80	1.91	1.99	2.02	2.00
-40	0.35	0.39	0.43	0.50	0.60	0.74	0.90	1.10	1.32	1.58	1.87	2.20	2.60	3.05	3.56	4.11	4.63	5.03	5.18
-30	0.35	0.40	0.45	0.55	0.70	0.88	1.12	1.40	1.75	2.18	2.73	3.47	4.50	6.04	8.36	11.7	15.9	20.0	22.5
-20	0.35	0.41	0.47	0.60	0.77	1.01	1.31	1.70	2.18	2.84	3.76	5.22	7.77	12.7	22.3	39.7	67.9	103	130
-10	0.35	0.41	0.48	0.63	0.83	1.10	1.46	1.93	2.53	3.38	4.66	6.91	11.3	20.7	43.0	98.2	219	400	571
0	0.35	0.42	0.49	0.64	0.86	1.15	1.54	2.05	2.71	3.63	5.03	7.28	11.2	18.5	35.0	74.2	164	361	618
10	0.35	0.42	0.49	0.64	0.85	1.14	1.52	2.01	2.64	3.50	4.76	6.82	10.2	16.5	29.1	55.8	112	198	269
20	0.35	0.42	0.49	0.63	0.81	1.07	1.41	1.84	2.37	3.08	4.02	5.39	7.43	10.6	15.5	23.2	33.8	45.1	51.6
30	0.35	0.41	0.47	0.59	0.76	0.97	1.24	1.58	2.00	2.50	3.12	3.89	4.88	6.19	7.76	9.60	11.5	13.2	14.0
40	0.35	0.40	0.46	0.55	0.68	0.84	1.05	1.29	1.59	1.92	2.30	2.72	3.20	3.71	4.26	4.81	5.28	5.65	5.82
50	0.35	0.39	0.44	0.50	0.59	0.71	0.85	1.01	1.20	1.41	1.63	1.87	2.11	2.35	2.57	2.77	2.94	3.06	3.12
60	0.35	0.39	0.43	0.46	0.51	0.59	0.68	0.77	0.87	0.99	1.11	1.23	1.35	1.47	1.57	1.66	1.74	1.79	1.82
70	0.35	0.38	0.40	0.43	0.46	0.49	0.53	0.58	0.63	0.69	0.74	0.80	0.85	0.90	0.94	0.98	1.01	1.03	1.05
80	0.35	0.37	0.38	0.40	0.41	0.43	0.45	0.46	0.48	0.50	0.51	0.53	0.55	0.57	0.58	0.60	0.61	0.62	0.63
90	0.35	0.36	0.36	0.37	0.37	0.38	0.39	0.39	0.40	0.40	0.41	0.41	0.42	0.43	0.43	0.44	0.44	0.45	0.46
100	0.35	0.36	0.36	0.36	0.36	0.35	0.34	0.33	0.33	0.33	0.33	0.33	0.33	0.33	0.34	0.34	0.34	0.34	0.34
110	0.35	0.36	0.36	0.33	0.31	0.31	0.31	0.31	0.31	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30
120	0.35	0.36	0.32	0.30	0.30	0.30	0.30	0.30	0.30	0.31	0.31	0.32	0.33	0.33	0.35	0.36	0.36	0.36	0.35
130	0.35	0.35	0.30	0.30	0.30	0.30	0.30	0.32	0.34	0.37	0.42	0.49	0.54	0.61	0.65	0.69	0.72	0.73	0.72
140	0.35	0.34	0.30	0.30	0.29	0.30	0.33	0.37	0.44	0.55	0.67	0.78	0.88	0.95	1.01	1.05	1.07	1.08	1.08
150	0.35	0.33	0.30	0.30	0.30	0.32	0.37	0.46	0.61	0.76	0.91	1.02	1.10	1.13	1.16	1.19	1.21	1.22	1.23
160	0.35	0.32	0.30	0.29	0.30	0.34	0.43	0.58	0.76	0.94	1.07	1.13	1.15	1.17	1.19	1.22	1.23	1.25	1.28
170	0.35	0.32	0.29	0.29	0.31	0.36	0.48	0.66	0.87	1.04	1.13	1.15	1.16	1.16	1.15	1.14	1.09	1.05	1.08
180	0.35	0.32	0.29	0.29	0.32	0.37	0.50	0.70	0.92	1.08	1.14	1.14	1.14	1.13	1.08	1.00	0.86	0.82	0.88

H_b Range:-90 - 90DEGH_b Interval: 0.5DEG

Test Speed: HIGH

Temperature:25.3DEG

Operators:

Test Date:2025-02-06

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:Astra D65-65mm-RGBW 6500K-20D-Rev2	TYPE:RGBW-6500K	WEIGHT:
SPEC.:20 DEG	DIA.:65MM	SERIAL No.:IES003426
MFR.:	SUR.:1	Shielding Angle:

Table--2

UNIT: cd

H(°) \ V(°)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90
-180	0.86	0.81	0.73	0.63	0.49	0.35	0.21	0.09	0.05	0.05	0.09	0.13	0.17	0.17	0.16	0.14	0.12	0.14
-170	0.90	0.85	0.76	0.63	0.49	0.34	0.20	0.09	0.05	0.06	0.09	0.13	0.17	0.17	0.16	0.14	0.12	0.14
-160	0.81	0.73	0.63	0.50	0.37	0.25	0.14	0.07	0.05	0.06	0.10	0.14	0.17	0.17	0.16	0.14	0.12	0.14
-150	0.52	0.45	0.37	0.29	0.20	0.12	0.08	0.06	0.06	0.08	0.12	0.16	0.17	0.17	0.16	0.13	0.12	0.14
-140	0.21	0.18	0.15	0.11	0.08	0.06	0.05	0.06	0.08	0.12	0.15	0.16	0.17	0.16	0.15	0.14	0.12	0.14
-130	0.06	0.05	0.05	0.05	0.06	0.07	0.08	0.10	0.13	0.15	0.16	0.17	0.17	0.16	0.14	0.13	0.13	0.14
-120	0.07	0.07	0.08	0.09	0.11	0.12	0.14	0.15	0.16	0.17	0.17	0.17	0.16	0.15	0.14	0.13	0.13	0.14
-110	0.15	0.15	0.16	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.16	0.15	0.14	0.14	0.13	0.13	0.13	0.14
-100	0.18	0.18	0.17	0.17	0.17	0.16	0.16	0.16	0.16	0.15	0.15	0.14	0.14	0.14	0.13	0.13	0.13	0.14
-90	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14	0.14
-80	0.20	0.21	0.21	0.21	0.21	0.20	0.20	0.19	0.19	0.19	0.18	0.18	0.17	0.16	0.16	0.15	0.14	0.14
-70	0.49	0.49	0.49	0.48	0.46	0.44	0.42	0.39	0.36	0.33	0.30	0.27	0.23	0.21	0.19	0.16	0.15	0.14
-60	0.98	0.97	0.95	0.91	0.86	0.81	0.74	0.67	0.60	0.53	0.47	0.40	0.34	0.29	0.23	0.19	0.16	0.14
-50	2.02	1.98	1.88	1.74	1.58	1.41	1.24	1.08	0.92	0.79	0.66	0.56	0.46	0.36	0.29	0.22	0.16	0.14
-40	5.30	5.07	4.60	3.93	3.27	2.66	2.15	1.72	1.38	1.12	0.90	0.72	0.57	0.45	0.33	0.24	0.17	0.14
-30	23.0	20.5	16.5	12.1	8.54	5.82	3.97	2.81	2.06	1.53	1.16	0.90	0.68	0.52	0.38	0.27	0.18	0.14
-20	131	107	73.7	44.0	25.1	14.0	7.84	4.60	2.94	2.01	1.44	1.05	0.79	0.59	0.42	0.29	0.19	0.14
-10	550	430	265	135	61.7	28.6	13.7	6.93	3.91	2.48	1.67	1.18	0.86	0.63	0.45	0.30	0.19	0.14
0	762	690	456	226	95.1	40.2	17.8	8.38	4.40	2.69	1.78	1.24	0.89	0.65	0.46	0.31	0.19	0.14
10	349	324	222	121	57.5	27.5	13.6	7.04	4.03	2.58	1.75	1.23	0.90	0.65	0.46	0.31	0.20	0.14
20	72.7	72.6	57.1	37.2	22.9	13.6	8.01	4.86	3.18	2.20	1.58	1.15	0.86	0.63	0.45	0.31	0.19	0.14
30	16.1	16.1	14.3	11.5	8.69	6.20	4.39	3.20	2.37	1.78	1.34	1.02	0.77	0.58	0.42	0.29	0.19	0.14
40	5.92	5.73	5.30	4.63	3.93	3.26	2.67	2.16	1.73	1.38	1.09	0.86	0.68	0.52	0.38	0.27	0.18	0.14
50	3.06	2.93	2.74	2.51	2.25	1.99	1.72	1.47	1.24	1.04	0.85	0.70	0.56	0.44	0.34	0.25	0.18	0.14
60	1.77	1.70	1.61	1.50	1.38	1.25	1.12	0.99	0.87	0.75	0.64	0.54	0.45	0.37	0.29	0.22	0.17	0.14
70	1.02	0.99	0.94	0.89	0.84	0.78	0.72	0.65	0.59	0.52	0.46	0.41	0.34	0.30	0.25	0.20	0.16	0.14
80	0.61	0.59	0.56	0.54	0.51	0.48	0.45	0.42	0.39	0.36	0.33	0.30	0.26	0.24	0.21	0.18	0.16	0.14
90	0.44	0.42	0.40	0.39	0.37	0.35	0.33	0.31	0.30	0.28	0.26	0.24	0.23	0.21	0.19	0.17	0.16	0.14
100	0.33	0.32	0.31	0.30	0.29	0.28	0.27	0.26	0.25	0.24	0.22	0.21	0.20	0.19	0.17	0.16	0.15	0.14
110	0.29	0.28	0.28	0.27	0.26	0.26	0.25	0.24	0.24	0.23	0.22	0.21	0.19	0.18	0.16	0.15	0.14	0.14
120	0.34	0.32	0.30	0.27	0.26	0.25	0.24	0.23	0.23	0.22	0.22	0.20	0.19	0.18	0.17	0.15	0.14	0.14
130	0.67	0.60	0.52	0.45	0.38	0.31	0.27	0.24	0.22	0.22	0.21	0.20	0.19	0.18	0.17	0.15	0.14	0.14
140	0.99	0.89	0.78	0.67	0.55	0.45	0.35	0.27	0.22	0.20	0.21	0.20	0.19	0.18	0.17	0.15	0.13	0.14
150	1.13	1.03	0.91	0.78	0.65	0.51	0.40	0.30	0.23	0.19	0.18	0.20	0.19	0.19	0.17	0.14	0.13	0.14
160	1.18	1.07	0.95	0.81	0.67	0.53	0.39	0.28	0.21	0.16	0.15	0.17	0.18	0.18	0.17	0.14	0.13	0.14
170	1.03	0.98	0.89	0.77	0.63	0.47	0.33	0.20	0.14	0.12	0.12	0.15	0.18	0.18	0.16	0.15	0.12	0.14
180	0.86	0.81	0.73	0.63	0.49	0.35	0.21	0.09	0.05	0.05	0.09	0.13	0.17	0.17	0.16	0.14	0.12	0.14

H_b Range: -90 - 90DEGH_b Interval: 0.5DEG

Test Speed: HIGH

Temperature: 25.3DEG

Operators:

Test Date: 2025-02-06

V(B) Range: -180 - 180DEG

V(B) Interval: 0.5DEG

Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity: 65.0%

Test Distance: 8.630m [K=1.0000]

Remarks: