

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	1407.5 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	83.5V x 81.9H
	At 50% of Imax	43.3V x 43.4H
	At 90% of Imax	18.5V x 17.8H

Beam Flux	Total	999.8 lumens per klm.
	To 10% of Imax	856.8 lumens per klm.
	To 50% of Imax	479.5 lumens per klm.
	To 90% of Imax	124.4 lumens per klm.

Upward LOR	2.0 %
Downward LOR	98.0 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:
Test Date:2025-02-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME:Astra D65-65mm-RGBW 6500K-40D-Rev2	TYPE:RGBW-6500K	WEIGHT:
SPEC.:40 DEG	DIA.:65MM	SERIAL No.:IES003442
MFR.:	SUR.:1	Shielding Angle:



DATA OF LAMP		Eff:60.61lm/W	
MODEL		Imax(cd)	204.8
NOMINAL POWER(W)	2.4	AVAILABILITY(%)	85.7
RATED VOLTAGE(V)	24	Avai. FLUX(lm)	124.7
NOMINAL FLUX(lm)	145.5	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	145.5
TEST VOLTAGE(V)	24	q @50%(H,V)	43,43DEG

72 64 56 48 40 32 24 -24 -32 -40 -48 -56 -64 -72 -72	AREA FLUX DIAGRAM																UNIT:lm				F t	F a
	0.00	0.01	0.01	0.02	0.03	0.03	0.04	0.04	0.05	0.05	0.04	0.04	0.03	0.03	0.02	0.01	0.01	0.01	0.47	0.00		
0.01	0.01	0.02	0.03	0.04	0.05	0.06	0.07	0.07	0.08	0.07	0.06	0.05	0.04	0.03	0.02	0.01	0.01	0.01	0.73	0.00		
0.01	0.01	0.02	0.04	0.05	0.07	0.10	0.12	0.14	0.14	0.14	0.12	0.09	0.07	0.04	0.03	0.02	0.01	1.21	0.00			
0.01	0.02	0.03	0.05	0.08	0.12	0.18	0.24	0.29	0.31	0.30	0.25	0.18	0.11	0.07	0.04	0.02	0.01	2.30	0.12			
0.01	0.02	0.04	0.07	0.12	0.21	0.33	0.47	0.58	0.63	0.60	0.49	0.35	0.21	0.11	0.05	0.03	0.01	4.33	2.97			
0.01	0.02	0.05	0.09	0.17	0.33	0.57	0.85	1.08	1.19	1.12	0.88	0.60	0.35	0.17	0.07	0.03	0.01	7.59	6.67			
0.01	0.03	0.05	0.11	0.23	0.48	0.88	1.42	1.92	2.12	1.93	1.47	0.93	0.52	0.25	0.10	0.04	0.01	12.5	11.7			
0.01	0.03	0.06	0.12	0.29	0.62	1.21	2.11	2.96	3.23	2.87	2.14	1.32	0.69	0.32	0.12	0.04	0.02	18.1	17.5			
0.01	0.03	0.06	0.13	0.31	0.68	1.38	2.49	3.51	3.85	3.51	2.67	1.64	0.82	0.37	0.14	0.04	0.02	21.6	21.0			
0.01	0.03	0.06	0.13	0.31	0.70	1.42	2.52	3.53	3.87	3.54	2.71	1.66	0.83	0.37	0.14	0.04	0.02	21.9	21.3			
0.01	0.03	0.06	0.13	0.30	0.67	1.31	2.22	3.07	3.34	2.98	2.24	1.37	0.71	0.32	0.12	0.04	0.02	18.9	18.3			
0.01	0.03	0.05	0.11	0.25	0.54	1.00	1.62	2.18	2.38	2.13	1.59	0.99	0.54	0.25	0.09	0.03	0.01	13.8	13.1			
0.01	0.02	0.04	0.09	0.18	0.38	0.67	1.02	1.32	1.43	1.29	0.98	0.64	0.36	0.17	0.07	0.03	0.01	8.73	7.87			
0.01	0.02	0.03	0.06	0.12	0.23	0.38	0.57	0.72	0.77	0.70	0.54	0.37	0.21	0.10	0.05	0.02	0.01	4.91	3.73			
0.01	0.02	0.03	0.04	0.07	0.12	0.19	0.27	0.33	0.36	0.33	0.26	0.18	0.11	0.06	0.03	0.02	0.01	2.44	0.43			
0.01	0.01	0.02	0.03	0.05	0.06	0.09	0.11	0.13	0.14	0.13	0.11	0.08	0.06	0.04	0.02	0.01	0.01	1.12	0.00			
0.01	0.01	0.02	0.02	0.03	0.04	0.05	0.05	0.06	0.06	0.06	0.05	0.04	0.03	0.02	0.02	0.01	0.01	0.57	0.00			
0.00	0.01	0.01	0.01	0.02	0.02	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.02	0.02	0.02	0.01	0.01	0.00	0.33	0.00		
	-64	-56	-48	-40	-32	-24	-16	HORIZONTAL (DEG)				16	24	32	40	48	56	64	72			
F t	0.17	0.35	0.65	1.27	2.65	5.34	9.88	16.2	22.0	24.0	21.8	16.6	10.5	5.69	2.73	1.12	0.46	0.20	142	---		
F a	0.00	0.00	0.00	0.00	0.64	4.05	8.78	15.2	21.0	23.0	20.8	15.7	9.56	4.62	1.29	0.00	0.00	0.00	---	125		

one-half-peak spread: U:22.5,D:21.1 , L:22.3,R:21.4


NEMA Beam Type: Type 5

H_(b) Range: -90 - 90DEG
 H_(b) Interval: 0.5DEG
 Test Speed: LOW
 Temperature: 25.3DEG
 Operators:
 Test Date: 2025-02-06

V(B) Range: -180 - 180DEG
 V(B) Interval: 0.5DEG
 Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
 Humidity: 65.0%
 Test Distance: 8.630m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

NAME:Astra D65-65mm-RGBW 6500K-40D-Rev2	TYPE:RGBW-6500K	WEIGHT:
SPEC.:40 DEG	DIA.:65MM	SERIAL No.:IES003442
MFR.:	SUR.:1	Shielding Angle:




H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:
Test Date:2025-02-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME:Astra D65-65mm-RGBW 6500K-40D-Rev2	TYPE:RGBW-6500K	WEIGHT:
SPEC.:40 DEG	DIA.:65MM	SERIAL No.:IES003442
MFR.:	SUR.:1	Shielding Angle:



H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:
Test Date:2025-02-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H(b) Range: -90 - 90DEG
H(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators:
Test Date: 2025-02-06

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME:Astra D65-65mm-RGBW 6500K-40D-Rev2	TYPE:RGBW-6500K	WEIGHT:
SPEC.:40 DEG	DIA.:65MM	SERIAL No.:IES003442
MFR.:	SUR.:1	Shielding Angle:



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:
Test Date:2025-02-06

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:Astra D65-65mm-RGBW 6500K-40D-Rev2	TYPE:RGBW-6500K	WEIGHT:
SPEC.:40 DEG	DIA.:65MM	SERIAL No.:IES003442
MFR.:	SUR.:1	Shielding Angle:

Table--1

UNIT: cd

H(°)\V(°)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	0.44	0.44	0.45	0.46	0.49	0.54	0.64	0.73	0.82	0.92	0.98	1.01	1.01	1.00	0.99	0.94	0.93	0.88	0.93
-170	0.44	0.43	0.44	0.45	0.48	0.51	0.59	0.67	0.76	0.83	0.89	0.92	0.91	0.91	0.90	0.88	0.86	0.85	0.82
-160	0.44	0.43	0.43	0.43	0.45	0.49	0.54	0.61	0.67	0.72	0.77	0.80	0.81	0.80	0.80	0.78	0.76	0.74	0.70
-150	0.44	0.43	0.42	0.42	0.43	0.45	0.48	0.52	0.57	0.60	0.64	0.66	0.67	0.67	0.65	0.63	0.60	0.57	0.52
-140	0.44	0.43	0.41	0.41	0.41	0.41	0.43	0.45	0.47	0.49	0.51	0.51	0.51	0.50	0.49	0.46	0.43	0.39	0.34
-130	0.44	0.42	0.41	0.40	0.39	0.39	0.39	0.39	0.38	0.39	0.39	0.39	0.38	0.37	0.34	0.31	0.28	0.24	0.19
-120	0.44	0.42	0.41	0.39	0.38	0.37	0.35	0.34	0.34	0.33	0.32	0.30	0.29	0.27	0.24	0.22	0.19	0.17	0.14
-110	0.44	0.42	0.40	0.39	0.37	0.35	0.34	0.32	0.31	0.29	0.28	0.26	0.24	0.22	0.20	0.18	0.16	0.14	0.12
-100	0.44	0.42	0.40	0.39	0.37	0.35	0.33	0.31	0.29	0.28	0.26	0.24	0.22	0.21	0.19	0.17	0.15	0.13	0.11
-90	0.44	0.42	0.40	0.39	0.37	0.35	0.33	0.32	0.30	0.28	0.26	0.25	0.23	0.21	0.20	0.18	0.16	0.14	0.13
-80	0.44	0.42	0.41	0.39	0.39	0.39	0.39	0.40	0.42	0.43	0.45	0.46	0.48	0.49	0.49	0.50	0.49	0.48	0.47
-70	0.44	0.42	0.43	0.44	0.50	0.56	0.64	0.72	0.80	0.88	0.96	1.03	1.10	1.16	1.20	1.23	1.25	1.26	1.25
-60	0.44	0.43	0.45	0.54	0.67	0.81	0.97	1.14	1.32	1.50	1.69	1.88	2.07	2.25	2.42	2.59	2.73	2.82	2.85
-50	0.44	0.45	0.52	0.67	0.87	1.10	1.36	1.65	1.98	2.33	2.77	3.31	3.97	4.76	5.70	6.69	7.59	8.31	8.73
-40	0.44	0.45	0.58	0.80	1.07	1.40	1.79	2.22	2.78	3.55	4.62	6.23	8.45	11.3	14.7	18.5	22.0	24.9	26.7
-30	0.44	0.46	0.63	0.91	1.26	1.69	2.19	2.84	3.77	5.22	7.57	11.2	16.6	23.5	31.9	41.1	50.0	57.5	62.5
-20	0.44	0.47	0.69	1.01	1.42	1.93	2.56	3.42	4.75	7.02	10.9	17.2	26.6	39.0	54.5	73.0	92.5	110	121
-10	0.44	0.48	0.72	1.07	1.53	2.09	2.81	3.80	5.38	8.12	13.1	21.3	33.4	50.2	74.0	104	137	165	183
0	0.44	0.48	0.73	1.09	1.57	2.16	2.89	3.88	5.39	7.89	12.5	20.5	32.1	48.7	73.5	107	145	175	194
10	0.44	0.48	0.73	1.09	1.56	2.14	2.87	3.85	5.37	7.95	12.6	20.1	31.3	46.8	69.4	99.2	133	161	179
20	0.44	0.48	0.71	1.05	1.48	2.03	2.69	3.56	4.81	6.86	10.3	15.8	23.9	34.4	47.6	63.6	81.0	96.3	106
30	0.44	0.48	0.66	0.97	1.35	1.82	2.37	3.06	3.97	5.29	7.32	10.5	14.9	20.5	27.2	34.2	41.0	46.5	49.8
40	0.44	0.47	0.61	0.87	1.17	1.55	1.99	2.50	3.11	3.86	4.84	6.22	8.06	10.5	13.2	16.1	18.8	20.9	22.2
50	0.44	0.46	0.56	0.74	0.98	1.25	1.57	1.93	2.33	2.76	3.26	3.80	4.43	5.14	5.95	6.75	7.50	8.10	8.46
60	0.44	0.45	0.50	0.62	0.78	0.96	1.17	1.40	1.64	1.90	2.16	2.43	2.70	2.96	3.22	3.44	3.63	3.77	3.86
70	0.44	0.45	0.47	0.51	0.60	0.70	0.81	0.94	1.06	1.20	1.32	1.46	1.59	1.71	1.82	1.91	1.99	2.06	2.10
80	0.44	0.44	0.45	0.47	0.49	0.51	0.54	0.58	0.63	0.68	0.72	0.77	0.82	0.86	0.90	0.94	0.97	1.00	1.02
90	0.44	0.44	0.45	0.46	0.46	0.47	0.47	0.48	0.49	0.49	0.50	0.50	0.51	0.52	0.52	0.53	0.53	0.54	0.55
100	0.44	0.44	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45
110	0.44	0.44	0.44	0.44	0.44	0.44	0.44	0.45	0.45	0.44	0.45	0.44	0.45	0.45	0.44	0.44	0.44	0.44	0.43
120	0.44	0.44	0.44	0.44	0.44	0.45	0.45	0.45	0.46	0.47	0.48	0.47	0.49	0.50	0.51	0.51	0.51	0.51	0.50
130	0.44	0.44	0.44	0.44	0.45	0.46	0.47	0.48	0.49	0.53	0.56	0.59	0.62	0.65	0.67	0.67	0.69	0.69	0.68
140	0.44	0.44	0.44	0.45	0.46	0.47	0.50	0.54	0.58	0.64	0.68	0.74	0.78	0.82	0.85	0.88	0.88	0.89	0.88
150	0.44	0.44	0.44	0.45	0.46	0.49	0.54	0.60	0.67	0.74	0.81	0.87	0.92	0.96	0.98	1.00	1.04	1.05	1.05
160	0.44	0.44	0.44	0.45	0.48	0.52	0.59	0.67	0.75	0.83	0.90	0.96	0.99	1.03	1.04	1.04	1.04	1.06	1.07
170	0.44	0.44	0.44	0.45	0.49	0.53	0.61	0.70	0.80	0.89	0.96	1.00	1.02	1.02	1.02	1.00	1.00	1.02	1.05
180	0.44	0.44	0.45	0.46	0.49	0.54	0.64	0.73	0.82	0.92	0.98	1.01	1.01	1.00	0.99	0.94	0.93	0.88	0.96

H_(b) Range:-90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:

Test Date:2025-02-06

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME:Astra D65-65mm-RGBW 6500K-40D-Rev2	TYPE:RGBW-6500K	WEIGHT:
SPEC.:40 DEG	DIA.:65MM	SERIAL No.:IES003442
MFR.:	SUR.:1	Shielding Angle:

Table--2

UNIT: cd

H(°) \ V(°)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90
-180	0.75	0.68	0.61	0.52	0.44	0.35	0.27	0.19	0.14	0.11	0.11	0.11	0.11	0.11	0.11	0.18	0.41	0.42
-170	0.76	0.70	0.62	0.54	0.45	0.35	0.27	0.20	0.14	0.12	0.12	0.11	0.11	0.11	0.11	0.18	0.41	0.42
-160	0.66	0.61	0.54	0.47	0.39	0.32	0.24	0.17	0.14	0.12	0.12	0.11	0.11	0.11	0.12	0.20	0.41	0.42
-150	0.50	0.45	0.41	0.35	0.29	0.23	0.18	0.15	0.13	0.12	0.12	0.11	0.11	0.11	0.12	0.22	0.40	0.42
-140	0.32	0.29	0.26	0.23	0.20	0.17	0.15	0.13	0.12	0.12	0.12	0.11	0.11	0.11	0.14	0.28	0.38	0.42
-130	0.19	0.18	0.16	0.16	0.15	0.13	0.12	0.12	0.12	0.12	0.11	0.11	0.12	0.12	0.19	0.35	0.36	0.42
-120	0.13	0.13	0.12	0.12	0.12	0.12	0.12	0.11	0.11	0.11	0.11	0.12	0.13	0.17	0.28	0.39	0.36	0.42
-110	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.14	0.16	0.21	0.30	0.37	0.35	0.38	0.42
-100	0.12	0.12	0.13	0.13	0.14	0.15	0.17	0.19	0.23	0.26	0.29	0.32	0.33	0.32	0.33	0.36	0.39	0.42
-90	0.14	0.16	0.18	0.19	0.21	0.22	0.24	0.26	0.27	0.29	0.31	0.32	0.34	0.35	0.37	0.39	0.40	0.42
-80	0.49	0.50	0.50	0.50	0.51	0.50	0.49	0.48	0.47	0.46	0.45	0.44	0.43	0.43	0.43	0.43	0.43	0.42
-70	1.28	1.29	1.28	1.26	1.23	1.18	1.11	1.04	0.95	0.87	0.78	0.66	0.62	0.55	0.50	0.48	0.45	0.42
-60	2.91	2.90	2.81	2.68	2.51	2.32	2.10	1.89	1.67	1.46	1.27	1.07	0.90	0.70	0.61	0.52	0.47	0.42
-50	8.93	8.72	8.15	7.28	6.24	5.22	4.28	3.46	2.82	2.31	1.89	1.54	1.24	0.97	0.71	0.58	0.49	0.42
-40	27.1	26.1	23.9	20.8	17.2	13.6	10.1	7.24	5.14	3.68	2.74	2.09	1.60	1.21	0.88	0.65	0.51	0.42
-30	63.4	60.5	54.5	46.3	37.6	29.2	21.5	14.8	9.58	6.04	3.93	2.74	1.98	1.45	1.03	0.71	0.53	0.42
-20	123	117	104	87.0	67.9	50.2	36.0	24.8	15.8	9.34	5.48	3.43	2.33	1.65	1.14	0.73	0.54	0.42
-10	183	173	156	131	102	73.2	50.1	33.8	21.6	12.5	6.90	4.03	2.61	1.79	1.21	0.75	0.55	0.42
0	203	200	183	155	122	86.6	57.8	38.3	24.5	14.2	7.65	4.33	2.75	1.85	1.25	0.76	0.56	0.42
10	179	169	151	126	98.5	71.1	49.0	33.3	21.4	12.5	6.96	4.09	2.66	1.82	1.23	0.76	0.56	0.42
20	109	105	94.8	80.1	63.3	47.5	34.6	24.2	15.6	9.40	5.61	3.56	2.43	1.71	1.18	0.75	0.55	0.42
30	52.3	51.5	47.6	41.6	34.6	27.6	20.7	14.5	9.65	6.23	4.15	2.92	2.11	1.54	1.08	0.74	0.54	0.42
40	23.1	22.9	21.6	19.3	16.4	13.2	10.1	7.46	5.45	4.00	3.01	2.30	1.75	1.31	0.95	0.68	0.53	0.42
50	8.71	8.63	8.22	7.52	6.62	5.68	4.77	3.94	3.25	2.66	2.17	1.76	1.39	1.08	0.78	0.62	0.51	0.42
60	3.86	3.80	3.66	3.47	3.22	2.95	2.65	2.36	2.07	1.79	1.52	1.27	1.05	0.80	0.68	0.57	0.49	0.42
70	2.07	2.03	1.96	1.88	1.78	1.66	1.54	1.40	1.27	1.13	1.00	0.83	0.75	0.66	0.58	0.52	0.48	0.42
80	1.00	0.98	0.95	0.91	0.88	0.85	0.80	0.76	0.71	0.67	0.62	0.59	0.56	0.53	0.50	0.48	0.45	0.42
90	0.54	0.53	0.52	0.52	0.51	0.50	0.50	0.49	0.48	0.48	0.47	0.46	0.45	0.45	0.44	0.43	0.43	0.42
100	0.44	0.42	0.40	0.39	0.39	0.38	0.38	0.39	0.40	0.41	0.43	0.43	0.43	0.40	0.39	0.40	0.41	0.42
110	0.41	0.39	0.38	0.36	0.34	0.32	0.30	0.28	0.27	0.26	0.26	0.27	0.30	0.38	0.42	0.39	0.40	0.42
120	0.47	0.44	0.41	0.38	0.35	0.32	0.29	0.28	0.26	0.24	0.22	0.21	0.21	0.24	0.33	0.42	0.38	0.42
130	0.64	0.59	0.53	0.48	0.43	0.38	0.33	0.29	0.26	0.23	0.21	0.20	0.18	0.18	0.23	0.38	0.38	0.42
140	0.82	0.75	0.67	0.59	0.51	0.44	0.37	0.31	0.27	0.23	0.20	0.19	0.17	0.16	0.18	0.31	0.39	0.42
150	0.97	0.89	0.77	0.68	0.58	0.48	0.39	0.32	0.27	0.23	0.19	0.17	0.16	0.15	0.15	0.24	0.41	0.42
160	0.98	0.89	0.80	0.71	0.61	0.50	0.40	0.31	0.25	0.20	0.18	0.16	0.14	0.14	0.14	0.21	0.41	0.42
170	0.94	0.85	0.75	0.65	0.56	0.45	0.35	0.27	0.20	0.16	0.15	0.14	0.13	0.13	0.12	0.19	0.41	0.42
180	0.75	0.68	0.61	0.52	0.44	0.35	0.27	0.19	0.14	0.11	0.11	0.11	0.11	0.11	0.11	0.18	0.41	0.42

H_(b) Range:-90 - 90DEGH_(b) Interval: 0.5DEG

Test Speed: LOW

Temperature:25.3DEG

Operators:

Test Date:2025-02-06

V(B) Range:-180 - 180DEG

V(B) Interval: 0.5DEG

Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351

Humidity:65.0%

Test Distance:8.630m [K=1.0000]

Remarks: