

Test report

Light measurement results

Laboratory and Equipment

Test lab
Spectrometer Manufacturer and Model
Measurement date

n/a - serial: n/a sensor serial: n/a
n/a, n/a – n/a
5/5/2025

Measurement Conditions

Tested c-planes
Tested gamma angles
Input Power

9 – distance {C_PLANES_DIST}°
361 – {H_PLANES_DIST}°
11.8 W


Tested Light Source
Luminaire
Basic Luminous Shape
Item No.
Manufacturer

Blazeline Max-598mm-TW-6000K-30D-Rev2
NONE
Luminoscape

Main Light Measurement Results
Output – Total Lumen (Up% / Down%)
Efficiency
Peak Intensity
Correlated Color Temperature, CCT
Color Rendering Index

1016 lm – 2.31% / 97.69%
86 lm/W
2550 cd
6000 K
CRI 80.0


Polar light distribution diagram



Test report


Light measurement results

Beam details



Luminaire budgetary diagram


LAMPS (number of lamps)




Test report

Light measurement results

Iso-intensity Diagram (Iso-candela)




Iso-illuminance Diagram (Iso-lux)



Test report


Light measurement results

Linear intensity distribution



IESNA TM-15-07 Luminaire Classification System For Outdoor Luminaires

BUG rating B1 U2 G0



Forward Light

Low (0-30°)	407	lm	40.1%
Medium (30-60°)	83.3	lm	8.2%
High (60-80°)	4.8	lm	0.5%
Very High	0.9	lm	0.1%

Back Light

Low (0-30°)	390.2	lm	38.4%
Medium (30-60°)	95.1	lm	9.4%
High (60-80°)	9.1	lm	0.9%
Very High	2.2	lm	0.2%

Uplight

Low (90-100°)	2.7	lm	0.3%
High (100-180°)	20.8	lm	2%

Total

Sum	1016	lm	100%
-----	------	----	------