

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	217.6 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	285.8V x 159.1H
	At 50% of Imax	172.4V x 109.1H
	At 90% of Imax	70.8V x 46.3H

Beam Flux	Total	1000.1 lumens per klm.
	To 10% of Imax	971.7 lumens per klm.
	To 50% of Imax	677.9 lumens per klm.
	To 90% of Imax	162.9 lumens per klm.

Upward LOR	17.8 %
Downward LOR	82.3 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

H_(b) Range:-90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature:25.3DEG
Operators:Fan
Test Date:2023-06-26

V(B) Range:-180 - 180DEG
V(B) Interval: 0.5DEG
Test System:EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity:65.0%
Test Distance:8.630m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME: Maya-Round Acrylic-600mm-RGBW ALL-110 170D-Rev2	TYPE: RGBW W=3000K	WEIGHT:
SPEC.: 110x170 DEG	DIM.: 600mm	SERIAL No.: IES001173
MFR.:	SUR.:	Shielding Angle:



DATA OF LAMP		Eff: 26.41lm/W	
MODEL	MAYA.06.14(30)	Imax(cd)	98.82
NOMINAL POWER(W)	17.2	AVAILABILITY(%)	96.4
RATED VOLTAGE(V)	220	Avai. FLUX(lm)	437.8
NOMINAL FLUX(lm)	454.2	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	454.2
TEST VOLTAGE(V)	220	q @50%(H,V)	109,172DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT: lm		F t	F a
	0.02	0.11	0.27	0.50	0.77	1.01	1.22	1.42	1.58	1.58	1.42	1.23	1.01	0.77	0.50	0.26	0.10	0.02	13.8	13.7
90	0.02	0.11	0.27	0.50	0.77	1.01	1.22	1.42	1.58	1.58	1.42	1.23	1.01	0.77	0.50	0.26	0.10	0.02	13.8	13.7
80	0.02	0.12	0.30	0.58	0.90	1.19	1.46	1.69	1.87	1.87	1.70	1.47	1.20	0.91	0.58	0.30	0.11	0.02	16.3	16.3
70	0.02	0.13	0.35	0.66	1.04	1.39	1.70	1.96	2.16	2.16	1.96	1.70	1.39	1.04	0.66	0.34	0.12	0.02	18.8	18.8
60	0.02	0.14	0.39	0.74	1.16	1.57	1.92	2.21	2.41	2.41	2.21	1.92	1.57	1.16	0.74	0.38	0.14	0.02	21.1	21.1
50	0.02	0.15	0.42	0.81	1.27	1.72	2.11	2.42	2.63	2.63	2.42	2.12	1.73	1.26	0.81	0.42	0.15	0.02	23.1	23.1
40	0.02	0.16	0.45	0.87	1.35	1.84	2.27	2.59	2.80	2.80	2.59	2.27	1.84	1.34	0.86	0.44	0.15	0.02	24.7	24.6
30	0.02	0.16	0.46	0.90	1.41	1.93	2.39	2.72	2.91	2.91	2.71	2.38	1.92	1.39	0.88	0.45	0.15	0.02	25.7	25.7
20	0.02	0.15	0.46	0.91	1.44	1.97	2.45	2.79	2.97	2.96	2.77	2.42	1.94	1.41	0.89	0.45	0.15	0.02	26.2	26.1
10	0.02	0.15	0.45	0.89	1.42	1.97	2.45	2.80	2.98	2.96	2.77	2.41	1.92	1.38	0.86	0.43	0.14	0.02	26.0	26.0
0	0.02	0.14	0.44	0.88	1.40	1.93	2.40	2.74	2.90	2.92	2.73	2.37	1.89	1.36	0.85	0.42	0.14	0.02	25.6	25.5
-10	0.02	0.15	0.45	0.88	1.38	1.88	2.31	2.62	2.81	2.83	2.65	2.31	1.86	1.36	0.86	0.43	0.14	0.02	25.0	24.9
-20	0.02	0.15	0.44	0.85	1.32	1.78	2.18	2.49	2.68	2.69	2.51	2.20	1.78	1.31	0.84	0.43	0.15	0.02	23.8	23.8
-30	0.02	0.15	0.42	0.80	1.24	1.66	2.04	2.33	2.52	2.53	2.35	2.06	1.67	1.23	0.79	0.41	0.14	0.02	22.4	22.4
-40	0.02	0.14	0.39	0.74	1.14	1.52	1.87	2.15	2.33	2.33	2.16	1.89	1.54	1.14	0.74	0.38	0.13	0.02	20.6	20.6
-50	0.02	0.13	0.35	0.66	1.02	1.37	1.68	1.94	2.11	2.12	1.94	1.69	1.39	1.03	0.66	0.35	0.12	0.02	18.6	18.6
-60	0.02	0.11	0.31	0.59	0.91	1.21	1.48	1.71	1.88	1.88	1.72	1.49	1.22	0.91	0.59	0.31	0.11	0.01	16.4	16.4
-70	0.02	0.10	0.26	0.50	0.78	1.04	1.27	1.48	1.63	1.64	1.48	1.28	1.04	0.78	0.50	0.26	0.09	0.01	14.2	14.1
-80	0.02	0.08	0.20	0.38	0.60	0.82	1.03	1.22	1.38	1.38	1.22	1.03	0.81	0.59	0.37	0.19	0.07	0.01	11.4	11.3
-90	0.02	0.08	0.20	0.38	0.60	0.82	1.03	1.22	1.38	1.38	1.22	1.03	0.81	0.59	0.37	0.19	0.07	0.01	11.4	11.3
-90 -80 -70 -60 -50 -40 -30 -20 HORIZONTAL (DEG) 20 30 40 50 60 70 80 90																				
F t	0.34	2.39	6.80	13.1	20.5	27.8	34.2	39.3	42.5	42.6	39.3	34.2	27.8	20.4	13.0	6.67	2.30	0.29	374	---
F a	0.05	2.34	6.80	13.1	20.5	27.8	34.2	39.3	42.5	42.6	39.3	34.2	27.8	20.4	13.0	6.67	2.21	0.02	---	373

one-half-peak spread: U:83.3,D:78.3 , L:55.4,R:54.3


NEMA Beam Type: Type 7

H_(b) Range: -90 - 90DEG
 H_(b) Interval: 0.5DEG
 Test Speed: LOW
 Temperature: 25.3DEG
 Operators: Fan
 Test Date: 2023-06-26

V(B) Range: -180 - 180DEG
 V(B) Interval: 0.5DEG
 Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
 Humidity: 65.0%
 Test Distance: 8.630m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

NAME: Maya-Round Acrylic-600mm-RGBW ALL-110 170D-Rev2	TYPE: RGBW W=3000K	WEIGHT:
SPEC.: 110x170 DEG	DIM.: 600mm	SERIAL No.: IES001173
MFR.:	SUR.:	Shielding Angle:




H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-06-26

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME: Maya-Round Acrylic-600mm-RGBW ALL-110 170D-Rev2	TYPE: RGBW W=3000K	WEIGHT:
SPEC.: 110x170 DEG	DIM.: 600mm	SERIAL No.: IES001173
MFR.:	SUR.:	Shielding Angle:



H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-06-26

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

Planar Illuminance Curve




H_b Range: -90 - 90DEG
H_b Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-06-26

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

AAI CURVES

NAME: Maya-Round Acrylic-600mm-RGBW ALL-110 170D-Rev2	TYPE: RGBW W=3000K	WEIGHT:
SPEC.: 110x170 DEG	DIM.: 600mm	SERIAL No.: IES001173
MFR.:	SUR.:	Shielding Angle:



Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range: -90 - 90DEG
H_(b) Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-06-26

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: Maya-Round Acrylic-600mm-RGBW ALL-110 170D-Rev2	TYPE: RGBW W=3000K	WEIGHT:
SPEC.: 110x170 DEG	DIM.: 600mm	SERIAL No.: IES001173
MFR.:	SUR.:	Shielding Angle:

Table--1
UNIT: cd

H(°) \ V(°)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-180	2.78	2.80	2.66	2.54	2.42	2.33	2.37	2.36	2.32	2.23	2.12	2.10	2.08	2.07	2.08	2.08	2.02	1.95	2.02
-170	2.78	3.12	3.21	3.27	3.36	3.44	3.56	3.49	3.44	3.34	3.29	3.11	2.94	2.74	1.83	1.80	1.76	1.81	1.85
-160	2.78	3.43	3.76	4.01	4.28	4.55	4.80	4.69	4.68	4.55	4.56	4.37	4.28	3.97	3.64	3.59	3.23	4.25	5.36
-150	2.78	3.72	4.32	4.79	5.17	5.65	6.10	6.28	6.12	6.15	5.98	6.08	6.14	5.86	6.04	6.10	6.31	6.73	7.35
-140	2.78	4.00	4.90	5.57	6.12	6.72	7.38	7.93	8.21	7.99	8.18	8.22	8.25	8.79	9.22	9.31	9.40	9.84	10.5
-130	2.78	4.24	5.43	6.36	7.13	7.78	8.56	9.41	10.2	10.8	11.1	11.1	11.6	12.4	13.0	13.8	14.7	15.7	16.8
-120	2.78	4.46	5.93	7.15	8.19	9.11	9.92	10.7	11.7	12.7	13.7	14.9	15.9	16.8	17.8	18.8	19.9	21.1	22.4
-110	2.78	4.65	6.34	7.89	9.26	10.5	11.7	12.8	13.8	14.7	16.0	17.5	19.1	20.6	22.2	23.8	25.4	27.0	28.7
-100	2.78	4.80	6.69	8.48	10.2	11.9	13.5	15.0	16.5	18.0	19.8	21.7	23.7	25.6	27.5	29.5	31.5	33.6	35.7
-90	2.78	4.93	7.08	9.24	11.4	13.5	15.7	17.8	20.0	22.2	24.5	26.9	29.2	31.6	33.9	36.3	38.7	41.0	43.4
-80	2.78	5.06	7.68	10.7	14.1	17.8	21.8	25.6	29.5	33.2	35.8	38.0	40.2	42.3	44.3	46.2	48.0	49.8	51.6
-70	2.78	5.12	8.42	12.7	17.3	22.0	26.5	31.0	35.3	39.4	42.6	45.2	47.7	50.0	52.2	54.3	56.2	58.0	59.7
-60	2.78	5.14	9.42	14.6	19.9	25.3	30.6	35.7	40.5	44.9	48.8	51.9	54.8	57.4	59.9	62.1	64.1	65.9	67.5
-50	2.78	5.23	10.2	16.1	22.2	28.4	34.5	40.1	45.4	50.2	54.5	58.2	61.5	64.5	67.2	69.6	71.7	73.4	74.9
-40	2.78	5.28	10.8	17.3	24.1	31.1	37.8	44.1	49.9	55.2	59.9	64.0	67.7	71.0	73.9	76.4	78.5	80.2	81.6
-30	2.78	5.24	11.0	18.0	25.5	33.1	40.4	47.3	53.7	59.5	64.8	69.3	73.2	76.5	79.6	82.3	84.4	86.1	87.2
-20	2.78	5.08	10.9	18.2	26.1	34.2	42.0	49.5	56.5	62.9	68.7	73.8	78.1	81.7	84.4	87.0	89.3	90.9	91.8
-10	2.78	4.77	10.5	17.8	25.9	34.2	42.5	50.4	58.0	64.9	71.2	76.9	81.9	86.0	89.2	91.7	92.7	94.3	95.3
0	2.78	4.32	9.63	16.6	24.6	33.0	41.4	49.6	57.5	64.9	71.7	77.9	83.5	88.2	92.1	95.2	97.3	98.5	98.8
10	2.78	4.90	10.7	18.1	26.4	34.9	43.4	51.6	59.5	66.7	73.4	79.5	84.8	89.2	92.8	95.5	97.3	98.3	98.8
20	2.78	5.34	11.4	18.9	27.2	35.6	43.9	51.9	59.5	66.5	72.9	78.7	83.7	88.0	91.5	94.0	95.9	97.3	98.3
30	2.78	5.64	11.7	19.0	27.0	35.1	43.0	50.6	57.8	64.4	70.5	76.0	80.8	84.9	88.1	90.7	92.8	94.5	95.8
40	2.78	5.82	11.6	18.5	25.9	33.5	40.9	48.0	54.7	61.0	66.7	71.9	76.2	79.8	82.9	85.6	87.9	89.8	91.4
50	2.78	5.92	11.3	17.5	24.3	31.1	37.9	44.4	50.6	56.4	61.7	66.2	69.9	73.3	76.3	79.0	81.4	83.4	85.2
60	2.78	5.98	10.7	16.3	22.1	28.2	34.2	40.1	45.7	51.0	55.8	59.3	62.6	65.7	68.5	71.1	73.5	75.6	77.5
70	2.78	6.11	10.1	14.8	19.8	25.0	30.1	35.3	40.3	45.2	48.8	51.8	54.6	57.3	59.9	62.3	64.5	66.6	68.5
80	2.78	6.18	9.75	13.5	17.6	21.8	26.1	30.5	34.8	39.1	41.7	44.0	46.4	48.6	50.8	52.9	55.0	57.0	58.9
90	2.78	6.15	9.52	12.9	16.3	19.6	23.0	26.4	29.7	33.1	34.9	36.7	38.5	40.3	42.1	43.8	45.6	47.4	49.2
100	2.78	6.02	9.11	12.1	14.9	17.6	20.1	22.6	25.0	27.4	28.7	30.0	31.3	32.6	34.0	35.4	36.9	38.4	40.0
110	2.78	5.80	8.56	11.1	13.3	15.3	17.2	19.0	20.6	22.1	23.2	24.0	24.8	25.7	26.6	27.7	28.8	30.0	31.4
120	2.78	5.50	7.88	9.87	11.6	13.1	14.4	15.6	16.6	17.5	18.3	18.6	19.1	19.6	20.2	20.9	21.7	22.6	23.7
130	2.78	5.15	7.08	8.63	9.91	11.0	11.8	12.5	13.1	13.5	13.9	14.2	14.1	14.0	14.3	14.7	15.4	16.2	17.2
140	2.78	4.75	6.24	7.38	8.29	8.99	9.45	9.82	10.1	10.3	9.83	9.65	9.73	9.91	10.1	10.3	10.6	11.1	11.8
150	2.78	4.30	5.34	6.14	6.74	7.10	7.38	7.57	7.56	7.10	7.05	7.06	6.92	6.69	6.56	6.37	6.49	6.77	7.25
160	2.78	3.81	4.44	4.91	5.25	5.41	5.59	5.63	5.32	5.21	5.11	4.87	4.60	4.28	4.11	3.87	3.94	3.94	4.10
170	2.78	3.31	3.55	3.72	3.82	3.84	3.94	3.87	3.73	3.64	3.49	3.29	3.09	2.96	2.89	2.82	2.38	2.32	2.27
180	2.78	2.80	2.66	2.54	2.42	2.33	2.37	2.36	2.32	2.23	2.12	2.10	2.08	2.07	2.08	2.08	2.02	1.95	2.02

H_b Range: -90 - 90DEG
H_b Interval: 0.5DEG
Test Speed: LOW
Temperature: 25.3DEG
Operators: Fan
Test Date: 2023-06-26

V(B) Range: -180 - 180DEG
V(B) Interval: 0.5DEG
Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
Humidity: 65.0%
Test Distance: 8.630m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: Maya-Round Acrylic-600mm-RGBW ALL-110 170D-Rev2	TYPE: RGBW W=3000K	WEIGHT:
SPEC.: 110x170 DEG	DIM.: 600mm	SERIAL No.: IES001173
MFR.:	SUR.:	Shielding Angle:

Table--2

UNIT: cd

H(°) \ V(°)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90
-180	1.82	1.78	1.63	1.54	1.45	1.37	1.36	1.36	1.32	1.27	1.21	1.15	1.08	1.07	1.09	1.10	0.98	0.88
-170	1.84	1.80	1.70	1.62	2.66	2.63	2.58	2.59	2.65	2.57	2.59	2.46	2.32	2.11	1.89	1.70	1.32	0.88
-160	4.26	3.28	2.37	4.28	4.17	4.00	3.87	4.16	4.07	4.09	3.94	3.88	3.55	3.14	2.68	2.31	1.65	0.88
-150	6.84	6.48	6.31	5.98	5.68	5.84	5.98	5.85	5.77	5.79	5.51	5.30	4.76	4.10	3.49	2.90	1.95	0.88
-140	9.77	9.27	9.31	9.28	8.92	8.51	8.08	8.54	7.89	7.64	7.38	6.71	5.92	5.01	4.30	3.46	2.23	0.88
-130	15.7	14.7	13.8	13.2	12.9	12.0	11.2	10.9	10.6	9.86	8.99	8.01	6.90	6.03	5.11	3.98	2.48	0.88
-120	21.0	19.8	18.8	17.8	16.9	15.9	14.9	13.8	12.7	11.5	10.3	9.11	8.16	7.10	5.89	4.39	2.71	0.88
-110	27.0	25.4	23.8	22.3	20.7	19.1	17.5	15.8	14.3	13.2	12.1	10.9	9.56	8.14	6.52	4.76	2.90	0.88
-100	33.5	31.4	29.4	27.4	25.4	23.4	21.4	19.5	17.6	16.0	14.3	12.6	10.8	8.99	7.08	5.11	3.06	0.88
-90	41.0	38.5	36.1	33.7	31.2	28.8	26.4	24.0	21.5	19.2	16.9	14.6	12.4	10.1	7.77	5.47	3.18	0.88
-80	49.9	48.1	46.2	44.3	42.3	40.2	38.0	35.7	33.2	29.3	25.3	21.2	17.2	13.3	9.66	6.25	3.33	0.88
-70	58.1	56.3	54.4	52.4	50.2	47.9	45.5	42.9	39.7	35.4	31.0	26.4	21.7	16.9	12.1	7.49	3.56	0.88
-60	66.0	64.3	62.4	60.2	57.8	55.2	52.4	49.3	45.2	40.6	35.7	30.5	25.1	19.6	14.1	8.66	3.90	0.88
-50	73.6	71.9	69.9	67.7	65.1	62.1	58.9	55.0	50.4	45.4	40.0	34.3	28.2	21.9	15.7	9.60	4.18	0.88
-40	80.4	78.8	76.9	74.6	71.7	68.5	64.7	60.2	55.2	49.7	43.8	37.4	30.7	23.7	16.8	10.2	4.35	0.88
-30	86.3	84.9	83.0	80.5	77.5	73.9	69.6	64.7	59.2	53.2	46.7	39.7	32.5	25.0	17.5	10.5	4.36	0.88
-20	91.3	90.1	88.0	85.4	82.1	78.1	73.5	68.1	62.1	55.6	48.5	41.1	33.3	25.4	17.7	10.4	4.22	0.88
-10	95.0	93.7	92.0	89.2	85.4	80.9	75.7	69.9	63.4	56.4	49.0	41.2	33.2	25.0	17.1	9.89	3.92	0.88
0	98.1	96.4	93.9	90.6	86.3	81.4	75.8	69.5	62.7	55.4	47.8	39.8	31.8	23.7	16.0	8.99	3.46	0.88
10	97.8	96.6	94.7	91.8	88.0	83.3	77.9	71.8	65.1	57.8	50.1	42.1	33.9	25.6	17.5	10.1	4.06	0.88
20	97.1	95.6	93.7	91.1	87.4	83.0	77.8	71.9	65.3	58.3	50.8	42.9	34.7	26.5	18.4	10.8	4.51	0.88
30	94.5	92.7	90.6	88.0	84.9	80.7	75.7	70.0	63.8	57.0	49.9	42.3	34.4	26.4	18.5	11.2	4.80	0.88
40	89.8	87.9	85.7	83.0	79.9	76.4	72.0	66.6	60.7	54.4	47.6	40.5	33.1	25.5	18.1	11.1	4.94	0.88
50	83.5	81.4	79.1	76.5	73.5	70.2	66.5	62.0	56.4	50.5	44.3	37.7	30.9	24.0	17.2	10.7	4.93	0.88
60	75.6	73.6	71.2	68.7	65.9	62.9	59.6	56.2	51.3	45.8	40.1	34.1	28.0	21.9	15.9	10.1	4.81	0.88
70	66.6	64.6	62.4	60.0	57.5	54.9	52.1	49.2	45.5	40.5	35.4	30.1	24.8	19.5	14.3	9.31	4.64	0.88
80	57.0	55.1	53.0	51.0	48.8	46.6	44.3	42.0	39.4	35.0	30.5	26.0	21.6	17.1	12.8	8.51	4.55	0.88
90	47.4	45.7	43.9	42.2	40.4	38.6	36.9	35.1	33.3	29.7	26.1	22.5	18.9	15.3	11.7	8.10	4.49	0.88
100	38.4	36.9	35.4	34.0	32.7	31.3	30.1	28.8	27.5	24.9	22.3	19.6	16.8	13.9	10.8	7.67	4.36	0.88
110	30.0	28.8	27.7	26.6	25.7	24.8	24.0	23.2	22.1	20.4	18.6	16.7	14.6	12.4	9.86	7.10	4.12	0.88
120	22.6	21.6	20.8	20.1	19.5	19.0	18.6	18.2	17.4	16.3	15.2	13.8	12.4	10.7	8.76	6.45	3.81	0.88
130	16.2	15.5	14.9	14.5	14.2	14.0	14.0	13.7	13.2	12.7	12.0	11.2	10.2	8.96	7.51	5.73	3.43	0.88
140	11.0	10.4	10.0	9.81	9.74	9.81	9.90	9.87	9.76	9.55	9.20	8.73	8.11	7.28	6.21	4.88	3.02	0.88
150	6.77	6.45	6.29	6.30	6.30	6.40	6.60	6.79	6.91	6.92	6.81	6.55	6.18	5.65	4.92	3.97	2.56	0.88
160	3.96	3.98	4.09	4.12	4.08	4.15	4.29	4.48	4.65	4.74	4.73	4.61	4.39	4.08	3.63	3.02	2.06	0.88
170	2.38	2.44	2.73	2.68	2.63	2.61	2.68	2.77	2.86	2.91	2.90	2.85	2.71	2.56	2.35	2.06	1.53	0.88
180	1.82	1.78	1.63	1.54	1.45	1.37	1.36	1.36	1.32	1.27	1.21	1.15	1.08	1.07	1.09	1.10	0.98	0.88

H_(b) Range: -90 - 90DEG
 H_(b) Interval: 0.5DEG
 Test Speed: LOW
 Temperature: 25.3DEG
 Operators: Fan
 Test Date: 2023-06-26

V(B) Range: -180 - 180DEG
 V(B) Interval: 0.5DEG
 Test System: EVERFINE G0-2000B_V1 SYSTEM V2.0.351
 Humidity: 65.0%
 Test Distance: 8.630m [K=1.0000]
 Remarks: